



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Sinclair Canyon Upgrade	
Solicitation No. - N° de l'invitation EP922-171805/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client Parks EP922-171805	Date 2016-12-06
GETS Reference No. - N° de référence de SEAG PW-\$PWU-183-10894	
File No. - N° de dossier PWU-6-39215 (183)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-12-09	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Tikhonovitch (RPC), Alex	Buyer Id - Id de l'acheteur pwu183
Telephone No. - N° de téléphone (780) 901-7940 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

The Bidding Documents are amended as noted in this Addendum, which consists of one (1) page and the following attachments:

1. Revised Specifications:

31 63 23 Bored Concrete Piles (Tangent Piles)

2. Drawings:

S101 – Tangent Pile Wall Plan & Section Structural

This addendum is issued prior to bid closing to amend the bid documents. This Addendum will form part of the Contract Documents. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the contract documents.

Acknowledge receipt of this Addendum by reference in the Bid Form submitted by the bidding Contractors. Ensure that all parties submitting bids are aware of all items included in this addendum.

1. SPECIFICATIONS

.1 Section 31 63 23 – Bored Concrete Piles


- .1 Refer to Part 3 Execution – Revise the section 3.1.14 with the following; “Clean pile bases of loose material by a methods approved by the Departmental Representative, and place reinforcing steel and concrete after acceptance by the geotechnical engineer. Perform these operations as soon as possible, but not later than two hours after drilling for each pile. Do not leave any unfilled shafts overnight”.

.2 DRAWINGS

.1 S101 – Tangent Pile Wall Plan & Section Structural

.1 Add the following notes:

- .1 From station STA 1+650 Pile tip elevation to be 995.75 m max. Locate piles max. 2.00 m from lip of gutter
- .2 From station STA 1+685 Pile tip elevation to be 992.5 m max. Locate piles max. 2.50 m from lip of gutter
- .3 From station STA 1+740 Pile tip elevation to be 998.5 m max. Locate piles max. 2.50 m from lip of gutter



END OF ADDENDUM NO. S-01