

**SPLITTERS, JUNCTION, PULL BOXES AND CABINETS****PART 1**      **GENERAL****1.1**            **RELATED SECTIONS**

- .1      Section 01 33 00 – Submittal Procedures.
- .2      Section 26 05 00 – Common Work Requirements – Electrical.

**1.2**            **SUBMITTALS**

- .1      Submit shop drawings and product data for cabinets.
- .2      Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3      Provide drawings stamped and signed by professional engineer registered or licensed in the Province of Newfoundland and Labrador, Canada as required.

**PART 2**      **PRODUCTS****2.1**            **SPLITTERS**

- .1      Sheet metal enclosure, welded corners and formed hinged cover suitable for locking in closed position.
- .2      Main and branch lugs to match required size and number of incoming and outgoing conductors as indicated.
- .3      At least three spare terminals on each set of lugs in splitters less than 400 A.

**2.2**            **JUNCTION AND PULL BOXES**

- .1      Welded steel construction with screw-on flat covers for surface mounting.
- .2      Covers with 25 mm minimum extension all around, for flush-mounted pull and junction boxes.

**2.3**            **CABINETS**

- .1      Type E: sheet steel, hinged door and return flange overlapping sides, handle, lock and catch, for surface mounting.
- .2      Type T: sheet steel cabinet, with hinged door, latch, lock, 2 keys, containing 19 mm fir plywood backboard for surface flush mounting.

**SPLITTERS, JUNCTION, PULL BOXES AND CABINETS****PART 3****EXECUTION****3.1 SPLITTER INSTALLATION**

- .1 Install splitters and mount plumb, true and square to the building lines.
- .2 Extend splitters full length of equipment arrangement except where indicated otherwise.

**3.2 JUNCTION, PULL BOXES AND CABINETS INSTALLATION**

- .1 Install pull boxes in inconspicuous but accessible locations.
- .2 Mount cabinets with top not higher than 2 m above finished floor.
- .3 Install terminal block as indicated in Type T cabinets.
- .4 Only main junction and pull boxes are indicated. Install pull boxes so as not to exceed 30 m of conduit run between pull boxes.

**3.3 IDENTIFICATION**

- .1 Provide equipment identification in accordance with Section 26 05 00 – Common Work Results - Electrical.
- .2 Install size 2 identification labels indicating system name voltage and phase.

**END OF SECTION**