



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet AAFC Facility System Repairs	
Solicitation No. - N° de l'invitation EP922-172162/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client AAFC EP922-172162	Date 2016-12-09
GETS Reference No. - N° de référence de SEAG PW-\$PWU-066-10910	
File No. - N° de dossier PWU-6-39263 (066)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2016-12-14	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Lee, Mony	Buyer Id - Id de l'acheteur pwu066
Telephone No. - N° de téléphone (780) 224-6675 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT No. 004

The below questions and answers are as a result of the Optional Site Visit:

1. Who will decommission and remove the old hot water tanks?

Agriculture and Agri-Foods Canada (AAFC) Lacombe

2. What is the intended route for the water lines?

Follow the existing

3. Where does the electrical panel go in the new mechanical room on the lower floor?

Relocate the panel on the wall separating the workshop and the new mechanical room.

4. Where is the 'baseboard' heater located in the new mechanical room on the lower floor?

Locate the baseboard heater 12" over floor level, close to the south east corner of the new mechanical room.

5. What are the make-up air requirements for the mechanical room on the lower floor?

See MUA schedule in Project.

6. Do we have to paint the entrance wall for the mechanical room on the lower floor?

Yes, where the new double door will be located.

7. What are the controls for the make-up air unit?

One thermostat

8. How does the contractor access the building?

They can access the building directly through the workshop exit door on the main level

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.