

ADDENDUM # 1

Solicitation Number: 16-1307 Title: 16-1307 REPLACEMENT OF IRRIGATION SYSTEM CEF BUILDING 84 Date: December 10, 2016

The following supplements and/or supersedes the Invitation to Tender documents issued on November 30, 2016. This addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. Any change to the cost of the work as a result of this addendum is to be included in the price proposal. The following revisions supersede the information contained in the original Invitation to Tender Package for the above-mentioned project to the extent referenced and shall become part thereof.

Bidders who did not attend or send a representative to the mandatory site visit will not be given an alternative appointment and their bids will be rejected as non-compliant.

Clarifications:

- 1. Provide new isolation valves and install as per note 5 on drawing M-1.
- 2. Suction pit is to be considered as confined space.
- 3. Pump schedule on French language drawing to include under remarks VSD controlled.

Additions:

1. Provide appropriate VSD cable with 1K insulation on load side (between VSD and motor).

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.

End of Addendum #1