

1 GENERAL

1.1 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedure.
- .2 Shop drawings: submit drawings stamped.
- .3 Shop drawings to show:
 - .1 Mounting arrangements.
 - .2 Operating and maintenance clearances.
- .4 Shop drawings and product data accompanied by:
 - .1 Detailed drawings of bases, supports, and anchor bolts.
 - .2 Acoustical sound power data, where applicable.
 - .3 Points of operation on performance curves.
 - .4 Manufacturer to certify current model production.
 - .5 Certification of compliance to applicable codes.
- .5 In addition to transmittal letter referred to in Section 01 33 00 - Submittal Procedures: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .6 Closeout Submittals:
 - .1 Operation and maintenance manual approved by, and final copies deposited with, 01 78 00 - Closeout Submittals Departmental Representative.
 - .2 Operation and maintenance manual approved by, and final copies deposited with Departmental Representative.
 - .3 Operation data to include:
 - .1 Control schematics for systems including environmental controls.
 - .2 Description of systems and their controls.
 - .3 Description of operation of systems at various loads together with reset schedules and seasonal variances.
 - .4 Operation instruction for systems and component.
 - .5 Description of actions to be taken in event of equipment failure.
 - .6 Valves schedule and flow diagram.
 - .7 Colour coding chart.
 - .4 Maintenance data to include:
 - .1 Servicing, maintenance, operation and trouble-shooting instructions for each item of equipment.
 - .2 Data to include schedules of tasks, frequency, tools required and task time.
 - .5 Performance data to include:
 - .1 Equipment manufacturer's performance datasheets with point of operation as left after commissioning is complete.
 - .2 Equipment performance verification test results.
 - .3 Special performance data as specified.
 - .4 Testing, adjusting and balancing reports as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
 - .6 Approvals:

2016-10-19

- .1 Submit 2 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
- .2 Make changes as required and re-submit as directed by [Departmental Representative.
- .7 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
- .8 Site records:
 - .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
- .9 As-built drawings:
 - .1 Prior to start of Testing, Adjusting and Balancing for HVAC, finalize production of as-built drawings.
 - .2 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .3 Submit to Departmental Representative for approval and make corrections as directed.
 - .4 Perform testing, adjusting and balancing for HVAC using as-built drawings.
 - .5 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
- .10 Submit copies of as-built drawings for inclusion in final TAB report.

1.02 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.3 MAINTENANCE

- .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:
 - .1 One set of packing for each pump.
 - .2 One casing joint gasket for each size pump.
 - .3 One head gasket set for each heat exchanger.
 - .4 One glass for each gauge glass.
 - .5 One filter cartridge or set of filter media for each filter or filter bank in addition to final operating set.
- .2 Provide one set of special tools required to service equipment as recommended

by manufacturers and in accordance with Section 01 78 00 - Closeout Submittals.

- .3 Furnish one commercial quality grease gun, grease and adapters to suit different types of grease and grease fittings.

2 PRODUCTS

3 EXECUTION

3.1 PAINTING REPAIRS AND RESTORATION

- .1 Prime and touch up marred finished paintwork to match original.
- .2 Restore to new condition, finishes which have been damaged.

3.02 CLEANING

- .1 Clean interior and exterior of all systems including strainers. Vacuum interior of ductwork and air handling units.

3.3 FIELD QUALITY CONTROL

- .1 Site Tests: conduct following tests in accordance with Section 01 45 00 - Quality Control and submit report as described in PART 1 - SUBMITTALS.

3.4 DEMONSTRATION

- .1 Departmental Representative will use equipment and systems for test purposes prior to acceptance. Supply labour, material, and instruments required for testing.
2. Supply tools, equipment and personnel to demonstrate and instruct operating and maintenance personnel in operating, controlling, adjusting, trouble-shooting and servicing of all systems and equipment during regular work hours, prior to acceptance.
- .2 Use operation and maintenance manual, as-built drawings, and audio visual aids as part of instruction materials.
- .5 Instruction duration time requirements as specified in appropriate sections.
- .6 Departmental Representative will record these demonstrations on video tape for future reference.

3.05 PROTECTION

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

END OF SECTION

1 GENERAL

1.1 USE OF SYSTEMS

- .1 Use of new and existing permanent ventilating systems for supplying temporary or ventilation is permitted only under following conditions:
 - .1 Entire system is complete, pressure tested, cleaned, flushed out.
 - .2 Specified water treatment system has been commissioned, water treatment is being continuously monitored.
 - .3 Building has been closed in, areas to be heated/ventilated are clean and will not thereafter be subjected to dust-producing processes.
 - .4 There is no possibility of damage.
 - .5 Supply ventilation systems are protected by 60 % filters, inspected daily, changed every 2 weeks or more frequently as required.
 - .6 Return systems have approved filters over openings, inlets, outlets.
 - .7 Systems will be:
 - .1 Operated as per manufacturer's recommendations and instructions.
 - .2 Operated by Contractor.
 - .3 Monitored continuously by Contractor.
 - .8 Warranties and guarantees are not relaxed.
 - .9 Regular preventive and other manufacturers recommended maintenance routines are performed by Contractor at own expense and under supervision of Departmental Representative.
 - .10 Refurbish entire system before static completion; clean internally and externally, restore to "as- new" condition, replace filters in air systems.
- .2 Filters specified in this Section are over and above those specified in other Sections of this project.
- .3 Exhaust systems are not included in approvals for temporary heating ventilation.

2 PRODUCTS

2.01 NOT USED

- .1 Not Used.

3 EXECUTION

3.01 NOT USED

- .1 Not Used.

END OF SECTION

1 GENERAL

1.2 REFERENCES

- .1 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.181-99, Ready-Mixed Organic Zinc-Rich Coating.
- .2 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .3 Canadian Standards Association (CSA International)
 - .1 CSA B139-04, Installation Code for Oil Burning Equipment.
- .4 Green Seal Environmental Standards (GSES)
 - .1 Standard GS-11-2008, 2nd Edition, Environmental Standard for Paints and Coatings.
- .5 National Fire Code of Canada (NFCC 2005)
- .6 South Coast Air Quality Management District (SCAQMD), California State, Regulation XI. Source Specific Standards
 - .1 SCAQMD Rule 1113-A2007, Architectural Coatings.
 - .2 SCAQMD Rule 1168-A2005, Adhesive and Sealant Applications.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:

1.04 QUALITY ASSURANCE

- .1 Sustainability Standards Certification:
 - .1 Low-Emitting Materials: provide listing of sealants coatings used in building, comply with VOC and chemical component limits or restriction requirements.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.

2016-10-19

- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.01 MATERIAL

- .1 Paint: zinc-rich to CAN/CGSB-1.181.
 - .1 Primers and Paints in accordance with manufacturer's recommendations for surface conditions.
 - .2 Primer: maximum VOC limit 250 g/L to Standard GS-11 to SCAQMD Rule 1113.
 - .3 Paints: maximum VOC limit 150 g/L to Standard GS-11 to SCAQMD Rule 1113.
- .2 Sealants:
 - .1 Sealants: maximum VOC limit to SCAQMD Rule 1168 to GSES GS-36.
- .3 Sealants: maximum VOC limit to SCAQMD Rule 1168 and to GSES GS-36.
- .4 Adhesives: maximum VOC limit to SCAQMD Rule 1168 and to GSES GS-36.
- .5 Fire Stopping: in accordance with Section 07 84 00 - Fire Stopping.

3 EXECUTION

3.01 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.02 CONNECTIONS TO EQUIPMENT

- .1 In accordance with manufacturer's instructions unless otherwise indicated.
- .2 Use valves and either unions or flanges for isolation and ease of maintenance and assembly.
- .3 Use double swing joints when equipment mounted on vibration isolation and when piping subject to movement.

3.03 CLEARANCES

- .1 Provide clearance around systems, equipment and components for observation of operation, inspection, servicing, maintenance and as recommended by manufacturer and National Fire Code of Canada and CSA B139.
- .2 Provide space for disassembly, removal of equipment and components as

recommended by manufacturer and CSA B139 as indicated without interrupting operation of other system, equipment, components.

3.04 DRAINS

- .1 Install piping with grade in direction of flow except as indicated.
- .2 Install drain valve at low points in piping systems, at equipment and at section isolating valves.
- .3 Pipe each drain valve discharge separately to above floor drain.
 - .1 Discharge to be visible.
- .4 Drain valves: NPS 3/4 gate or globe valves unless indicated otherwise, with hose end male thread, cap and chain.

3.05 AIR VENTS

- .1 Install manual air vents to CSA B139 at high points in piping systems.
- .2 Install isolating valve at each automatic air valve.
- .3 Install drain piping to approved location and terminate where discharge is visible.

3.06 DIELECTRIC COUPLINGS

- .1 General: compatible with system, to suit pressure rating of system.
- .2 Locations: where dissimilar metals are joined.
- .3 NPS 2 and under: isolating unions or bronze valves.
- .4 Over NPS 2: isolating flanges.

3.07 PIPEWORK INSTALLATION

- .1 Install pipework to CSA B139.
- .2 Screwed fittings jointed with Teflon tape.
- .3 Protect openings against entry of foreign material.
- .4 Install to isolate equipment and allow removal without interrupting operation of other equipment or systems.
- .5 Assemble piping using fittings manufactured to ANSI standards.
- .6 Saddle type branch fittings may be used on mains if branch line is no larger than half size of main.
 - .1 Hole saw (or drill) and ream main to maintain full inside diameter of branch line prior to welding saddle.
- .7 Install exposed piping, equipment, rectangular cleanouts and similar items

- parallel or perpendicular to building lines.
- .8 Install concealed pipework to minimize furring space, maximize headroom, conserve space.
 - .9 Slope piping, except where indicated, in direction of flow for positive drainage and venting.
 - .10 Install, except where indicated, to permit separate thermal insulation of each pipe.
 - .11 Group piping wherever possible and as indicated.
 - .12 Ream pipes, remove scale and other foreign material before assembly.
 - .13 Use eccentric reducers at pipe size changes to ensure positive drainage and venting.
 - .14 Provide for thermal expansion as indicated.
 - .15 Valves:
 - .1 Install in accessible locations.
 - .2 Remove interior parts before soldering.
 - .3 Install with stems above horizontal position unless indicated.
 - .4 Valves accessible for maintenance without removing adjacent piping.
 - .5 Install globe valves in bypass around control valves.
 - .6 Use ball or butterfly valves at branch take-offs for isolating purposes except where specified.
 - .7 Install butterfly valves between weld neck flanges to ensure full compression of liner.
 - .8 Use chain operators on valves NPS 2 1/2 and larger where installed more than 2400 mm above floor in Mechanical Rooms.
 - .16 Check Valves:
 - .1 Install silent check valves on discharge of pumps and in vertical pipes with downward flow and as indicated.
 - .2 Install swing check valves in horizontal lines on discharge of pumps and as indicated.

3.08 SLEEVES

- .1 General: install where pipes pass through masonry, concrete structures, fire rated assemblies, and as indicated.
- .2 Material: schedule 40 black steel pipe.
- .3 Construction: use annular fins continuously welded at mid-point at foundation walls and where sleeves extend above finished floors.
- .4 Sizes: 6 mm minimum clearance between sleeve and uninsulated pipe or between sleeve and insulation.
- .5 Installation:
 - .1 Concrete, masonry walls, concrete floors on grade: terminate flush

- with finished surface.
- .2 Other floors: terminate 25 mm above finished floor.
- .3 Before installation, paint exposed exterior surfaces with heavy application of zinc-rich paint to CAN/CGSB-1.181.
- .6 Sealing:
 - .1 Foundation walls and below grade floors: fire retardant, waterproof non-hardening mastic.
 - .2 Elsewhere:
 - .1 Provide space for firestopping.
 - .2 Maintain fire rating integrity.
 - .3 Sleeves installed for future use: fill with lime plaster or other easily removable filler.
 - .4 Ensure no contact between copper pipe or tube and sleeve.

3.09 ESCUTCHEONS

- .1 Install on pipes passing through walls, partitions, floors, and ceilings in finished areas.
- .2 Construction: one piece type with set screws.
 - .1 Chrome or nickel plated brass or type 302 stainless steel.
- .3 Sizes: outside diameter to cover opening or sleeve.
 - .1 Inside diameter to fit around pipe or outside of insulation if so provided.

3.10 PREPARATION FOR FIRE STOPPING

- .1 Install firestopping within annular space between pipes, ducts, insulation and adjacent fire separation in accordance with Section 07 84 00 - Fire Stopping.
- .2 Uninsulated unheated pipes not subject to movement: no special preparation.
- .3 Uninsulated heated pipes subject to movement: wrap with non-combustible smooth material to permit pipe movement without damaging fires topping material or installation.
- .4 Insulated pipes and ducts: ensure integrity of insulation and vapour barriers.

3.11 FLUSHING OUT OF PIPING SYSTEMS

- .1 Flush system in accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.
- .2 Before start-up, clean interior of piping systems in accordance with requirements of Section 01 74 11 - Cleaning supplemented as specified in relevant mechanical sections.
- .3 Preparatory to acceptance, clean and refurbish equipment and leave in operating condition, including replacement of filters in piping systems.

3.12 PRESSURE TESTING OF EQUIPMENT AND PIPEWORK

- .1 Advise Departmental Representative 48 hours minimum prior to performance of pressure tests.
- .2 Pipework: test as specified in relevant sections of heating, ventilating and air conditioning work.
- .3 Maintain specified test pressure without loss for 4 hours minimum unless specified for longer period of time in relevant mechanical sections.
- .4 Prior to tests, isolate equipment and other parts which are not designed to withstand test pressure or media.
- .5 Conduct tests in presence of Departmental Representative.
- .6 Pay costs for repairs or replacement, retesting, and making good. Departmental Representative to determine whether repair or replacement is appropriate.
- .7 Insulate or conceal work only after approval and certification of tests by Departmental Representative.

3.13 EXISTING SYSTEMS

- .1 Connect into existing piping systems at times approved by Departmental Representative.
- .2 Request written approval by [Departmental Representative 10 days minimum, prior to commencement of work.
- .3 Be responsible for damage to existing plant by this work.

3.14 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Electrical motors, drives and guards for mechanical equipment and systems.
 - .2 Supplier and installer responsibility indicated in Motor, Control and Equipment Schedule on electrical drawings and related mechanical responsibility is indicated on Mechanical Equipment Schedule on mechanical drawings.
 - .3 Control wiring and conduit is specified in Division 26 except for conduit, wiring and connections below 50 V which are related to control systems specified in Division 22 and 23. Refer to Division 26 for quality of materials and workmanship.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 ASHRAE 90.1-01, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA cosponsored; ANSI approved; Continuous Maintenance Standard).
- .2 Electrical Equipment Manufacturers' Association Council (EEMAC)
- .3 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Shop Drawings: submit drawings stamped.
- .3 Quality Control: in accordance with Section 01 45 00 - Quality Control.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

2016-10-19

- .4 Closeout Submittals
 - .1 Provide maintenance data for motors, drives and guards for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.4 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.05 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling.

2 PRODUCTS

2.01 GENERAL

- .1 Motors: high efficiency, in accordance with local Hydro company standards and to ASHRAE 90.1.

2.3 MOTORS 1 Provide motors for mechanical equipment as specified.

- .1 Motors under 373 W speed as indicated, continuous duty, built-in overload protection, resilient mount, single phase, 120 V, unless otherwise specified or indicated.
- .2 Motors 373 W and larger: EEMAC Class B, squirrel cage induction, speed as indicated, continuous duty, drip proof, ball bearing, maximum temperature rise 40 degrees C, 3 phase, 600 V, unless otherwise indicated.

2.03 TEMPORARY MOTORS

- .1 If delivery of specified motor will delay completion or commissioning work, install motor approved by Departmental Representative for temporary use. Work will only be accepted when specified motor is installed.

2.04 BELT DRIVES

- .1 Fit reinforced belts in sheave matched to drive. Multiple belts to be matched sets.
- .2 Use cast iron or steel sheaves secured to shafts with removable keys unless otherwise indicated.
- .3 For motors under 7.5kW: standard adjustable pitch drive sheaves, having plus

2016-10-19

or minus 10% range. Use mid-position of range for specified r/min.

- .4 For motors 7.5 kW and over: sheave with split tapered bushing and keyway having fixed pitch unless specifically required for item concerned. Provide sheave of correct size to suit balancing.
- .5 Correct size of sheave determined during commissioning.
- .6 Minimum drive rating: 1.5 times nameplate rating on motor. Keep overhung loads within manufacturer's design requirements on prime mover shafts.
- .7 Motor slide rail adjustment plates to allow for centre line adjustment.
- .8 Supply one set of spare belts for each set installed in accordance with Section 01 78 00 - Closeout Submittals.

2.05 DRIVE GUARDS

- .1 Provide guards for unprotected drives.
- .2 Guards for belt drives:
 - .1 Expanded metal screen welded to steel frame.
 - .2 Minimum 1.2 mm thick sheet metal tops and bottoms.
 - .3 38 mm dia holes on both shaft centres for insertion of tachometer.
 - .4 Removable for servicing.
- .3 Provide means to permit lubrication and use of test instruments with guards in place.
- .4 Install belt guards to allow movement of motors for adjusting belt tension.
-
- .5 Guard for flexible coupling:
 - .1 "U" shaped, minimum 1.6 mm thick galvanized mild steel.
 - .2 Securely fasten in place.
 - .3 Removable for servicing.
- .6 Unprotected fan inlets or outlets:
 - .1 Wire or expanded metal screen, galvanized, 19 mm mesh.
 - .2 Net free area of guard: not less than 80% of fan openings.
 - .3 Securely fasten in place.
 - .4 Removable for servicing.

3 EXECUTION

3.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.02 INSTALLATION

- .1 Fasten securely in place.

2016-10-19

- .2 Make removable for servicing, easily returned into, and positively in position.

3.3 FIELD QUALITY
CONTROL

- 1 Site Tests: conduct following tests [in accordance with Section 01 45 00 - Quality Control and submit report as described in PART 1 - SUBMITTALS.

.1 Manufacturer's Field Services:

- .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
- .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
- .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.04 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 GENERAL

1.1 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B40.100-2005, Pressure Gauges and Gauge Attachments.
 - .2 ASME B40.200-2008, Thermometers, Direct Reading and Remote Reading.
- .2 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
 - .2 LEED Canada 2009 for Design and Construction-2010, LEED Canada 2009 for Design and Construction Leadership in Energy and Environmental Design Green Building Rating System Reference Guide.
 - .3 LEED Canada for Existing Buildings, Operations and Maintenance-2009, LEED Canada 2009 Leadership In Energy and Environmental Design Green Building Rating System Reference Guide.
- .3 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-14.4-M88, Thermometers, Liquid-in-Glass, Self Indicating, Commercial/Industrial Type.
 - .2 CAN/CGSB-14.5-M88, Thermometers, Bimetallic, Self-Indicating, Commercial/Industrial Type.
- .4 Efficiency Valuation Organization (EVO)
 - .1 International Performance Measurement and Verification Protocol (IPMVP)
 - .1 IPMVP 2007 Version.
- .5 Green Seal Environmental Standards (GS)
 - .1 GS-11-11, Standard for Paints and Coatings.
 - .2 GS-36-11, Standard for Commercial Adhesives.

1.02 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for thermometers and pressure gauges and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped.
- .4 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.

2016-10-19

- .5 Test and Evaluation Reports:
 - .1 Submit certified test reports for thermometers and pressure gauges from approved independent testing laboratories, indicating compliance with specifications for specified performance characteristics and physical properties.

1.3 DELIVERY

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common STORAGE AND HANDLING Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store thermometers and pressure gauges off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect thermometers and pressure gauges from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

2 PRODUCTS

2.01 GENERAL

- .1 Design point to be at mid-point of scale or range.

2.02 DIRECT READING THERMOMETERS

- .1 Industrial, variable angle type, mercury-free, liquid filled, 125 mm scale length: to CAN/CGSB-14.4.
 - .1 Resistance to shock and vibration.

2.03 THERMOMETER WELLS

- .1 Copper pipe: copper or bronze.
- .2 Steel pipe: brass or stainless steel.

2.04 PRESSURE GAUGES

- .1 112 mm, dial type: to ASME B40.100, Grade 2A, stainless steel bourdon tube having 0.5% accuracy full scale unless otherwise specified.
- .2 Provide:
 - .1 Snubber for pulsating operation.
 - .2 Diaphragm assembly for corrosive service.
 - .3 Gasketed pressure relief back with solid front.
 - .4 Bronze stop cock.

3 EXECUTION

3.01 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.02 GENERAL

- .1 Install thermometers and gauges so they can be easily read from floor or platform.
 - .1 If this cannot be accomplished, install remote reading units.
- .2 Install between equipment and first fitting or valve.

3.03 THERMOMETERS

- .1 Install in wells on piping. Include heat conductive material inside well.
- .2 Install in locations as indicated and on inlet and outlet of:
 - .1 Water and cooling coils.
- .3 Install wells as indicated only for balancing purposes.
- .4 Use extensions where thermometers are installed through insulation.

3.04 PRESSURE GAUGES

- .1 Install in locations as follows:
 - .1 Suction and discharge of pumps.
 - .2 Upstream and downstream of control valves.
 - .3 Inlet and outlet of coils.
 - .4 In other locations as indicated.
- .2 Install gauge cocks for balancing purposes.
- .3 Use extensions where pressure gauges are installed through insulation.

3.05 NAMEPLATES

- .1 Install engraved lamicooid nameplates in accordance with Section 23 05 53.01 - Mechanical Identification, identifying medium.

3.06 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.

- .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management.

3.07 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by thermometer and gauge installation.

END OF SECTION

1 GENERAL

1.1 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)
 - .1 ANSI/ASME B1.20.1-1983(R2006), Pipe Threads, General Purpose (Inch).
 - .2 ANSI/ASME B16.18-2001, Cast Copper Alloy Solder Joint Pressure Fittings.
- .2 ASTM International
 - .1 ASTM A 276-08, Standard Specification for Stainless Steel Bars and Shapes.
 - .2 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .3 ASTM B 283-08a, Standard Specification for Copper and Copper Alloy Die Forgings (Hot-Pressed).
 - .4 ASTM B 505/B 505M-08a, Standard Specification for Copper-Base Alloy Continuous Castings.
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .4 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
 - .1 MSS-SP-25-1998, Standard Marking System for Valves, Fittings, Flanges and Unions.
 - .2 MSS-SP-80-2008, Bronze Gate Globe, Angle and Check Valves.
 - .3 MSS-SP-110-1996, Ball Valves, Threaded, Socket-Welding, Solder Joint, Grooved and Flared Ends.

1.02 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Shop Drawings:
 - .1 Submit drawings stamped.
 - .2 Submit data for valves specified in this Section.

1.3 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.04 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
 - .1 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size. Minimum 1.
 - .3 Stem packing: one for every 10 valves, each size. Minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.
 - .2 Tools:
 - .1 Furnish special tools for maintenance of systems and equipment.
 - .2 Include following:
 - .1 Lubricant gun for expansion joints.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.1 MATERIALS

- .1 Valves:
 - .1 Except for specialty valves, to be single manufacturer.
 - .2 Products to have CRN registration numbers.
- .2 End Connections:
 - .1 Connection into adjacent piping/tubing:
 - .1 Steel pipe systems: screwed ends to ANSI/ASME B1.20.1.
 - .2 Copper tube systems: solder ends grooved ends to ANSI/ASME B16.18.
- .3 Lockshield Keys:
 - .1 Where lockshield valves are specified, provide 10 keys of each size: malleable iron cadmium plated.
- .4 Gate Valves:
 - .1 Requirements common to gate valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Inspection and pressure testing: to MSS SP-80. Tests to be hydrostatic.

- .5 Packing: non-asbestos.
- .6 Handwheel: non-ferrous.
- .7 Handwheel Nut: bronze to ASTM B 62.
- .2 NPS 2 and under, non-rising stem, solid wedge disc, Class 125
 - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
 - .2 Operator: Handwheel.
- .3 NPS 2 and under, non-rising stem, solid wedge disc, Class 150:
 - .1 Body: with long disc guides, screwed bonnet with stem retaining nut.
 - .2 Operator: handwheel.
- .4 NPS 2 and under, rising stem, split wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Disc: split wedge, bronze to ASTM B 283, loosely secured to stem.
 - .3 Operator: handwheel.
- .5 NPS 2 and under, rising stem, solid wedge disc, Class 125:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Operator: handwheel.
- .6 NPS 2 and under, rising stem, solid wedge disc, Class 150:
 - .1 Body: with long disc guides, screwed bonnet.
 - .2 Operator: handwheel.
- .5 Globe Valves:
 - .1 Requirements common to globe valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Bonnet: union with hexagonal shoulders.
 - .3 Connections: screwed with hexagonal shoulders.
 - .4 Pressure testing: to MSS SP-80. Tests to be hydrostatic.
 - .5 Stuffing box: threaded to bonnet with gland follower, packing nut, high grade non-asbestos packing.
 - .6 Handwheel: non-ferrous.
 - .7 Handwheel Nut: bronze to ASTM B 62.
 - .2 NPS 2 and under, composition disc, Class 125:
 - .1 Body and bonnet: screwed bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc composition to suit service conditions, regrindable bronze seat, loosely secured to bronze stem to ASTM B 505.
 - .3 Operator: handwheel.
 - .3 NPS 2 and under, composition disc, Class 150:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc in easily removable disc holder, regrindable bronze seat, loosely secured to bronze stem to ASTM B 505.
 - .3 Operator: handwheel.
 - .4 NPS 2 and under, plug disc, Class 150, screwed ends:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat ring: tapered plug type with disc stem ring of AISI S420 stainless steel to ASTM A 276, loosely secured to stem.
 - .3 Operator: handwheel.
 - .5 Angle valve, NPS 2 and under, composition disc, Class 150:
 - .1 Body and bonnet: union bonnet.
 - .2 Disc and seat: renewable rotating PTFE disc in slip-on easily removable disc holder having integral guides, regrindable

- .3 bronze seat, loosely secured to stem.
Operator: handwheel.
- .6 Check Valves:
 - .1 Requirements common to check valves, unless specified otherwise:
 - .1 Standard specification: MSS SP-80.
 - .2 Connections: screwed with hexagonal shoulders.
 - .2 NPS 2 and under, swing type, bronze disc, Class 125:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
 - .3 NPS 2 and under, swing type, bronze disc:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc and seat: renewable rotating disc, two-piece hinge disc construction; seat: regrindable.
 - .4 NPS 2 and under, swing type, composition disc, Class 200:
 - .1 Body: Y-pattern with integral seat at 45 degrees, screw-in cap with hex head.
 - .2 Disc: renewable rotating disc of number 6 composition to suit service conditions, bronze two-piece hinge disc construction.
 - .5 NPS 2 and under, horizontal lift type, composition disc, Class 150:
 - .1 Body: with integral seat, union bonnet ring with hex shoulders, cap.
 - .2 Disc: renewable PTFE rotating disc in disc holder having guides top and bottom, of bronze to ASTM B 62.
 - .6 NPS 2 and under, vertical lift type, bronze disc, Class 125:
 - .1 Disc: rotating disc having guides top and bottom, disc guides, retaining rings.
- .7 Silent Check Valves:
 - .1 NPS 2 and under:
 - .1 Body: cast high tensile bronze to ASTM B 62 with integral seat.
 - .2 Pressure rating: Class 125.
 - .3 Connections: screwed ends to ANSI B1.20.1 and with hex. shoulders.
 - .4 Disc and seat: renewable rotating disc.
 - .5 Stainless steel spring, heavy duty.
 - .6 Seat: regrindable.
- .8 Ball Valves:
 - .1 NPS 2 and under:
 - .1 Body and cap: cast high tensile bronze to ASTM B 62.
 - .2 Pressure rating: Class 125 2760-kPa CWP.
 - .3 Connections: screwed ends to ANSI B1.20.1 and with hexagonal shoulders, solder ends to ANSI.
 - .4 Stem: tamperproof ball drive.
 - .5 Stem packing nut: external to body.
 - .6 Ball and seat: replaceable stainless steel solid ball and Teflon seats.
 - .7 Stem seal: TFE with external packing nut.
 - .8 Operator: removable lever handle.
- .9 Butterfly Valves:

- .1 NPS 2 1/2 through NPS 6, 2068 kPa with grooved ends.
 - .1 Body: cast bronze, with copper-tube dimensioned grooved ends.
 - .2 Disc: elastomer coated ductile iron with integrally cast stem.
 - .3 Operator: lever or handwheel. Handwheels to be used on all valves 150mm and larger.

3 EXECUTION

3.01 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.
- .2 Remove internal parts before soldering.
- .3 Install valves with unions at each piece of equipment arranged to allow servicing, maintenance, and equipment removal.

3.02 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 GENERAL

1.1 RELATED

REQUIREMENTS

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B16.1-05, Cast Iron Pipe Flanges and Flanged Fittings.

- .2 ASTM International Inc.
 - .1 ASTM A 49-01(2006), Standard Specification for Heat-Treated Carbon Steel Joint Bars.
 - .2 ASTM A 126-04, Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .3 ASTM A 536-84(2004)e1, Standard Specification for Ductile Iron Castings.
 - .4 ASTM B 61-08, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM B 85/B 85M-08, Standard Specification for Aluminum-Alloy Die Castings.
 - .7 ASTM B 209-07, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.

- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.

- .4 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
 - .1 MSS SP-61-03, Pressure Testing of Steel Valves.
 - .2 MSS SP-70-06, Grey Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS SP-71-05, Grey Iron Swing Check Valves, Flanged and Threaded Ends.
 - .4 MSS SP-82-1992, Valve Pressure Testing Methods.
 - .5 MSS SP-85-2002, Cast Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.

- .2 Product Data:
 - .1 Provide manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations.

- .3 Shop Drawings:
 - .1 Provide drawings stamped and signed by professional engineer.

1.04 CLOSEOUT SUBMITTALS

- .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials.

1.06 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
- .2 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size, minimum 1.
 - .3 Stem packing: one for every 10 valves, each size, minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.

2 PRODUCTS

2.1 MATERIAL

- .1 Valves:
 - .1 Except for specialty valves, to be of single manufacturer.
- .2 Standard specifications:
 - .1 Gate valves: MSS SP-70.
 - .2 Globe valves: MSS SP-85.
 - .3 Check valves: MSS SP-71.
- .3 Requirements common to valves, unless specified otherwise:
 - .1 Body, bonnet: cast iron to ASTM B 209 Class B or ductile iron to ASTM A 536 Grade 65-45-12.
 - .2 Connections: flanged ends grooved ends to ANSI B16.1.
 - .3 Inspection and pressure testing: to MSS SP-82.
 - .4 Bonnet gasket: non-asbestos.
 - .5 Stem: to have precision-machined Acme or 60 degrees V threads, top screwed for handwheel nut.
 - .6 Stuffing box: non-galling two-piece ball-jointed packing gland, gland bolts and nuts.
 - .7 Gland packing: non-asbestos.
 - .8 Handwheel: die-cast aluminum alloy to ASTM B 85/B 85M or malleable iron to ASTM A 49. Nut of bronze to ASTM B 62.
 - .9 Identification tag: with catalogue number, size, other pertinent data.

- .4 All products to have CRN registration numbers.

2.02 GLOBE VALVES

- .1 NPS 2 1/2 - 10, OSY:
 - .1 Body: with multiple-bolted bonnet.
 - .2 WP: 860 kPa steam, 1.4 MPa CWP.
 - .3 Bonnet-yoke gasket: non-asbestos.
 - .4 Disc: bronze to ASTM B 62, fully guided from bottom, securely yet freely connected to stem for swivel action and accurate engagement with disc.
 - .5 Seat ring: renewable, regrindable, screwed into body.
 - .6 Stem: bronze to ASTM B 62.
 - .7 Operator: handwheel manual gear:
 - .8 Section 23 05 23.01 - Valves - Bronze,

2.03 VALVE OPERATOR

- .1 Install valve operators as follows:
 - .1 Handwheel: on valves except as specified.
 - .2 Handwheel with chain operators: on valves installed more than 2400 mm above floor in boiler rooms and mechanical equipment room.

2.04 CHECK VALVES

- .1 Swing check valves, Class 125:
 - .1 Body and bolted cover: with tapped and plugged opening on each side for hinge pin. Grooved or flanged ends: plain faced with smooth finish.
 - .1 Up to NPS 16: cast iron to ASTM A 126 Class B or ductile iron ASTM A 536 Grade 65-45-12.
 - .2 NPS 18 and over: cast iron to ASTM A 126 Class C.
 - .2 Ratings:
 - .1 NPS 8 and over: bronze-faced cast iron.
 - .3 Seat rings: renewable bronze to ASTM B 62 screwed into body.
 - .4 Hinge pin, bushings: renewable bronze to ASTM B 62.

2.05 SILENT CHECK VALVES

- .1 Construction:
 - .1 Body: malleable or ductile iron with integral seat.
 - .2 Pressure rating: Class 125, WP = 860 kPa.
 - .3 Connections: grooved ends.
 - .4 Disc: bronze or stainless steel renewable rotating disc.
 - .5 Seat: renewable, EPDM.
 - .6 Stainless steel spring, heavy duty.

3 EXECUTION

3.01 INSTALLATION

- .1 Install rising stem valves in upright position with stem above horizontal.

3.02 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Clean installed products in accordance to manufacturer's recommendation.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 GENERAL

1.1 RELATED

REQUIREMENTS

1.2 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers (ASME)
 - .1 ASME B1.20.1-1983(R2006), Pipe Threads, General Purpose (Inch).
 - .2 ASME B16.1-05, Gray Iron Pipe Flanges and Flanged Fittings: Classes 25,125 and 250.
 - .3 ANSI/ASME B16.5-03, Pipe Flanges and Flanged Fittings: NPS ½ through 24.
 - .4 ANSI/ASME B16.11-05, Forged Fittings, Socket-Welding and Threaded.
 - .5 ANSI/ASME B16.25-07, Buttwelding Ends.
 - .6 ANSI/ASME B16.34-04, Valves - Flanged, Threaded and Welding Ends.
- .2 American Petroleum Institute (API)
 - .1 API Std. 609-04, Butterfly Valves: Double Flanged, Lug- and Wafer-Type.
- .3 ASTM International Inc.
 - .1 ASTM A 126-04), Standard Specification for Gray Iron Castings for Valves, Flanges, and Pipe Fittings.
 - .2 ASTM A 536-84(2004)e1, Standard Specification for Ductile Iron Castings.
 - .3 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .4 ASTM B 209M-07, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate Metric.
- .4 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .5 Manufacturers Standardization Society of the Valve and Fittings Industry, Inc. (MSS)
 - .1 MSS SP-67-02a, Butterfly Valves.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheets for valves and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit data for valves specified in this section.

- .3 Shop Drawings:
 - .1 Provide drawings stamped and signed by professional engineer.

1.04 CLOSEOUT SUBMITTALS

- .1 Submit maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

1.06 MAINTENANCE MATERIAL SUBMITTALS

- .1 Extra Materials/Spare Parts:
- .2 Furnish following spare parts:
 - .1 Valve seats: one for every 10 valves each size, minimum 1.
 - .2 Discs: one for every 10 valves, each size, minimum 1.
 - .3 Stem packing: one for every 10 valves, each size, minimum 1.
 - .4 Valve handles: 2 of each size.
 - .5 Gaskets for flanges: one for every 10 flanged joints.
- .3 Tools:
 - .1 Furnish special tools for maintenance of systems and equipment.

2 PRODUCTS

2.1 MATERIAL

2.2 BUTTERFLY

VALVES - RESILIENT

SEAT - 200 PSIG

- .1 Except to specialty valves, to be of single manufacturer.
- .2 To be suitable for dead-end service.
- .3 CRN registration number required for products.
- .4 Sizes:
 - .1 Wafer or Lug type: NPS 2 to 30.
 - .2 Grooved end type: NPS 2 to 12.
- .5 Pressure rating for tight shut-off at temperatures up to maximum for seat material.

- .1 NPS 2 - 12: 200 psig.
- .2 NPS 14 - 48: 200 psig.

- .6 Minimum seat temperature ratings to 121 degrees C.

- .7 Application: on-off operation.

- .8 Grooved ends.

- .9 Operators:
 - .1 NPS 2 - 6: handles capable of locking in any of ten (10) positions - 0 degrees to 90 degrees. Handle and release trigger - ductile iron. Return spring and hinge pin: carbon steel. Latch plate and mounting hardware: cadmium plated carbon steel. Standard coating: black laquer.
 - .2 NPS 8 - 30: manual enclosed gear operator as specified elsewhere in this section.

- .10 Designed to comply with MSS SP-67 and API 609.

- .11 Compatible with ANSI Class 125/Class 150 flanges.

- .12 Construction:
 - .1 Body ductile iron.
 - .2 Disc: aluminum bronze.
 - .3 Seat: EPDM.
 - .4 Shaft: 316 stainless steel.
 - .5 Taper pin: 316 SS.
 - .6 Key: carbon steel.
 - .7 O-Ring: Buna-N or EPDM.
 - .8 Bushings: luberized bronze.

2.03 BUTTERFLY VALVES - RESILIENT SEAT - 285 PSIG

- .1 Sizes:
 - .1 Lug type: NPS 2 to 48.
 - .2 Grooved end type: NPS 2 to 12.

- .2 Pressure rating: 285 psig at 121 degrees C.

- .3 Lug body: 150 ANSI bolt pattern.

- .4 Grooved ends.

- .5 Application: for on-off service.

- .6 Operators:
 - .1 NPS 2 - 6: handles capable of locking in any of ten (10) positions - 0 degrees to 90 degrees. Handle and release trigger - ductile iron. Return spring and hinge pin: carbon steel. Latch plate and mounting hardware: cadmium plated carbon steel.
 - .2 NPS 8 - 24: manual enclosed gear operator.
 - .3 Install parallel or perpendicular to pipeline.

- .7 Designed to comply with MSS SP-67 and API Std. 609.

- .8 Compatible with ANSI B16.1 Class 125 (iron) and ANSI B16.5 Class 150 (steel)

flanges.

- .9 Construction:
 - .1 Body: ductile iron.
 - .2 Disc: aluminum bronze.
 - .3 Seat: EPDM.
 - .4 Refer to manufacturer's literature for additional materials.
 - .5 Shaft: NPS 2 - 12: 416 stainless steel.
 - .6 Taper pin: 316 SS.
 - .7 Blowout proof stem.
 - .8 O-Ring: Buna-N or EPDM.
 - .9 Bushings: Teflon.
 - .10 Disc shall not be pinned to shaft.
 - .11 Bubble tight shutoff with downstream flanges removed, class 6 shutoff.

2.04 MOUNTING FLANGES

- .1 Class 125 cast iron to ANSI B16.1 or Class 150 steel to B16.5 pipe flanges.

3 EXECUTION

3.01 PREPARATION

- .1 Valve and mating flange preparation.
 - .1 Inspect adjacent pipeline, remove rust, scale, welding slag, other foreign material.
 - .2 Ensure that valve seats and pipe flange faces are free of dirt or surface irregularities which may disrupt flange seating and cause external leakage.
 - .3 Install butterfly valves with disc in almost closed position.
 - .4 Inspect valve disc seating surfaces and waterway and eliminate dirt or foreign material.

3.02 INSTALLATION OF VALVES

- .1 Install in accordance with manufacturer's instructions.
- .2 Do not use gaskets between pipe flanges and valves unless instructed otherwise by valve manufacturer.
- .3 Verify suitability of valve for application by inspection of identification tag.
- .4 Mount actuator on to valve prior to installation.
- .5 Handle valve with care so as to prevent damage to disc and seat faces.
- .6 Valves in horizontal pipe lines should be installed with stem in horizontal position to minimize liner and seal wear.
- .7 Ensure that valves are centered between bolts before bolts are tightened and then opened and closed to ensure unobstructed disc movement. If interference occurs due, for example to pipe wall thickness, taper bore adjacent piping to remove interference.

3.03 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
- .2 Clean installed products in accordance to manufacturer's recommendation.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 GENERAL

1.1 RELATED

REQUIREMENTS

1.2 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME B31.1-07, Power Piping.
- .2 ASTM International
 - .1 ASTM A 125-1996(2007), Standard Specification for Steel Springs, Helical, Heat-Treated.
 - .2 ASTM A 307-07b, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .3 ASTM A 563-07a, Standard Specification for Carbon and Alloy Steel Nuts.
 - .3
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
- .4 Factory Mutual (FM)
- .5 Manufacturer's Standardization Society of the Valves and Fittings Industry (MSS)
 - .1 MSS SP 58-2002, Pipe Hangers and Supports - Materials, Design and Manufacture.
 - .2 MSS SP 69-2003, Pipe Hangers and Supports - Selection and Application.
 - .3 MSS SP 89-2003, Pipe Hangers and Supports - Fabrication and Installation Practices.
- .6 Underwriter's Laboratories of Canada (ULC)

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and data sheets for hangers and supports and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer.
 - .2 Submit shop drawings for:
 - .1 Bases, hangers and supports.
 - .2 Connections to equipment and structure.
 - .3 Structural assemblies.
- .4 Certificates:
 - .1 Submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical

properties.

- .5 Manufacturers' Instructions:
 - .1 Provide manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.04 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements:
 - .1 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.01 SYSTEM DESCRIPTION

- .1 Design Requirements:
 - .1 Construct pipe hanger and support to manufacturer's recommendations utilizing manufacturer's regular production components, parts and assemblies.
 - .2 Base maximum load ratings on allowable stresses prescribed by ASME B31.1 or MSS SP 58.
 - .3 Ensure that supports, guides, anchors do not transmit excessive quantities of heat to building structure.
 - .4 Design hangers and supports to support systems under conditions of operation, allow free expansion and contraction, prevent excessive stresses from being introduced into pipework or connected equipment.
 - .5 Provide for vertical adjustments after erection and during commissioning. Amount of adjustment in accordance with MSS SP 58.
- .2 Performance Requirements:
 - .1 Design supports, platforms, catwalks, hangers to withstand seismic events.

2.02 GENERAL

- .1 Fabricate hangers, supports and sway braces in accordance with MSS SP 58. ANSI B31.1 and
- .2 Use components for intended design purpose only. Do not use for rigging or

2016-10-19

erection purposes.

2.3 PIPE HANGERS

- .1 Finishes:
 - .1 Pipe hangers and supports: galvanized after manufacture.
 - .2 Use electro-plating galvanizing process or hot dipped galvanizing process.
 - .3 Ensure steel hangers in contact with copper piping are copper plated or epoxy coated.
- .2 Upper attachment structural: suspension from lower flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: malleable iron C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip.
 - .1 Rod: 9 mm UL listed or 13 mm FM approved.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron beam clamp, eye rod, jaws and extension with carbon steel retaining clip, tie rod, nuts and washers, UL listed FM approved to MSS-SP 58 and MSS-SP 69.
- .3 Upper attachment structural: suspension from upper flange of I-Beam:
 - .1 Cold piping NPS 2 maximum: ductile iron top-of-beam C-clamp with hardened steel cup point setscrew, locknut and carbon steel retaining clip, UL listed or FM approved to MSS SP 69.
 - .2 Cold piping NPS 2 1/2 or greater, hot piping: malleable iron top-of-beam jaw-clamp with hooked rod, spring washer, plain washer and nut UL listed or FM approved.
- .4 Upper attachment to concrete:
 - .1 Ceiling: carbon steel welded eye rod, clevis plate, clevis pin and cotters with weldless forged steel eye nut. Ensure eye 6 mm minimum greater than rod diameter.
 - .2 Concrete inserts: wedge shaped body with knockout protector plate UL listed FM approved to MSS SP 69.
- .5 Hanger rods: threaded rod material to MSS SP 58:
 - .1 Ensure that hanger rods are subject to tensile loading only.
 - .2 Provide linkages where lateral or axial movement of pipework is anticipated.
 - .3 Do not use 22 mm or 28 mm rod.
- .6 Pipe attachments: material to MSS SP 58:
 - .1 Attachments for steel piping: carbon steel or galvanized.
 - .2 Attachments for copper piping: copper plated black steel.
 - .3 Use insulation shields for hot pipework.
 - .4 Oversize pipe hangers and supports.
- .7 Adjustable clevis: material to MSS SP 69 UL listed or FM approved, clevis bolt with nipple spacer and vertical adjustment nuts above and below clevis.
 - .1 Ensure "U" has hole in bottom for rivetting to insulation shields.
- .8 Yoke style pipe roll: carbon steel yoke, rod and nuts with cast iron roll, to MSS SP 69.
- .9 U-bolts: carbon steel to MSS SP 69 with 2 nuts at each end to ASTM A 563.
 - .1 Finishes for steel pipework: galvanized.
 - .2 Finishes for copper, glass, brass or aluminum pipework: black

2016-10-19

galvanized, with formed portion plastic coated epoxy coated.

- .10 Pipe rollers: cast iron roll and roll stand with carbon steel rod to MSS SP 69.

2.04 RISER CLAMPS

- .1 Steel or cast iron pipe: black carbon steel to MSS SP 58, type 42.
- .2 Copper pipe: carbon steel copper plated to MSS SP 58, type 42.
- .3 Bolts: to ASTM A 307.
- .4 Nuts: to ASTM A 563.

2.05 INSULATION PROTECTION SHIELDS

- .1 Insulated cold piping:
 - .1 64 kg/m³ density insulation plus insulation protection shield to: MSS SP 69, galvanized sheet carbon steel. Length designed for maximum 3 m span.
- .2 Insulated hot piping:
 - .1 Curved plate 300 mm long, with edges turned up, welded-in centre plate for pipe sizes NPS 12 and over, carbon steel to comply with MSS SP 69.

2.06 CONSTANT SUPPORT SPRING HANGERS

- .1 Springs: alloy steel to ASTM A 125, shot peened, magnetic particle inspected, with +/-5% spring rate tolerance, tested for free height, spring rate, loaded height and provided with Certified Mill Test Report (CMTR).
- .2 Load adjustability: 10% minimum adjustability each side of calibrated load. Adjustment without special tools. Adjustments not to affect travel capabilities.
- .3 Provide upper and lower factory set travel stops.
- .4 Provide load adjustment scale for field adjustments.
- .5 Total travel to be actual travel + 20%. Difference between total travel and actual travel 25 mm minimum.
- .6 Individually calibrated scales on each side of support calibrated prior to shipment, complete with calibration record.

2.07 VARIABLE SUPPORT SPRING HANGERS

- .1 Vertical movement: 13 mm minimum, 50 mm maximum, use single spring pre-compressed variable spring hangers.
- .2 Vertical movement greater than 50 mm: use double spring pre-compressed variable spring hanger with 2 springs in series in single casing.
- .3 Variable spring hanger complete with factory calibrated travel stops. Provide certificate of calibration for each hanger.

- .4 Steel alloy springs: to ASTM A 125, shot peened, magnetic particle inspected, with +/-5 % spring rate tolerance, tested for free height, spring rate, loaded height and provided with CMTR.

2.08 EQUIPMENT ANCHOR BOLTS AND TEMPLATES

- .1 Provide templates to ensure accurate location of anchor bolts.

2.09 HOUSE-KEEPING PADS

- .1 Provide 100 mm high concrete housekeeping pads for base-mounted equipment; size pads [50] mm larger than equipment; chamfer pad edges.

3 EXECUTION

3.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.02 INSTALLATION

- .1 Install in accordance with:
 - .1 Manufacturer's instructions and recommendations.
- .2 Vibration Control Devices:
 - .1 Install on piping systems at pumps, boilers, chillers, cooling towers, and as indicated.
- .3 Clamps on riser piping:
 - .1 Support independent of connected horizontal pipework using riser clamps and riser clamp lugs welded to riser.
 - .2 Bolt-tightening torques to industry standards.
 - .3 Steel pipes: install below coupling or shear lugs welded to pipe.
 - .4 Cast iron pipes: install below joint.
- .4 Clevis plates:
 - .1 Attach to concrete with 4 minimum concrete inserts, one at each corner.
- .5 Provide supplementary structural steelwork where structural bearings do not exist or where concrete inserts are not in correct locations.
- .6 Use approved constant support type hangers where:
 - .1 Vertical movement of pipework is 13 mm or more,
 - .2 Transfer of load to adjacent hangers or connected equipment is not permitted.
- .7 Use variable support spring hangers where:
 - .1 Transfer of load to adjacent piping or to connected equipment is not critical.
 - .2 Variation in supporting effect does not exceed 25 % of total load.

3.03 HANGER SPACING

- .1 Plumbing piping: to Canadian Plumbing Code
- .2 Copper piping: up to NPS 1/2: every 1.5 m.
- .3 Flexible joint roll groove pipe: in accordance with table below for steel, but not less than one hanger at joints. Table listings for straight runs without concentrated loads and where full linear movement is not required.

- .4 Within 300 mm of each elbow.

Maximum Pipe Size : NPS	Maximum Spacing Steel	Maximum Spacing Copper
up to 1-1/4	2.4 m	1.8 m
1-1/2	3.0 m	2.4 m
2	3.0 m	2.4 m
2-1/2	3.7 m	3.0 m
3	3.7 m	3.0 m
3-1/2	3.7 m	3.3 m
4	3.7 m	3.6 m
5	4.3 m	
6	4.3 m	
8	4.3 m	
10	4.9 m	
12	4.9 m	

3.04 HANGER INSTALLATION

- .1 Install hanger so that rod is vertical under operating conditions.
- .2 Adjust hangers to equalize load.
- .3 Support from structural members. Where structural bearing does not exist or inserts are not in suitable locations, provide supplementary structural steel members.

3.05 HORIZONTAL MOVEMENT

- .1 Angularity of rod hanger resulting from horizontal movement of pipework from cold to hot position not to exceed 4 degrees from vertical.
- .2 Where horizontal pipe movement is less than 13 mm, offset pipe hanger and support so that rod hanger is vertical in the hot position.

3.06 FINAL ADJUSTMENT

- .1 Adjust hangers and supports:
 - .1 Ensure that rod is vertical under operating conditions.
 - .2 Equalize loads.
- .2 Adjustable clevis:
 - .1 Tighten hanger load nut securely to ensure proper hanger performance.
 - .2 Tighten upper nut after adjustment.
- .3 C-clamps:

2016-10-19

- .1 Follow manufacturer's recommended written instructions and torque values when tightening C-clamps to bottom flange of beam.

- .4 Beam clamps:

- .1 Hammer jaw firmly against underside of beam.

3.7 FIELD QUALITY
CONTROL

- .1 Manufacturer's Field Services:

- .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.08 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and requirements for the identification of piping systems, duct work, valves and controllers, including the installation and location of identification systems.
 - .2 Sustainable requirements for construction and verification.
- .2 Related Requirements

1.2 REFERENCES

- .1 Canadian Gas Association (CGA)
 - .1 CSA/CGA B149.1-05, Natural Gas and Propane Installation Code.
- .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-1.60-97, Interior Alkyd Gloss Enamel.
 - .2 CAN/CGSB-24.3-92, Identification of Piping Systems.
- .3 National Fire Protection Association (NFPA)
 - .1 NFPA 13-2002, Standard for the Installation of Sprinkler Systems.
 - .2 NFPA 14-2003, Standard for the Installation of Standpipe and Hose Systems.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
- .2 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Product data to include paint colour chips, other products specified in this section.
- .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Samples to include nameplates, labels, tags, lists of proposed legends.

1.04 QUALITY ASSURANCE

- .1 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

1.05 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's

2016-10-19

written instructions.

- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Dispose of unused paint coating material at official hazardous material collections site approved by Departmental Representative.
 - .3 Do not dispose of unused paint, coating material into sewer system, into streams, lakes, onto ground or in locations where it will pose health or environmental hazard.

1.06 MANUFACTURER'S EQUIPMENT NAMEPLATES

- .1 Metal or plastic laminate nameplate mechanically fastened to each piece of equipment by manufacturer.
- .2 Lettering and numbers raised or recessed.
- .3 Information to include, as appropriate:
 - .1 Equipment: manufacturer's name, model, size, serial number, capacity.
 - .2 Motor: voltage, Hz, phase, power factor, duty, frame size.

1.7 SYSTEM NAMEPLATES

- .1 Colours:
 - .1 Hazardous: red letters, white background.
 - .2 Elsewhere: black letters, white background (except where required otherwise by applicable codes).
- .2 Construction:
 - .1 3 mm thick laminated plastic or white anodized aluminum, matte finish, with square corners, letters accurately aligned and machine engraved into core.

.3 Sizes:

- .1 Conform to following table:

Size #	mm	Sizes (mm)	No. of Lines	Height of Letters (mm)
1		10 x 50	1	3
2		13 x 75	1	5
3		13 x 75	2	3
4		20 x 100	1	8
5		20 x 100	2	5
6		20 x 200	1	8
7		25 x 125	1	12
8		25 x 125	2	8
9		35 x 200	1	20

- .2 Use maximum of 25 letters/numbers per line.

- .4 Identification for PWGSC Preventive Maintenance Support System (PMSS):
 - .1 Use arrangement of Main identifier, Source identifier, Destination identifier.

- .2 Equipment in Mechanical Room:
 - .1 Main identifier: size #9.
 - .2 Source and Destination identifiers: size #6.
 - .3 Terminal cabinets, control panels: size #5.
 - .3 Equipment elsewhere: sizes as appropriate.
- 1.8 EXISTING
IDENTIFICATION

SYSTEMS

- .1 Apply existing identification system to new work.
- .2 Where existing identification system does not cover for new work, use identification system specified this section.
- .3 Before starting work, obtain written approval of identification system from Departmental Representative.

1.09 IDENTIFICATION OF PIPING SYSTEMS

- .1 Identify contents by background colour marking, pictogram (as necessary), legend; direction of flow by arrows. To CAN/CGSB 24.3 except where specified otherwise.
- .2 Pictograms:
 - .1 Where required: Workplace Hazardous Materials Information System (WHMIS) regulations.
- .3 Legend:
 - .1 Block capitals to sizes and colours listed in CAN/CGSB 24.3.
- .4 Arrows showing direction of flow:
 - .1 Outside diameter of pipe or insulation less than 75 mm: 100 mm long x 50 mm high.
 - .2 Outside diameter of pipe or insulation 75 mm and greater: 150 mm long x 50 mm high.
 - .3 Use double-headed arrows where flow is reversible.
- .5 Extent of background colour marking:
 - .1 To full circumference of pipe or insulation.
 - .2 Length to accommodate pictogram, full length of legend and arrows.
- .6 Materials for background colour marking, legend, arrows:
 - .1 Pipes and tubing 20 mm and smaller: waterproof and heat-resistant pressure sensitive plastic marker tags.
 - .2 Other pipes: pressure sensitive plastic-coated cloth vinyl with protective overcoating, waterproof contact adhesive undercoating, suitable for ambient of 100% RH and continuous operating temperature of 150 degrees C and intermittent temperature of 200 degrees C.

- .7 Colours and Legends:
- .1 Where not listed, obtain direction from Departmental Representative.
 - .2 Colours for legends, arrows: to following table:

<u>Background colour:</u>	<u>Legend, arrows:</u>
Yellow	BLACK
Green	WHITE
Red	WHITE
 - .3 Background colour marking and legends for piping systems:

Contents	Background colour marking	Legend
Chilled water supply	Green	CH. WTR. SUPPLY
Chilled water return	Green	CH. WTR. RETURN

1.10 IDENTIFICATION DUCTWORK SYSTEMS

- .1 50 mm high stencilled letters and directional arrows 150 mm long x 50 mm high.
- .2 Colours: back, or co-ordinated with base colour to ensure strong contrast.

1.11 VALVES, CONTROLLERS

- .1 Brass tags with 12 mm stamped identification data filled with black paint.
- .2 Include flow diagrams for each system, of approved size, showing charts and schedules with identification of each tagged item, valve type, service, function, normal position, location of tagged item.

1.12 CONTROLS COMPONENTS IDENTIFICATION

- .1 Identify all systems, equipment, components, controls, sensors with system nameplates specified in this section.
- .2 Inscriptions to include function and (where appropriate) fail-safe position.

1.13 LANGUAGE

- .1 Identification in English.

3 EXECUTION

2.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

2.02 TIMING

- .1 Provide identification only after painting specified Section 09 91 23 - Interior Painting has been completed.

2.03 INSTALLATION

- .1 Perform work in accordance with CAN/CGSB-24.3 except as specified otherwise.
- .2 Provide ULC and CSA registration plates as required by respective agency.
- .3 Identify systems, equipment to conform to PWGSC PMSS.

2.04 NAMEPLATES

- .1 Locations:
 - .1 In conspicuous location to facilitate easy reading and identification from operating floor.
- .2 Standoffs:
 - .1 Provide for nameplates on hot and/or insulated surfaces.
- .3 Protection:
 - .1 Do not paint, insulate or cover.

2.05 LOCATION OF IDENTIFICATION ON PIPING AND DUCTWORK SYSTEMS

- .1 On long straight runs in open areas in boiler rooms, equipment rooms, galleries, tunnels: at not more than 17 m intervals and more frequently if required to ensure that at least one is visible from any one viewpoint in operating areas and walking aisles.
- .2 Adjacent to each change in direction.
- .3 At least once in each small room through which piping or ductwork passes.
- .4 On both sides of visual obstruction or where run is difficult to follow.
- .5 On both sides of separations such as walls, floors, partitions.
- .6 Where system is installed in pipe chases, ceiling spaces, galleries, confined spaces, at entry and exit points, and at access openings.
- .7 At beginning and end points of each run and at each piece of equipment in run.
- .8 At point immediately upstream of major manually operated or automatically controlled valves, and dampers. Where this is not possible, place identification as close as possible, preferably on upstream side.

2016-10-19

- .9 Identification easily and accurately readable from usual operating areas and from access points.
 - .1 Position of identification approximately at right angles to most convenient line of sight, considering operating positions, lighting conditions, risk of physical damage or injury and reduced visibility over time due to dust and dirt.

2.06 VALVES, CONTROLLERS

- .1 Valves and operating controllers, except at plumbing fixtures, radiation, or where in plain sight of equipment they serve: Secure tags with non-ferrous chains or closed "S" hooks.
- .2 Install one copy of flow diagrams, valve schedules mounted in frame behind non-glare glass where directed by Departmental Representative. Provide one copy (reduced in size if required) in each operating and maintenance manual.
- .3 Number valves in each system consecutively.

2.07 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 GENERAL

1.1 SUMMARY

- .1 TAB is used throughout this Section to describe the process, methods and requirements of testing, adjusting and balancing for HVAC.
- .2 TAB means to test, adjust and balance to perform in accordance with requirements of Contract Documents and to do other work as specified in this section.

1.02 QUALIFICATIONS OF TAB PERSONNEL

- .1 Submit names of personnel to perform TAB to Departmental Representative within 90 days of award of contract.
- .2 Provide documentation confirming qualifications, successful experience.
- .3 TAB: performed in accordance with the requirements of standard under which TAB Firm's qualifications are approved:
 - .1 Associated Air Balance Council, (AABC) National Standards for Total System Balance, MN-1-2002.
 - .2 National Environmental Balancing Bureau (NEBB) TABES, Procedural Standards for Testing, Adjusting, Balancing of Environmental Systems-1998.
 - .3 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA), HVAC TAB HVAC Systems - Testing, Adjusting and Balancing-2002.
- .4 Recommendations and suggested practices contained in the TAB Standard: mandatory.
- .5 Use TAB Standard provisions, including checklists, and report forms to satisfy Contract requirements.
- .6 Use TAB Standard for TAB, including qualifications for TAB Firm and Specialist and calibration of TAB instruments.
- .7 Where instrument manufacturer calibration recommendations are more stringent than those listed in TAB Standard, use manufacturer's recommendations.
- .8 TAB Standard quality assurance provisions such as performance guarantees form part of this contract.
 - .1 For systems or system components not covered in TAB Standard, use TAB procedures developed by TAB Specialist.
 - .2 Where new procedures, and requirements, are applicable to Contract requirements have been published or adopted by body responsible for TAB Standard used (AABC, NEBB, or TABB), requirements and recommendations contained in these procedures and requirements are mandatory.

1.3 PURPOSE OF TAB

- .1 Test to verify proper and safe operation, determine actual point of performance, evaluate qualitative and quantitative performance of equipment, systems and controls at design, average and low loads using actual or simulated loads
- .2 Adjust and regulate equipment and systems to meet specified performance requirements and to achieve specified interaction with other related systems under normal and emergency loads and operating conditions.
- .3 Balance systems and equipment to regulate flow rates to match load requirements over full operating ranges.

1.04 EXCEPTIONS

- .1 TAB of systems and equipment regulated by codes, standards to satisfaction of authority having jurisdiction.

1.05 CO-ORDINATION

- .1 Schedule time required for TAB (including repairs, re-testing) into project construction and completion schedule to ensure completion before acceptance of project.
- .2 Do TAB of each system independently and subsequently, where interlocked with other systems, in unison with those systems.

1.06 PRE-TAB REVIEW

- .1 Review contract documents before project construction is started and confirm in writing to Departmental Representative adequacy of provisions for TAB and other aspects of design and installation pertinent to success of TAB.
- .2 Review specified standards and report to Departmental Representative in writing proposed procedures which vary from standard.
- .3 During construction, co-ordinate location and installation of TAB devices, equipment, accessories, measurement ports and fittings.

1.07 START-UP

- .1 Follow start-up procedures as recommended by equipment manufacturer unless specified otherwise.
- .2 Follow special start-up procedures specified elsewhere in Division 23.

1.08 OPERATION OF SYSTEMS DURING TAB

- .1 Operate systems for length of time required for TAB and as required by Departmental Representative or verification of TAB reports.

1.09 START OF TAB

- .1 Notify Departmental Representative 7 days prior to start of TAB.
- .2 Start TAB when building is essentially completed, including:
 - .3 Installation of ceilings, doors, windows, other construction affecting TAB.
 - .4 Application of weatherstripping, sealing, and caulking.
 - .5 Pressure, leakage, other tests specified elsewhere Division 23.
 - .6 Provisions for TAB installed and operational.
- .7 Start-up, verification for proper, normal and safe operation of mechanical and associated electrical and control systems affecting TAB including but not limited to:
 - .1 Proper thermal overload protection in place for electrical equipment.
 - .2 Air systems:
 - .1 Filters in place, clean.
 - .2 Duct systems clean.
 - .3 Ducts, air shafts, ceiling plenums are airtight to within specified tolerances.
 - .4 Correct fan rotation.
 - .5 Fire, smoke, volume control dampers installed and open.
 - .6 Coil fins combed, clean.
 - .7 Access doors, installed, closed.
 - .8 Outlets installed, volume control dampers open.
 - .3 Liquid systems:
 - .1 Flushed, filled, vented.
 - .2 Correct pump rotation.
 - .3 Strainers in place, baskets clean.
 - .4 Isolating and balancing valves installed, open.
 - .5 Calibrated balancing valves installed, at factory settings.
 - .6 Chemical treatment systems complete, operational.

1.10 APPLICATION TOLERANCES

- .1 Do TAB to following tolerances of design values:
 - .1 HVAC systems: plus 5 %, minus 5 %.
 - .2 Hydronic systems: plus or minus 5 %.

1.11 ACCURACY TOLERANCES

- .1 Measured values accurate to within plus or minus 2 % of actual values.

1.12 INSTRUMENTS

- .1 Prior to TAB, submit to Departmental Representative list of instruments used together with serial numbers.
- .2 Calibrate in accordance with requirements of most stringent of referenced standard for either applicable system or HVAC system.

2016-10-19

- .3 Calibrate within 3 months of TAB. Provide certificate of calibration to Departmental Representative.

1.13 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit, prior to commencement of TAB:
- .2 Proposed methodology and procedures for performing TAB if different from referenced standard.

1.14 PRELIMINARY TAB REPORT

- .1 Submit for checking and approval of Departmental Representative, prior to submission of formal TAB report, sample of rough TAB sheets. Include:
 - .1 Details of instruments used.
 - .2 Details of TAB procedures employed.
 - .3 Calculations procedures.
 - .4 Summaries.

1.15 TAB REPORT

- .1 Format in accordance with referenced standard.
- .2 TAB report to show results in SI units and to include:
 - .1 Project record drawings.
 - .2 System schematics.
- .3 Submit 2 hard copies and pdf files electronic file of TAB Report to Departmental Representative for verification and approval, hard copies are to be in D-ring binders, complete with index tabs.

1.16 VERIFICATION

- .1 Reported results subject to verification by Departmental Representative.
- .2 Provide personnel and instrumentation to verify up to 30 % of reported results.
- .3 Number and location of verified results as directed by Departmental Representative.
- .4 Pay costs to repeat TAB as required to satisfaction of Departmental Representative.

1.17 SETTINGS

- .1 After TAB is completed to satisfaction of Departmental Representative, replace drive guards, close access doors, lock devices in set positions, ensure sensors are at required settings.
- .2 Permanently mark settings to allow restoration at any time during life of facility. Do not eradicate or cover markings.

1.18 COMPLETION OF TAB

- .1 TAB considered complete when final TAB Report received and approved by

Departmental Representative.

1.19 AIR SYSTEMS

- .1 Standard: TAB to most stringent of this section or TAB standards of AABC, NEBB, SMACNA, ASHRAE.
- .2 Do TAB of systems, equipment, components, controls specified Division 23.
- .3 Qualifications: personnel performing TAB qualified to standards of AABC or NEBB.
- .4 Quality assurance: perform TAB under direction of supervisor qualified to standards of AABC, or NEBB.
- .5 Measurements: to include as appropriate for systems, equipment, components, controls: air velocity, static pressure, flow rate, pressure drop (or loss), temperatures (dry bulb, wet bulb, dewpoint), duct cross-sectional area, RPM, electrical power, voltage, noise, vibration.
- .6 Locations of equipment measurements: to include as appropriate:
 - .1 Inlet and outlet of dampers, filter, coil, fan, other equipment causing changes in conditions.
 - .2 At controllers, controlled device.
- .7 Locations of systems measurements to include as appropriate: main ducts, main branch, sub-branch, run-out (or grille, register or diffuser).

1.20 OTHER TAB REQUIREMENTS

- .1 General requirements applicable to work specified this paragraph:
 - .1 Qualifications of TAB personnel: as for air systems specified this section.
 - .2 Quality assurance: as for air systems specified this section.

1.21 POST-OCCUPANCY TAB

- .1 Participate in systems checks twice during Warranty Period - #1 approximately 3 months after acceptance and #2 within 1 month of termination of Warranty Period.

2 PRODUCTS

2.01 NOT USED

- .1 Not used.

3 EXECUTION

3.01 NOT USED

- .1 Not used.

BIO MURRAY BLDG.
CHILLED WATER UPGRADE
DARTMOUTH, NS
R.082149.001

TESTING, ADJUSTING AND
BALANCING FOR HVAC

SECTION 23 05 93
PAGE 6 of 6

2016-10-19

END OF SECTION

1 GENERAL

1.01 REFERENCES

- .1 Definitions:
 - .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services and equipment in suspended ceilings and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - means "not concealed" as previously defined.
 - .3 Insulation systems - insulation material, fasteners, jackets, and other accessories.
 - .2 TIAC Codes:
 - .1 CRD: Code Round Ductwork,
 - .2 CRF: Code Rectangular Finish.
- .2 Reference Standards:
 - .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ANSI/ASHRAE/IESNA 90.1-04, SI; Energy Standard for Buildings Except Low-Rise Residential Buildings.
 - .2 ASTM International Inc.
 - .1 ASTM B 209M-07, Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate (Metric).
 - .2 ASTM C 335-05a1, Standard Test Method for Steady State Heat Transfer Properties of Pipe Insulation.
 - .3 ASTM C 411-05, Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C 449/C 449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C 547-07e1, Standard Specification for Mineral Fiber Pipe Insulation.
 - .6 ASTM C 553-02e1, Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications.
 - .7 ASTM C 612-04e1, Standard Specification for Mineral Fiber Block and Board Thermal Insulation.
 - .8 ASTM C 795-03, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .9 ASTM C 921-03a, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
 - .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .4 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations.
 - .2 Rating System Addenda for New Construction and Major Renovations LEED Canada-NC Version 1.0-Addendum 2007.
 - .3 LEED Canada-CI Version 1.0-2007, LEED (Leadership in

- Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .5 Green Seal Environmental Standards (GSES)
 - .1 Standard GS-36-00, Commercial Adhesives.
 - .6 South Coast Air Quality Management District (SCAQMD), California State
 - .1 SCAQMD Rule 1168-A2005, Adhesive and Sealant Applications.
 - .7 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (2005).
 - .8 Underwriters Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-03, Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-05, Standard for Thermal Insulation, Polystyrene, Boards and Pipe Covering.

1.02 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for duct insulation, and include product characteristics, performance criteria, physical size, finish and limitations.
 - .1 Description of equipment giving manufacturer's name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.
- .3 Shop Drawings:
 - .1 Provide drawings stamped.
- .4 Manufacturers' Instructions:
 - .1 Provide manufacture's written duct insulation jointing recommendations, and special handling criteria, installation sequence, cleaning procedures.

1.03 QUALITY ASSURANCE

- .1 Qualifications:
 - .1 Installer: specialist in performing work of this section, and have at least 3 years successful experience in this size and type of project, qualified to standards of TIAC.

1.04 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address and ULC markings.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section

01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.01 FIRE AND SMOKE RATING

- .1 To CAN/ULC-S102:
 - .1 Maximum flame spread rating: 25.
 - .2 Maximum smoke developed rating: 50.

2.2 INSULATION

- .1 Mineral fibre: as specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C 335.
- .3 TIAC Code C-1: Rigid mineral fibre board to ASTM C 612, with factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this Section).
- .4 TIAC Code C-2: Mineral fibre blanket to ASTM C 553 faced without factory applied vapour retarder jacket to CGSB 51-GP-52Ma (as scheduled in PART 3 of this section).
 - .1 Mineral fibre: to ASTM C 553.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to ASTM C 553.

2.03 JACKETS

- .1 Canvas:
 - (a) .1 220 gm/ meters square cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C 921.
- .2 Lagging adhesive: compatible with insulation.
 - .1 Maximum VOC limit 250 g/L to SCAQMD Rule 1168 GSES GS-36.

2.04 ACCESSORIES

- .1 Vapour retarder lap adhesive:
 - .1 Water based, fire retardant type, compatible with insulation.
 - .1 Maximum VOC limit 200 g/L to SCAQMD Rule 1168 GSES GS-36.
- .2 Indoor Vapour Retarder Finish:
 - .1 Vinyl emulsion type acrylic, compatible with insulation.
- .3 Insulating Cement: hydraulic setting on mineral wool, to ASTM C 449.
- .4 ULC Listed Canvas Jacket:
 - .1 220 gm/meters square cotton, plain weave, treated with dilute fire retardant lagging adhesive to ASTM C 921.
- .5 Tape: self-adhesive, aluminum, reinforced, 75 mm wide minimum.
- .6 Contact adhesive: quick-setting.

2016-10-19

- .1 Maximum VOC limit 250 g/L to SCAQMD Rule 1168 GSES GS-36.
- .7 Canvas adhesive: washable.
 - .1 Maximum VOC limit 250 g/L to SCAQMD Rule 1168 GSES GS-36.
- .8 Tie wire: 1.5 mm stainless steel.
- .9 Banding: 19 mm wide, 0.5 mm thick stainless steel.
- .10 Facing: 25 mm galvanized steel hexagonal wire mesh stitched on both faces of insulation one face of insulation with expanded metal lath on other face.
- .11 Fasteners: 4 mm diameter pins with 35 mm diameter clips, length to suit thickness of insulation.

3 EXECUTION

3.01 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.02 PRE-INSTALLATION REQUIREMENTS

- .1 Pressure test ductwork systems complete, witness and certify.
- .2 Ensure surfaces are clean, dry, free from foreign material.

3.03 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and as indicated.
- .3 Use 2 layers with staggered joints when required nominal thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Ensure hangers, and supports are outside vapour retarder jacket.
- .5 Hangers and supports in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .1 Apply high compressive strength insulation where insulation may be compressed by weight of ductwork.
- .6 Fasteners: install at 300 mm on centre in horizontal and vertical directions, minimum 2 rows each side.

3.4 DUCTWORK INSULATION SCHEDULE

- .1 Insulation types and thicknesses: conform to following table:

	TIAC Code	Vapour Retarder	Thickness (mm)
Rectangular Cold and dual temperature Supply air ducts	C-1	yes	50
Round cold and Dual temperature Supply air ducts	C-2	yes	50

- .2 Exposed round ducts 600 mm and larger, smaller sizes where subject to abuse:
 - .1 Use TIAC code C-1 insulation, scored to suit diameter of duct.
 - .1 Finishes: conform to following table:

	TIAC Code Rectangle	Round
Indoor concealed	none	none
Indoor exposed within mechanical room	CRF/2	CRD/2
Indoor exposed elsewhere	CRF/2	CRD/2

3.05 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Thermal insulation for piping and piping accessories in commercial type applications.

1.2 REFERENCES

- .1 American Society of Heating, Refrigeration and Air Conditioning Engineers (ASHRAE)
 - .1 ASHRAE Standard 90.1-01, Energy Standard for Buildings Except Low-Rise Residential Buildings (IESNA co-sponsored; ANSI approved; Continuous Maintenance Standard).
- .2 American Society for Testing and Materials International (ASTM)
 - .1 ASTM B 209M-04, Standard Specification for Aluminum and Aluminum Alloy Sheet and Plate Metric.
 - .2 ASTM C 335-04, Standard Test Method for Steady State Heat Transfer Properties of Horizontal Pipe Insulation.
 - .3 ASTM C 411-04, Standard Test Method for Hot-Surface Performance of High-Temperature Thermal Insulation.
 - .4 ASTM C 449/C 449M-00, Standard Specification for Mineral Fiber-Hydraulic-Setting Thermal Insulating and Finishing Cement.
 - .5 ASTM C 533-2004, Calcium Silicate Block and Pipe Thermal Insulation.
 - .6 ASTM C 547-2003, Mineral Fiber Pipe Insulation.
 - .7 ASTM C 795-03, Standard Specification for Thermal Insulation for Use in Contact with Austenitic Stainless Steel.
 - .8 ASTM C 921-03a, Standard Practice for Determining the Properties of Jacketing Materials for Thermal Insulation.
- .3 Canadian General Standards Board (CGSB)
 - .1 CGSB 51-GP-52Ma-89, Vapour Barrier, Jacket and Facing Material for Pipe, Duct and Equipment Thermal Insulation.
 - .2 CAN/CGSB-51.53-95, Poly (Vinyl Chloride) Jacketing Sheet, for Insulated Pipes, Vessels and Round Ducts
- .4 Department of Justice Canada (Jus)
 - .1 Canadian Environmental Assessment Act (CEAA), 1995, c. 37.
 - .2 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
 - .3 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.
- .5 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).
- .6 Manufacturer's Trade Associations
 - .1 Thermal Insulation Association of Canada (TIAC): National Insulation Standards (Revised 2004).
- .7 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S102-03, Surface Burning Characteristics of Building Materials and Assemblies.
 - .2 CAN/ULC-S701-01, Thermal Insulation, Polystyrene, Boards and Pipe Covering.

2016-10-19

- .3 CAN/ULC-S702-1997, Thermal Insulation, Mineral Fibre, for Buildings
- .4 CAN/ULC-S702.2-03, Thermal Insulation, Mineral Fibre, for Buildings, Part 2: Application Guidelines.

1.03 DEFINITIONS

- .1 For purposes of this section:
 - .1 "CONCEALED" - insulated mechanical services in suspended ceilings and non-accessible chases and furred-in spaces.
 - .2 "EXPOSED" - will mean "not concealed" as specified.
- .2 TIAC ss:
 - .1 CRF: Code Rectangular Finish.
 - .2 CPF: Code Piping Finish.

1.04 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
 - .1 Submit two copies of Workplace Hazardous Materials Information System (WHMIS) Material Safety Data Sheets (MSDS) in accordance with Section 01 33 00 - Submittal Procedures.
- .3 Shop Drawings:
 - .1 Submit shop drawings in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Shop drawings: submit drawings stamped and signed.
- .4 Samples:
 - .1 Submit samples in accordance with Section 01 33 00 - Submittal Procedures.
 - .2 Submit for approval: complete assembly of each type of insulation system, insulation, coating, and adhesive proposed. Mount sample on 12 mm plywood board. Affix label beneath sample indicating service.
- .5 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
 - .2 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.05 QUALITY ASSURANCE

- .1 Qualifications:
- .2 Installer: specialist in performing work of this Section, and have at least 3 years successful experience in this size and type of project, qualified

to standards member of TIAC.

- .3 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section [01 35 29.06 - Health and Safety Requirements].

1.06 DELIVERY, STORAGE AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
 - .2 Deliver, store and handle materials in accordance with manufacturer's written instructions.
 - .3 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .2 Storage and Protection:
 - .1 Protect from weather, construction traffic.
 - .2 Protect against damage.
 - .3 Store at temperatures and conditions required by manufacturer.
- .3 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Place excess or unused insulation and insulation accessory materials in designated containers.
 - .3 Divert unused metal materials from landfill to metal recycling facility approved by Departmental Representative.
 - .4 Dispose of unused adhesive material at official hazardous material collections site approved by Departmental Representative.

2 PRODUCTS

2.1 INSULATION

- .1 Mineral fibre specified includes glass fibre, rock wool, slag wool.
- .2 Thermal conductivity ("k" factor) not to exceed specified values at 24 degrees C mean temperature when tested in accordance with ASTM C 335.
- .3 TIAC Code A-1: rigid moulded mineral fibre without factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC-S702 or
 - .2 Maximum "k" factor: to CAN/ULC-S702.
- .4 TIAC Code A-3: rigid moulded mineral fibre with factory applied vapour retarder jacket.
 - .1 Mineral fibre: to CAN/ULC-S702 or
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Maximum "k" factor: to CAN/ULC-S702.
- .5 TIAC Code C-2: mineral fibre blanket faced with factory applied vapour retarder jacket (as scheduled in PART 3 of this section).

2016-10-19

- .1 Mineral fibre: to CAN/ULC-S702 ASTM C 547.
- .2 Jacket: to CGSB 51-GP-52Ma.
- .3 Maximum "k" factor: to CAN/ULC-S702.
- .6 TIAC Code A-6: flexible unicellular tubular elastomer.
 - .1 Insulation: with vapour retarder jacket.
 - .2 Jacket: to CGSB 51-GP-52Ma.
 - .3 Certified by manufacturer: free of potential stress corrosion cracking corrodants.

2.02 INSULATION SECUREMENT

- .1 Tape: self-adhesive, aluminum, plain, 50 mm wide minimum.
- .2 Contact adhesive: quick setting.
- .3 Canvas adhesive: washable.
- .4 Tie wire: 1.5 mm diameter stainless steel.
- .5 Bands: stainless steel, 19mm wide, 0.5 mm thick.

2.03 CEMENT

- .1 Thermal insulating and finishing cement:
 - .1 [Hydraulic setting] [or] [Air drying] on mineral wool, to ASTM C 449/C 449M.

2.04 VAPOUR RETARDER LAP ADHESIVE

- .1 Water based, fire retardant type, compatible with insulation.

2.05 INDOOR VAPOUR RETARDER FINISH

- .1 Vinyl emulsion type acrylic, compatible with insulation.

2.6 JACKETS

- .1 Polyvinyl Chloride (PVC):
 - .1 One-piece moulded type and sheet to CAN/CGSB-51.53 with pre-formed shapes as required.
 - .2 Colours: by Departmental Representative.
 - .3 Minimum service temperatures: -20 degrees C.
 - .4 Maximum service temperature: 65 degrees C.
 - .5 Moisture vapour transmission: 0.02 perm.
 - .6 Fastenings:
 - .1 Use solvent weld adhesive compatible with insulation to seal laps and joints.
 - .2 Tacks.
 - .3 Pressure sensitive vinyl tape of matching colour.
- .2 Aluminum:
 - .1 Fittings: 0.5 mm thick die-shaped fitting covers with factory-attached protective liner.

- .2 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5mm thick at 300mm spacing.
- .3 Stainless steel:
 - .1 Type: 304 or 316.
 - .2 Thickness: 0.25 mm.
 - .3 Finish: smooth.
 - .4 Joining: longitudinal and circumferential slip joints with 50 mm laps.
 - .5 Fittings: 0.5 mm thick die-shaped fitting covers with factory-attached protective liner.
 - .6 Metal jacket banding and mechanical seals: stainless steel, 19 mm wide, 0.5mm thick at 300 mm spacing.

3 EXECUTION

3.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.02 PRE-INSTALLATION REQUIREMENT

- .1 Pressure testing of piping systems and adjacent equipment to be complete, witnessed and certified.
- .2 Surfaces clean, dry, free from foreign material.

3.03 INSTALLATION

- .1 Install in accordance with TIAC National Standards.
- .2 Apply materials in accordance with manufacturers instructions and this specification.
- .3 Use two layers with staggered joints when required nominal wall thickness exceeds 75 mm.
- .4 Maintain uninterrupted continuity and integrity of vapour retarder jacket and finishes.
 - .1 Install hangers, supports outside vapour retarder jacket.
- .5 Supports, Hangers:
 - .1 Apply high compressive strength insulation, suitable for service, at oversized saddles and shoes where insulation saddles have not been provided.

3.04 REMOVABLE, PRE-FABRICATED, INSULATION AND ENCLOSURES

- .1 Application: at expansion joints, valves, primary flow measuring elements flanges and unions at equipment.

- .2 Design: to permit periodic removal and replacement without damage to adjacent insulation.
- .3 Insulation:
 - .1 Insulation, fastenings and finishes: same as system.
 - .2 Jacket: PVC.

3.05 INSTALLATION OF ELASTOMERIC INSULATION

- .1 Insulation to remain dry. Overlaps to manufacturers instructions. Ensure tight joints.
- .2 Provide vapour retarder as recommended by manufacturer.

3.6 PIPING INSULATION

SCHEDULES

- .1 Includes valves, valve bonnets, strainers, flanges and fittings unless otherwise specified.
- .2 TIAC Code: A-1.
 - .1 Securements: SS bands or Tape at 300 mm on centre.
 - .2 Seals: lap seal adhesive, lagging adhesive.
 - .3 Installation: TIAC Code 1501-H.
- .3 TIAC Code: A-3.
 - .1 Securements: SS, bands, Tape at 300 mm on centre.
 - .2 Seals: VR lap seal adhesive, VR lagging adhesive.
 - .3 Installation: TIAC Code: 1501-C.
- .4 TIAC Code: A-6.
 - .1 Seals: lap seal adhesive, lagging adhesive.
- .5 TIAC Code: C-2 with vapour retarder jacket.
 - .1 Seals: lap seal adhesive, lagging adhesive.
 - .2 Installation: TIAC Code: 1501-C.
- .6 TIAC Code: A-2.
 - .1 Seals: lap seal adhesive, lagging adhesive.
 - .2 Installation: TIAC Code: 1501-H.
- .7 Thickness of insulation as listed in following table.
 - .1 Run-outs to individual units and equipment not exceeding 4000 mm long.
 - .2 Do not insulate exposed runouts to plumbing fixtures, chrome plated piping, valves, fittings.

degree s C	code	(mm)			
Run out	to 1	1 1/4 to 2	2 1/2 to 4	5 to 6	8 & over
<u>chilled water 4-13</u>	A-3	25	25	25	25
<u>chilled water below 4</u>	A-3	25	25	38	38
<u>chilled water</u>	A-3	25	25	25	25

- .8 Finishes:
 - .3 Exposed indoors: PVC jacket.
 - .4 Exposed in mechanical rooms: PVC jacket.
 - .5 Concealed, indoors: canvas on valves, fittings. No further finish.
 - .6 Use vapour retarder jacket on TIAC code A-3 insulation compatible with insulation.
 - .7 Finish attachments: SS bands, at 150 mm on centre. Seals: wing.
 - .8 Installation: to appropriate TIAC code CRF/1 through CPF/5.

3.07 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 GENERAL

1.1 RELATED REQUIREMENTS

1.2 REFERENCES

1.03 CLEANING AND START-UP OF MECHANICAL PIPING SYSTEMS

- .1 In accordance with Section 23 08 02 - Cleaning and Start-up of Mechanical Piping Systems.

1.04 HYDRONIC SYSTEMS - PERFORMANCE VERIFICATION (PV)

- .1 Perform hydronic systems performance verification after cleaning is completed and system is in full operation.
- .2 When systems are operational, perform following tests:
 - .1 Conduct full scale tests at maximum design flow rates, temperatures and pressures for continuous consecutive period of [48] hours to demonstrate compliance with design criteria.
 - .2 Verify performance of hydronic system circulating pumps as specified, recording system pressures, temperatures, fluctuations by simulating maximum design conditions and varying.
 - .1 Pump operation.
 - .2 Pressure bypass open/closed.
 - .3 Control pressure failure.
 - .4 Maximum heating demand.

1.5 HYDRONIC SYSTEM CAPACITY TEST

- .1 Chilled water system capacity test:
 - .1 Perform capacity test when ambient temperature is within 10% of design conditions. Simulate design conditions by:
 - .1 Adding heat from building heating system or;
 - .2 Raising space temperature by turning off cooling and air systems for sufficient period of time before starting testing and pre-heating building to summer design space temperature (occupied) or above. Set OAD and RAD for minimum outside air if OAT is near outside design temperature or to maximum recirculation if RAT is greater than OAT. RAT to be at least 23 degrees C minimum.
 - .2 Test procedures:
 - .1 Open fully cooling coil control valves.
 - .2 Set thermostats on associated AHU's for maximum cooling.
 - .3 Set AHU's for design maximum air flow rates.
 - .4 Set load or demand limiters on chillers to 100%.
 - .5 After system has stabilized, record chilled water, and condenser water flow rates and supply and return temperatures simultaneously.

1.6 REPORTS

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: Reports, supplemented as specified herein.

1.06 TRAINING

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx)
Requirements: Training of O&M Personnel, supplemented as specified herein.

2 PRODUCTS

2.01 NOT USED

- .1 Not Used.

3 EXECUTION

3.01 NOT USED

- .1 Not Used.

END OF SECTION

1 GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Procedures and cleaning solutions for cleaning mechanical piping systems.

1.2 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS)
 - .1 Material Safety Data Sheets (MSDS).

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet in accordance with Section 01 33 00 - Submittal Procedures. Include product characteristics, performance criteria, and limitations.
- .2 Quality assurance submittals: submit following in accordance with Section 01 33 00 - Submittal Procedures.
 - .1 Instructions: submit manufacturer's installation instructions.
 - .1 Departmental Representative will make available 1 copy of systems supplier's installation instructions.

1.04 QUALITY ASSURANCE

- .1 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section [01 35 29.06 - Health and Safety Requirements].

1.05 DELIVERY, STORAGE, AND HANDLING

- .1 Packing, shipping, handling and unloading:
 - .1 Deliver, store and handle in accordance with manufacturer's written instructions and Section 01 61 00 - Common Product Requirements.
- .2 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

2.01 CLEANING SOLUTIONS

- .1 Tri-sodium phosphate: 0.40 kg per 100 L water in system.
- .2 Sodium carbonate: 0.40 kg per 100 L water in system.

-
- .3 Low-foaming detergent: 0.01 kg per 100 L water in system.

3 EXECUTION

3.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheet.

3.02 CLEANING HYDRONIC AND STEAM SYSTEMS

- .1 Timing: systems operational, hydrostatically tested and with safety devices functional, before cleaning is carried out.
- .2 Cleaning Agency:
 - .1 Retain qualified water treatment specialist to perform system cleaning.
- .3 Install instrumentation such as flow meters, orifice plates, pitot tubes, flow metering valves only after cleaning is certified as complete by water treatment specialist.
- .4 Cleaning procedures:
 - .1 Provide detailed report outlining proposed cleaning procedures at least 4 weeks prior to proposed starting date. Report to include:
 - .1 Cleaning procedures, flow rates, elapsed time.
 - .2 Chemicals and concentrations used.
 - .3 Inhibitors and concentrations.
 - .4 Specific requirements for completion of work.
 - .5 Special precautions for protecting piping system materials and components.
 - .6 Complete analysis of water used to ensure water will not damage systems or equipment.
- .5 Conditions at time of cleaning of systems:
 - .1 Systems: free from construction debris, dirt and other foreign material.
 - .2 Control valves: operational, fully open to ensure that terminal units can be cleaned properly.
 - .3 Strainers: clean prior to initial fill.
 - .4 Install temporary filters on pumps not equipped with permanent filters.
 - .5 Install pressure gauges on strainers to detect plugging.
- .6 Report on Completion of Cleaning:
 - .1 When cleaning is completed, submit report, complete with certificate of compliance with specifications of cleaning component supplier.

-
- .7 Hydronic Systems:
 - .1 Fill system with water, ensure air is vented from system.
 - .2 Fill expansion tanks 1/3 to 1/2 full, charge system with compressed air to at least 35 kPa (does not apply to diaphragm type expansion tanks).
 - .3 Use water metre to record volume of water in system to +/- 0.5%.
 - .4 Add chemicals under direct supervision of chemical treatment supplier.
 - .5 Closed loop systems: circulate system cleaner at 60 degrees C for at least 36 h. Drain as quickly as possible. Refill with water and inhibitors. Test concentrations and adjust to recommended levels.
 - .6 Flush velocity in system mains and branches to ensure removal of debris. System pumps may be used for circulating cleaning solution provided that velocities are adequate.
 - .7 Add chemical solution to system.
 - .8 Establish circulation, raise temperature slowly to 82 degrees C minimum. Circulate for 12 h, ensuring flow in all circuits. Remove heat, continue to circulate until temperature is below 38 degrees C. Drain as quickly as possible. Refill with clean water. Circulate for 6 h at design temperature. Drain and repeat procedures specified above. Flush through low point drains in system. Refill with clean water adding to sodium sulphite (test for residual sulphite).

3.03 START-UP OF HYDRONIC SYSTEMS

- .1 After cleaning is completed and system is filled:
 - .1 Establish circulation and expansion tank level, set pressure controls.
 - .2 Ensure air is removed.
 - .3 Check pumps to be free from air, debris, possibility of cavitation when system is at design temperature.
 - .4 Dismantle system pumps used for cleaning, inspect, replace worn parts, install new gaskets and new set of seals.
 - .5 Clean out strainers repeatedly until system is clean.
 - .6 Commission water treatment systems as specified in Section 23 25 00 - HVAC Water Treatment Systems.
 - .7 Check water level in expansion tank with cold water with circulating pumps OFF and again with pumps ON.
 - .8 Repeat with water at design temperature.
 - .9 Check pressurization to ensure proper operation and to prevent water hammer, flashing, cavitation. Eliminate water hammer and other noises.
 - .10 Bring system up to design temperature and pressure slowly over a 48 hour period.
 - .11 Perform TAB as specified in Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
 - .12 Adjust pipe supports, hangers, springs as necessary.
 - .13 Re-tighten bolts using torque wrench, to compensate for heat-caused relaxation. Repeat several times during commissioning.
 - .14 Check operation of drain valves.
 - .15 Adjust valve stem packings as systems settle down.
 - .16 Fully open balancing valves (except those that are factory-set).

-
- .17 Check operation of over-temperature protection devices on circulating pumps.
 - .18 Adjust alignment of piping at pumps to ensure flexibility, adequacy of pipe movement, absence of noise or vibration transmission.

3.04 CLEANING

- .1 Proceed in accordance with Section 01 74 11 - Cleaning.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

1 GENERAL

1.1 RELATED

REQUIREMENTS

1.2 REFERENCES

- .1 American National Standards Institute/American Water Works Association (ANSI/AWWA)
 - .1 ANSI/AWWA C111/A21.11-06, Standard for Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .2 American Society of Mechanical Engineers (ASME)
 - .1 ASME B16.1-10, Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250.
 - .2 ASME B16.3-06, Malleable Iron Threaded Fittings: Classes 150 and 300.
 - .3 ASME B16.5-09, Pipe Flanges and Flanged Fittings: NPS ½ through NPS 24 Metric/Inch Standard.
 - .4 ASME B16.9-07, Factory-Made Wrought Buttwelding Fittings.
 - .5 ASME B18.2.1-10, Square Hex, Heavy Hex and Askew Head Bolts and Hex, Heavy Hex, Hex Flange. Loded Head and Lag Screws (Inch Series).
 - .6 ASME B18.2.2-10, Nuts for General Applications: Machine Screw Nuts, Hex, Square, Hex Flange, and Coupling Nuts (Inch Series).
- .3 ASTM International
 - .1 ASTM A 47/A 47M-99(2009), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 53/A 53M-10, Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc Coated Welded and Seamless.
 - .3 ASTM A 536-84(2009), Standard Specification for Ductile Iron Castings.
 - .4 ASTM B 61-08, Standard Specification for Steam or Valve Bronze Castings.
 - .5 ASTM B 62-09, Standard Specification for Composition Bronze or Ounce Metal Castings.
 - .6 ASTM E 202-10, Standard Test Method for Analysis of Ethylene Glycols and Propylene Glycols.
- .4 CSA International
 - .1 CSA B242-05(R2011), Groove and Shoulder Type Mechanical Pipe Couplings.
 - .2 CSA W48-06, Filler Metals and Allied Materials for Metal Arc Welding.
- .5 Manufacturer's Standardization of the Valve and Fittings Industry (MSS)
 - .1 MSS-SP-67-2002a, Butterfly Valves.
 - .2 MSS-SP-70-06, Gray Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71-05, Gray Iron Swing Check Valves Flanged and Threaded Ends.
 - .4 MSS-SP-80-08, Bronze Gate, Globe, Angle and Check Valves.
 - .5 MSS-SP-85-02, Gray Iron Globe and Angle Valves, Flanged and Threaded Ends.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.

- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for hydronic systems and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Submit drawings stamped.
 - .2 Indicate on drawings:
 - .1 Components and accessories.

1.04 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for hydronic systems for incorporation into manual.
 - .1 Include special servicing requirements.

1.05 EXTRA STOCK MATERIALS

- .1 Supply spare parts as follows:
 - .1 Valve seats: 1 minimum for every ten valves, each size. Minimum one.
 - .2 Discs: 1 minimum for every ten valves, each size. Minimum one.
 - .3 Stem packing: 1 minimum for every ten valves, each size. Minimum one.
 - .4 Valve handles: 2 minimum of each size.
 - .5 Gaskets for flanges: 1 minimum for every ten flanges.

1.06 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect hydronic systems from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

2 PRODUCTS

2.01 PIPE

- .1 Steel pipe: to ASTM A 53/A 53M, Grade [B], as follows:
 - .1 To NPS 6: Schedule 40.
 - .2 NPS 8 and over, 10.

2.2 PIPE JOINTS

- .1 NPS 2 and under: screwed fittings with PTFE tape or lead-free pipe dope.
- .2 NPS 2-1/2 and over: welding fittings and flanges to CSA W48.

- .3 Roll grooved: standard rigid coupling to CSA B242.
- .4 Flanges: to ANSI/AWWA C111/ A21.11.
- .5 Orifice flanges: slip-on raised face, 2100 kPa.
- .6 Flange gaskets: to ANSI/AWWA C111/ A21.11.
- .7 Pipe thread: taper.
- .8 Bolts and nuts: to ASME B18.2.1 and ASME B18.2.2.
- .9 Roll grooved coupling gaskets: type EPDM.

2.3 FITTINGS

- .1 Screwed fittings: malleable iron, to ASME B16.3, Class 150.
- .2 Pipe flanges and flanged fittings:
 - .1 Cast iron: to ASME B16.1, Class 125.
 - .2 Steel: to ASME B16.5.
- .3 Butt-welding fittings: steel, to ASME B16.9.
- .4 Unions: malleable iron, to ASTM A 47/A 47M and ASME B16.3.
- .5 Fittings for roll grooved piping: malleable iron to ASTM A 47/A 47M.

2.4 VALVES

- .1 Connections:
 - .1 NPS 2 and smaller: screwed ends.
 - .2 NPS 2-1/2 and larger: flanged or grooved ends.
- .2 Gate valves: to MSS-SP-70 to MSS-SP-80 application: isolating equipment, control valves, pipelines:
 - .1 NPS 2 and under:
 - .1 [Mechanical Rooms: Class 125, rising stem, split wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 Elsewhere: Class 125, non- rising stem, solid wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .3 Butterfly valves: to MSS-SP-67 application: isolating cells or section of multiple component equipment (i.e. multi-section coils, multi-cell cooling towers):
 - .1 NPS 2-1/2 and over: grooved ends.
- .4 Globe valves: to MSS-SP- 80 85 application: throttling, flow control, emergency bypass:
 - .1 NPS 2 and under:
 - .1 Mechanical Rooms: withPTFE disc, as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 Elsewhere: globe, with composition disc, as specified Section 23 05 23.01 - Valves - Bronze.

- .5 Balancing, for TAB:
 - .1 Sizes: calibrated balancing valves, as specified this section.
 - .2 NPS 2 and under:
 - .1 Mechanical Rooms: globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 Elsewhere: globe, with plug disc as specified Section 23 05 23.01 - Valves - Bronze.
- .6 Drain valves: Gate, Class 125, non-rising stem, solid wedge disc, as specified Section 23 05 23.01 - Valves - Bronze.
- .7 Bypass valves on gate, globe valves NPS 8 and larger: NPS 3/4, Globe, with PTFE disc as specified Section 23 05 23.01 - Valves - Bronze.
- .8 Swing check valves: to MSS-SP-71.
 - .1 NPS 2 and under:
 - .1 Class 125, swing, with composition disc, as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 NPS 2-1/2 and over:
 - .1 Grooved ends: as specified Section 23 05 23.02 - Valves - Cast Iron.
- .9 Silent check valves:
 - .1 NPS 2 and under:
 - .1 As specified Section 23 05 23.01 - Valves - Bronze.
 - .2 NPS 2-1/2 and over:
 - .1 Grooved ends: as specified Section 23 05 23.02 - Valves - Cast Iron.
- .10 Ball valves:
 - .1 NPS 2 and under: as specified Section 23 05 23.01 - Valves - Bronze.

3 EXECUTION

3.01 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for hydronic systems installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.02 PIPING INSTALLATION

- .1 Install pipework in accordance with Section 23 05 05 - Installation of Pipe Work.

3.03 CIRCUIT BALANCING VALVES

- .1 Install flow measuring stations and flow balancing valves as indicated.
- .2 Remove handwheel after installation and when TAB is complete.
- .3 Tape joints in prefabricated insulation on valves installed in chilled water mains.

3.04 CLEANING, FLUSHING AND START-UP

- .1 In accordance with Section 23 08 02 - Cleaning and Start-Up of Mechanical Piping Systems.

3.05 TESTING

- .1 Test system in accordance with Section 21 05 01 - Common Work Results for Mechanical.

3.06 BALANCING

- .1 Balance water systems to within plus or minus 5 % of design output.
- .2 In accordance with Section 23 05 93 - Testing, Adjusting and Balancing for HVAC for applicable procedures.

3.07 PERFORMANCE VERIFICATION

- .1 In accordance with Section 23 08 01 - Performance Verification Mechanical Piping Systems.

3.08 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal 01 35 21 - LEED Requirements.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.09 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by hydronic systems installation.

END OF SECTION

1 GENERAL

1.01 RELATED REQUIREMENTS

1.02 REFERENCES

- .1 American Society of Mechanical Engineers (ASME)
 - .1 ASME-04(2007), Boiler and Pressure Vessel Code.
- .2 ASTM International Inc.
 - .1 ASTM A 47/A 47M-99(2004), Standard Specification for Ferritic Malleable Iron Castings.
 - .2 ASTM A 278/A 278M-01(2006), Standard Specification for Gray Iron Castings for Pressure-Containing Parts for Temperatures up to 650 degrees F (350 degrees C).
 - .3 ASTM A 516/A 516M-06, Standard Specification for Pressure Vessel Plates, Carbon Steel, for Moderate - and Lower - Temperature Service.
 - .4 ASTM A 536-84(2004), Standard Specification for Ductile Iron Castings.
 - .5 ASTM B 62-02, Standard Specification for Composition Bronze or Ounce Metal Castings.
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-[2004], LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum [2007]).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
- .4 Canadian Standards Association (CSA International)
 - .1 CSA B51-03(R2003), Boiler, Pressure Vessel, and Pressure Piping Code.
 - .2 CSA B51-03(R2005), Boiler, Pressure Vessel, and Pressure Piping Code, Supplement #1.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for expansion tanks, air vents, separators, valves, and strainers and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Shop Drawings:
 - .1 Provide stamped drawings.

1.04 CLOSEOUT SUBMITTALS

- .1 Submit maintenance and operation data in accordance with Section [01 78 00 - Closeout Submittals].

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section [01 61 00 - Common Product Requirements].
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse [and return] [by manufacturer] of [pallets] [crates] [padding] [and] [packaging materials] in accordance with Section [01 74 21 - Construction/Demolition Waste Management and Disposal].

2 PRODUCTS

2.01 SUSTAINABLE REQUIREMENTS

2.03 DIAPHRAGM TYPE EXPANSION TANK

2.04 AUTOMATIC AIR VENT

- .1 Standard float vent: brass body and NPS [1/8] connection and rated at 620 kPa working pressure.
- .2 Industrial float vent: cast iron body and NPS 1/2 connection and rated at 860 kPa working pressure.
- .3 Float: solid material suitable for 115 degrees C working temperature.

2.05 AIR SEPARATOR - BOILER MOUNTED

2.08 COMBINATION SEPARATORS/ STRAINERS

- .1 Steel, tested and stamped in accordance with ANSI/ASME BPVC, for [860] kPa operating pressure, with galvanized steel integral strainer with [5] mm perforations, tangential inlet and outlet connections, and internal stainless steel air collector tube.

2.09 PIPE LINE STRAINER

- .1 NPS 2 1/2 to 12: cast iron body to ASTM A 278/A 278M, Class 30 flanged or grooved connections.
- .2 Blowdown connection: NPS 1.
- .3 Screen: stainless steel brass with 1.19 mm perforations.

- .4 Working pressure: 860 kPa.

2.10 SUCTION DIFFUSER

- .1 Body: cast iron with flanged connections.
- .2 Strainer: with built-in, disposable 1.19 mm mesh, low pressure drop screen and NPS 1 blowdown connection.
- .3 Permanent magnet particle trap.
- .4 Full length straightening vanes.
- .5 Pressure gauge tappings.
- .6 Adjustable support leg.

3 EXECUTION

3.01 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.02 GENERAL

- .1 Run drain lines and blow off connections to terminate above nearest drain.
- .2 Maintain adequate clearance to permit service and maintenance.
- .3 Should deviations beyond allowable clearances arise, request and follow Departmental Representative's.
- .4 Check shop drawings for conformance of tappings for ancillaries and for equipment operating weights.

3.03 STRAINERS

- .1 Install in horizontal or down flow lines.
- .2 Ensure clearance for removal of basket.
- .3 Install ahead of each pump.

3.04 AIR VENTS

- .1 Install at high points of systems.
- .2 Install gate valve on automatic air vent inlet. Run discharge to nearest drain or service sink.

3.07 SUCTION DIFFUSERS

- .1 Install on inlet to pumps having suction size greater than 75.

3.08 PERFORMANCE VERIFICATION

- .1 Operational requirements in accordance with Section 01 47 19 - Sustainable Requirements: Operation], include:
 - .1 Repair and maintenance materials and instructions.
 - .2 [_____].

3.09 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal 01 35 21 - LEED Requirements].

END OF SECTION

1 GENERAL

1.1 RELATED REQUIREMENTS

1.2 REFERENCES

- .1 American Society of Heating Refrigeration and Air-Conditioning Engineers (ASHRAE)
 - .1 Standard 90.1-2007, Energy Standard for Buildings Except Low-Rise Residential Buildings.
- .2 Electrical Equipment Manufacturers Advisory Council (EEMAC)
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
- .4 Canadian Standards Association (CSA International)
 - .1 CSA-B214-07, Installation Code for Hydronic Heating Systems.
- .5 National Electrical Manufacturers' Association (NEMA)
 - .1 NEMA MG 1-2006, Motors and Generators.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for pump, circulator, and equipment, and include product characteristics, performance criteria, physical size, finish and limitations indicate point of operation, and final location in field assembly.
- .3 Shop Drawings:
 - .1 Provide drawings stamped.
- .4 Submit manufacturer's detailed composite wiring diagrams for control systems showing factory installed wiring and equipment on packaged equipment or required for controlling devices or ancillaries, accessories and controllers.

1.04 CLOSEOUT SUBMITTALS

- .1 Provide maintenance and operation data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.05 MAINTENANCE

- .1 Provide maintenance materials in accordance with Section 01 78 00 - Closeout Submittals.

1.06 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

2 PRODUCTS

- .1 Materials and products in accordance with Section 01 47 15 - Sustainable Requirements: Construction.

2.1 EQUIPMENT

- .1 Size and select components to: CSA-B214.

2.02 SINGLE SUCTION CENTRIFUGAL PUMP

- .1 General: bronze fitted pump complete with motor.
- .2 Base: common cast iron with drip rim and tapping for drain connection.
- .3 Volute: cast iron bronze radially split, end suction, flanged suction and discharge, with drain plug and vent cock, suction and discharge pressure gauge tapings.
- .4 Impeller: bronze enclosed type, keyed drive with locking nut or screw.
- .5 Shaft: alloy steel with two point support.
- .6 Seal assembly: mechanical seal, oil lubricated.
- .7 Coupling: flexible self-aligning.
- .8 Motor: EEMAC Class B NEMA MG 1, squirrel cage induction.
- .9 Capacity: and size as indicated on drawings.
- .10 Design pressure: 1200 kPa.

3 EXECUTION

3.01 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.02 INSTALLATION

- .1 Install hydronic pumps to: CSA-B214.
- .2 In line circulators: install as indicated by flow arrows.
 - .1 Support at inlet and outlet flanges or unions.
 - .2 Install with bearing lubrication points accessible.
- .3 Base mounted type: supply templates for anchor bolt placement.
 - .1 Include anchor bolts with sleeves. Place level, shim unit and grout.
 - .2 Align coupling in accordance with manufacturer's recommended tolerance.
 - .3 Check oil level and lubricate.
- .4 Ensure that pump body does not support piping or equipment.
 - .1 Provide stanchions or hangers for this purpose.
 - .2 Refer to manufacturer's installation instructions for details.
- .5 Pipe drain tapping to floor drain.
- .6 Install volute venting pet cock in accessible location.
- .7 Check rotation prior to start-up.
- .8 Install pressure gauge test cocks.

3.03 START-UP

- .1 General:
 - .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: General Requirements; supplemented as specified herein.
 - .2 In accordance with manufacturer's recommendations.
- .2 Procedures:
 - .1 Before starting pump, check that cooling water system over-temperature and other protective devices are installed and operative.
 - .2 After starting pump, check for proper, safe operation.
 - .3 Check installation, operation of mechanical seals, packing gland type seals. Adjust as necessary.
 - .4 Check base for free-floating, no obstructions under base.
 - .5 Run-in pumps for 12 continuous hours minimum.
 - .6 Verify operation of over-temperature and other protective devices under low- and no-flow condition.
 - .7 Eliminate air from scroll casing.
 - .8 Adjust water flow rate through water-cooled bearings.
 - .9 Adjust flow rate from pump shaft stuffing boxes to manufacturer's recommendation.
 - .10 Adjust alignment of piping and conduit to ensure true flexibility.
 - .11 Eliminate cavitation, flashing and air entrainment.
 - .12 Adjust pump shaft seals, stuffing boxes, glands.
 - .13 Measure pressure drop across strainer when clean and with flow rates as finally set.
 - .14 Replace seals if pump used to degrease system or if pump used for

- temporary heat.
- .15 Verify lubricating oil levels.

3.04 PERFORMANCE VERIFICATION (PV)

- .1 General:
 - .1 Verify performance in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: General Requirements, supplemented as specified herein.
- .2 Verify that manufacturer's performance curves are accurate.
- .3 Ensure valves on pump suction and discharge provide tight shut-off.
- .4 Net Positive Suction Head (NPSH):
 - .1 Application: measure NPSH for pumps which operate on open systems and with water at elevated temperatures.
 - .2 Measure using procedures prescribed in Section 01 91 13 - General Commissioning (Cx) Requirements.
 - .3 Where procedures do not exist, discontinue PV, report to Departmental Representative.
- .5 Multiple Pump Installations - Series and Parallel:
 - .1 Repeat PV procedures specified above for pump performance and pump BHP for combinations of pump operations.
- .6 Mark points of design and actual performance at design conditions as finally set upon completion of TAB.
- .7 Commissioning Reports: in accordance with Section 01 91 13 - General Commissioning (Cx) Requirements reports supplemented as specified herein. Reports to include:
 - .1 Record of point(s) of actual performance at maximum and minimum conditions and for single and parallel operation as finally set at completion of commissioning on pump curves.
 - .2 Use Report Forms specified in Section 01 91 13 - General Commissioning (Cx) Requirements: Report Forms and Schematics.
 - .3 Pump performance curves (family of curves).

3.05 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal 01 35 21 - LEED Requirements.

END OF SECTION

1 GENERAL

1.01 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation of low-pressure metallic ductwork, joints and accessories.

1.02 REFERENCES

- .1 American Society of Heating, Refrigerating and Air-Conditioning Engineers, Inc. (ASHRAE).
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A 480/A 480M-03c, Standard Specification for General Requirements for Flat-Rolled Stainless and Heat-Resisting Steel Plate, Sheet and Strip.
 - .2 ASTM A 635/A 635M-02, Standard Specification for Steel, Sheet and Strip, Heavy-Thickness Coils, Carbon, Hot Rolled.
 - .3 ASTM A 653/A 653M-03, Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc-Iron Alloy Coated (Galvannealed) by the Hot-Dip Process.
- .3 Department of Justice Canada (Jus).
 - .1 Canadian Environmental Protection Act (CEPA), 1999, c. 33.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .5 National Fire Protection Association (NFPA).
 - .1 NFPA 90A-02, Standard for the Installation of Air-Conditioning and Ventilating Systems.
 - .2 NFPA 90B-02, Standard for the Installation of Warm Air Heating and Air-Conditioning Systems.
 - .3 NFPA 96-01, Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations.
- .6 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA HVAC Duct Construction Standards - Metal and Flexible, 2nd Edition 1995 and Addendum No. 1, 1997.
 - .2 SMACNA HVAC Air Duct Leakage Test Manual, 1985, 1st Edition.
 - .3 IAQ Guideline for Occupied Buildings Under Construction 1995, 1st Edition.
- .7 Transport Canada (TC).
 - .1 Transportation of Dangerous Goods Act (TDGA), 1992, c. 34.

—

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS.

1.04 QUALITY ASSURANCE

- .1 Certification of Ratings:
 - .1 Catalogue or published ratings shall be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 30 - Health and Safety Requirements.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Protect on site stored or installed absorptive material from moisture damage.
- .2 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard, packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
 - .4 Separate for reuse and recycling and place in designated containers Steel, Metal, Plastic waste in accordance with Waste Management Plan.
 - .5 Place materials defined as hazardous or toxic in designated containers.
 - .6 Handle and dispose of hazardous materials in accordance with CEPA and Regional and Municipal regulations.
 - .7 Fold up metal and plastic banding, flatten and place in designated area for recycling.

2 PRODUCTS

2.01 SEAL CLASSIFICATION

- .1 Classification as follows:

<u>Maximum Pressure Pa</u>	<u>SMACNA Seal Class</u>
500	[C]
250	[C]
125	[C]
125	[Unsealed]

—
.2 Seal classification:

- .1 Class A: longitudinal seams, transverse joints, duct wall penetrations and connections made airtight with sealant and tape.
- .2 Class B: longitudinal seams, transverse joints and connections made airtight with sealant, tape, or combination thereof.
- .3 Class C: transverse joints and connections made air tight with gaskets, sealant, tape, or combination thereof. Longitudinal seams unsealed.
- .4 Unsealed seams and joints.

2.02 SEALANT

- .1 Sealant: water borne, polymer type flame resistant duct sealant. Temperature range of minus 30 degrees C to plus 93 degrees C.

2.03 TAPE

- .1 Tape: polyvinyl treated, open weave fiberglass tape, 50 mm wide.

2.04 DUCT LEAKAGE

- .1 In accordance with SMACNA HVAC Air Duct Leakage Test Manual.

2.05 FITTINGS

- .1 Fabrication: to SMACNA.
- .2 Radiused elbows.
 - .1 Rectangular: standard radius.
 - .2 Round: smooth radius. Centreline radius: 1.5 times diameter.
- .3 Transitions:
 - .1 Diverging: 20 degrees maximum included angle.
 - .2 Converging: 30 degrees maximum included angle.

2.06 GALVANIZED STEEL

- .1 Lock forming quality: to ASTM A 653/A 653M, Z90 zinc coating.
- .2 Thickness, fabrication and reinforcement: to SMACNA.
- .3 Joints: to SMACNA or proprietary manufactured duct joint. Proprietary manufactured flanged duct joint to be considered to be a class A seal.

2.07 HANGERS AND SUPPORTS

- .1 Hangers and Supports: in accordance with Section 23 05 29 - Hangers and Supports for HVAC Piping and Equipment.
 - .1 Strap hangers: of same material as duct but next sheet metal thickness heavier than duct.
 - .1 Maximum size duct supported by strap hanger: 500.
 - .2 Hanger configuration: to ASHRAE and SMACNA.
 - .3 Hangers: galvanized steel angle with galvanized steel rods to following table:

<u>Duct Size</u> (mm)	<u>Angle Size</u> (mm)	<u>Rod Size</u> (mm)
up to 750	25 x 25 x 3	6
751 to 1050	40 x 40 x 3	6
1051 to 1500	40 x 40 x 3	10
1501 to 2100	50 x 50 x 3	10
2101 to 2400	50 x 50 x 5	10
2401 and over	50 x 50 x 6	10
 - .4 Upper hanger attachments:
 - .1 For concrete: manufactured concrete inserts.
 - .2 For steel joist: manufactured joist clamp.
 - .3 For steel beams: manufactured beam clamps:

3 EXECUTION

3.01 GENERAL

- .1 Do work [in accordance with NFPA 90A, NFPA 90B, ASHRAE, SMACNA.
- .2 Do not break continuity of insulation vapour barrier with hangers or rods.
 - .1 [Insulate strap hangers 100 mm beyond insulated duct.
- .3 Support risers in accordance with SMACNA.
- .4 Install proprietary manufactured flanged duct joints in accordance with manufacturer's instructions.

3.02 HANGERS

- .1 Strap hangers: install in accordance with SMACNA.
- .2 Angle hangers: complete with locking nuts and washers.
- .3 Hanger spacing: in accordance with as follows:

<u>Duct Size</u> (mm)	<u>Spacing</u> (mm)
to 1500	3000
1501 and over	2500

—

3.03 WATERTIGHT DUCT

- .1 Provide watertight duct for:
 - .1 Minimum 1000 mm from duct mounted chilled water coiling coil in all directions.
 - .2 Form bottom of horizontal duct without longitudinal seams.
 - .1 Solder, weld joints of bottom and side sheets.
 - .2 Seal other joints with duct sealer.

3.04 SEALING AND TAPING

- .1 Apply sealant to outside of joint to manufacturer's recommendations.
- .2 Bed tape in sealant and recoat with minimum of one coat of sealant to manufacturers recommendations.

3.06 LEAKAGE TESTS

- .1 In accordance with SMACNA HVAC Duct Leakage Test Manual.
- .2 Do leakage tests in sections.
- .3 Make trial leakage tests as instructed to demonstrate workmanship.
- .4 Do not install additional ductwork until trial test has been passed.
- .5 Test section minimum of 5 m on either side of new cooling coils.
- .6 Complete test before performance insulation or concealment Work.

END OF SECTION

1 GENERAL

1.01 SUMMARY

1.02 REFERENCES

- .1 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .2 Sheet Metal and Air Conditioning Contractors' National Association (SMACNA).
 - .1 SMACNA - HVAC Duct Construction Standards - Metal and Flexible, 95.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Co-ordinate submittal requirements and provide submittals required by Section 01 47 15 - Sustainable Requirements: Construction.
- .3 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and data sheet. Indicate the following:
 - .1 Flexible connections.
 - .2 Duct access doors.
 - .3 Turning vanes.
 - .4 Instrument test ports.
- .4 Test Reports: submit certified test reports from approved independent testing laboratories indicating compliance with specifications for specified performance characteristics and physical properties.
 - .1 Certification of ratings: catalogue or published ratings to be those obtained from tests carried out by manufacturer or independent testing agency signifying adherence to codes and standards.
- .5 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .6 Instructions: submit manufacturer's installation instructions.
- .7 Manufacturer's Field Reports: manufacturer's field reports specified.
- .8 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal paper, plastic, polystyrene, corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan (WMP).
 - .4 Separate for reuse and recycling and place in designated containers Steel, Metal, Plastic, waste in accordance with Waste Management Plan (WMP).
 - .5 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.

2 PRODUCTS

2.01 MATERIALS

2.02 GENERAL

- .1 Manufacture in accordance with SMACNA - HVAC Duct Construction Standards.

2.04 ACCESS DOORS IN DUCTS

- .1 Insulated Ducts: sandwich construction of same material as duct, one sheet metal thickness heavier, minimum 0.6 mm thick complete with sheet metal angle frame and 25 mm thick rigid glass fibre insulation.
- .2 Gaskets: neoprene or foam rubber.
- .4 Hardware:
 - .1 Up to 300 x 300 mm: two sash locks complete with safety chain.
 - .2 300 to 450 mm: four sash locks complete with safety chain.
 - .3 450 to 1000 mm: piano hinge and minimum two sash locks.
 - .4 Doors over 1000 mm: piano hinge and two handles operable from both sides.
 - .5 Hold open devices.

3 EXECUTION

3.01 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.02 INSTALLATION

- .1 Access Doors and Viewing Panels:
 - .1 Size:
 - .1 As indicated.
 - .2 Locations:
 - .1 As indicated.
- .

3.03 CLEANING

- .1 Perform cleaning operations as specified in and in accordance with manufacturer's recommendations.
- .2 Upon completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION