



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Lake Louise Visitor Centre Washroom Rehabilitation, Banff National Park, Alberta		
Solicitation No.: / N° de l'invitation : 5P420-16-5297/A	Amendment No.: / N° de modification de l'invitation : 002	Date: December 19, 2016 Date : 19 décembre 2016
GETS Reference No.: / N° de référence de SEAG : PW-16-00757730		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: December 22, 2016	Time Zone: Mountain Standard Time (MST)
À : 14h00	Le : 22 décembre 2016	Fuseau horaire : Heure normale des Rocheuses (HNR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 002

This amendment is being raised to submit minutes taken from the optional site visit that occurred on December 7, 2016, make changes to the specifications and add additional documents.

1) QUESTIONS AND ANSWERS

Q1 Interior laydown area?

A1 As per "Interior Laydown area and Power Connection Location" attached.

Q2 Hours of work?

A2 24/7, 7 days a week. Hours to be coordinated with / approved by PCA before commencing work.

Q3 Water hookup for washcar?

A3 No, the washcar must be self contained and maintained by the contractor.

Q4 Location of site trailer and temporary washcar?

A4 The first three (3) bus parking stalls to the South of the main entrance are to be used for laydown, garbage, bin, site trailer and washcar.

Q5 Location of connection for power to temporary washcar and site trailer?

A5 As per "Interior Laydown area and Power Connection Location" attached. Power lines to be ran overhead when crossing the road. A generator may be used instead of connecting to building power.

Q6 Hazardous material assessment?

A6 An assessment will be completed before Jan.9. The building was constructed in the 90s and is not believed to house any hazardous materials. Bidders to assume no hazardous materials are present, if assessment proves otherwise, a CCN will be issued to the contract holder.

Q7 Owner supplied items?

A7 Soap and toilet tissue dispensers as per drawings and specs.

Q8 Will an alternate route for power distribution other than what's shown on drawing E4.0 be accepted?

A8 An alternate route will be considered.

Q9. Would Parks Canada accept barrier free portable washrooms with hand sanitizer in them?

A8. No, a washcar with flushing toilets is required for visitors.

2) SPECIFICATIONS

Add to section 02 41 00 - Demolition - 3.2.1:

.1 In addition; Remove and dispose of existing countertops and vanities, lavatories, faucets, toilets, hand driers, trash containers, w/c partitions and hardware, grab bars, bath tissue dispensers, sanitary disposals, baby change stations, mirrors, soap dispensers, exhaust fans, water fountain, lighting fixtures, wall plates and junction boxes, wall tile, floor tile.



3) ATTACHMENTS

Stall partitions to be EAD NOVO as per the attached:

Stall Partitions - EAD NOVO.pdf

Interior Laydown area and Power Connection Location.pdf

All other terms and conditions remain the same.