



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving - PWGSC / Réception des soumissions
- TPSGC**

11 Laurier St./ 11 rue, Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

Bid Fax: (819) 997-9776

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Scientific, Medical and Photographic Division /
Division de l'équipement scientifique, des produits
photographiques et pharmaceutiques

11 Laurier St./ 11 rue, Laurier

6B1, Place du Portage

Gatineau, Québec K1A 0S5

Title - Sujet Walk in Cooler & Refrigeration Syst	
Solicitation No. - N° de l'invitation 23240-170820/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 23240-170820	Date 2016-12-20
GETS Reference No. - N° de référence de SEAG PW-\$\$PV-941-71928	
File No. - N° de dossier pv941.23240-170820	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-01-03	Time Zone Fuseau horaire Eastern Standard Time EST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Martins, Christina	Buyer Id - Id de l'acheteur pv941
Telephone No. - N° de téléphone (613) 355-1973 ()	FAX No. - N° de FAX (819) 956-3814
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Amendment 002 has been raised to answer the following questions and modify Annex A:

- Q6. How many pounds of product will be entering the cooler?
- A6. <250lbs
- Q7. What is the temperature of the product entering cooler?
- A7. Room temperature (i.e. approximately 18-20 degrees Celsius)
- Q8. What is the draw down time requirement or is this just a store and hold box?
- A8. Store and hold.
- Q9. What are the load requirements?
- A9. Not important.
- Q10. Where is the condensate drain located?
- A10. Away from the cold room in the floor.
- Q11. Are there humidity requirements? If so, what are they?
- A11. There are no humidity requirements.
- Q12. In line 1.8, it states that the compressor must be moveable. Can you define that more? Does it have to be moveable in the sense that you can move it around on a cart? Or by moveable do you mean that with appropriate provisions and renovations that the compressor could be moved at a later date.
- A12. Moveable means, that the compressor is separate from the main cold room (Not attached). We can place it in a desired location away from the cold room and then connect it to cold room.
- Q13. In line 1.9 you state that it must be 30 cycle. Is that an error? Furthermore you state a 208V supply, does this also include the 120V supply? Or is this strictly 208V.
- A13. Yes, this is an error. The spec should state, "Must be able to operate with our electrical service i.e. 208 volts-3 phase"
- Q14. In line 1.11 you ask to provide a minimum of 10 electrical receptacles weatherproofed at 15 Amps. Can you advise on what the wattage load would be? And are these receptacles supposed to be on the same, or separate service breakers?
- A14. 1500 watts. The receptacles will be on one circuit.

.....

Change to the RFP:

1. Delete:

Page 13 of 18, Annex "A" Part 1- REQUIREMENT, Article 9

Solicitation No. - N° de l'invitation
23240-170820/A
Client Ref. No. - N° de réf. du client
23240-170820

Amd. No. - N° de la modif.
002
File No. - N° du dossier
pv94123240-170820

Buyer ID - Id de l'acheteur
pv941
CCC No./N° CCC - FMS No./N° VME

“Must be able to operate with our electrical service i.e. 600 volts-30 cycle-3 phase and 208 volts-30 cycle-3 phase.”

Replace with:

Page 13 of 18, Annex “A” Part 1- REQUIREMENT, Article 9

“Must be able to operate with our electrical service i.e. 208 volts-3 phase.”

ALL OTHER TERMS AND CONDITIONS IN THE RFP REMAIN UNCHANGED.