



Procurement Hub – Ottawa Office,  
Station 9W079, 9th Floor,  
200 Kent Street,  
Ottawa, Ontario K1A 0E6

December 22, 2016

**ADDENDUM NO. 3**

Subject: **ITT Invitation to Tender No. FP802-160319**  
**15.24 m (50 ft) Self-Support VHF Tower, Hill Island, Ontario**

Further to the above-mentioned Request for Proposal, this Addendum (#2) is to advise potential bidders of the question(s) received during this tender call to date. The question(s) and the response(s) are indicated in the attached **Annex A**.

All other terms and conditions remain unchanged.

**Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.**

Yours truly,

**Michel Larivière**  
Senior Contracting Officer,  
Financial & Materials Management Operations

**RECEIPT ACKNOWLEDGED**

Name of Company: \_\_\_\_\_

Signature: \_\_\_\_\_

**Canada**



## Annex A

***Bidders wishing to submit their bid by the closing date and at the closing location indicated in the Invitation To Tender Notice of solicitation number FP802-160319 or if so applicable, indicated in previous addendum(s) must also consider the following questions and answers in their bid.***

### **Question and Answer number 5, 6, 7, 8, 9 & 10**

#### **Question #5**

***Does the tower base have easy access for the installation equipment?***

**Answer #5:** Yes.

#### **Question #6**

***Is ready mixed concrete readily available?***

**Answer #6:** Yes.

#### **Question #7**

***Is power for the lighting system available at the base of the tower?***

**Answer #7:** No, power is available in the basement and cables will need to be routed through the crawlspace and basement to reach the fuse box.

#### **Question #8**

***Is a wave guide bridge required?***

**Answer #8:** No, a wave guide bridge is not required.

#### **Question #9**

***Does the lighting system require a controller/monitor?***

**Answer #9:** No, the lighting system does not require a controller/monitor .

#### **Question #10**

***Will DFO provide a surveyor report for pad location?***

**Answer #10:** No, the exact tower location will be pointed out on site by Coast Guard representative.