



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Emergency Generator Installation	
Solicitation No. - N° de l'invitation K4A22-170763/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client K4A22-170763	Date 2016-12-22
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7924	
File No. - N° de dossier PWY-6-39188 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-01-05	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: EC - Whitehorse Complex - Whitehorse, YT	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
K4A22-170763/A
Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.
001
File No. - N° du dossier
pwy-6-39188

Buyer ID - Id de l'acheteur
pwy019
CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

This Solicitation Amendment 001 is raised to incorporate Addendum #1.

Please find following Addendum #1.

All other terms and conditions remain unchanged.

**The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents**

Amend/revise the Standard Contract Documents as follows:

MODIFICATION TO THE WORK

1. Refer to Section 16 24 10 Item 2.6 Power Supply Authority Meter.
 - 1.1 Existing power authority meters located at the weather office and combined services building are to be removed. New configuration will have new supply authority meter located in the generator enclosure. Supply customer metering for three feeders originating in the generator enclosure. Standard of acceptance Schneider Power Logic EM4000 series or approved alternate complete with CT's for three feeders.
2. Refer to Section 16 24 10 Item 1.3 Maintenance Data.
 - 2.1 Provide profession quality As Built Single line Diagram mounted in minimum 11x17" break resistant glazed frame located adjacent to main CDP.
 - 2.2 Provide written instructions for customer metering operation in pocket located on main CDP.
3. Refer to Section 16 32 10 Item 1.4.5 Scope of Work.
 - 3.1 Div 26 Contractor shall acquire the services of a structural engineer, licensed to practice in the Yukon, to complete a design for the concrete generator pad suitable for the enclosure provided (in wet condition). Stamped and certified as built drawings for this work to be provided with final submissions.
 - 3.2 Div 26 Contractor is responsible for all clearing, brushing and grubbing required for trenching and installation of the generator enclosure. Intended area for clearing is to be flagged for approval by the owner's representative prior to tree cutting. All brush and trees to be removed from site.
4. Refer to Section 26 32 10 Item 1.12 Standard of Acceptance:
 - 4.1 Kohler, John Deer and Volvo are added as acceptable products.
5. Refer to Section 26 32 10 Item 2.1 Products
 - 5.1 Room temperature control by system of modulating motorized dampers. Exterior air dampers to be insulated for Arctic conditions. Spring return and/or two position (fully open or closed) dampers will not be accepted. Air design to allow for energy efficient provision for combustion air requirements.
 - 5.2 Electric Space heating requirement (item.40) to be determined by manufacturer for environmental conditions of Whitehorse Yukon.

-
- 5.3 Power generation unit to meet requirements of NFPA 110 for one step addition of 100% rated load on transfer of building loads to emergency.
 - 6. Refer to Section 26 32 10 Item 3.4 Full Load Test
 - 6.1 Remove requirement to test at 110% of full load.
 - 7. Refer to Section 26 32 23 Item 2.2 Manufacturers
 - 7.1 Add Thomson Technology as an approved manufacturer for the bypass transfer switch.
 - 8. Refer to Drawing E1:Section 26 32 10 Item 2.1 Products
 - 8.1 Supply and install generator annunciator surface mounted in Combined Services Building Main Entrance Lobby adjacent to Detail note 1-E3. Supply and Install all conduit and wiring connections back to generator enclosure.

END OF ADDENDUM 1