

**Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan**

[illegible]

**Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan**

[illegible]

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type or Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision			Zone Number	Notes or comments for customer's attention and/or action
									5	Range G
G1 Hall West	FAPT-851	2	D	135	Y	Y				
G1 Hall East	FAPT-851	2	D	134	Y	Y				
G2 Hall West	FAPT-851	2	D	123	Y	Y				
G2 Hall East	FAPT-851	2	D	122	Y	Y				
Dining West	FAPT-851	2	D	156	Y	Y				
Dining East	FAPT-851	2	D	157	Y	Y				
Range G-1 Cell 1	FMM-101A	2	M	152	Y	Y				
Range G-1 Cell 2	FMM-101A	2	M	153	Y	Y				
Range G-2 Cell 1	FMM-101A	2	M	154	Y	Y				
Range G-2 Cell 2	FMM-101A	2	M	155	Y	Y				
Range G-1 Cell 3	FMM-101A	2	M	147	Y	Y				
Range G-1 Cell 4	FMM-101A	2	M	148	Y	Y				
Range G-2 Cell 3	FMM-101A	2	M	149	Y	Y				
Range G-2 Cell 4	FMM-101A	2	M	150	Y	Y				
Range G-1 Cell 5	FMM-101A	2	M	142	Y	Y				
Range G-1 Cell 6	FMM-101A	2	M	143	Y	Y				
Range G-2 Cell 5	FMM-101A	2	M	144	Y	Y				
Range G-2 Cell 6	FMM-101A	2	M	145	Y	Y				
Range G-1 Cell 7	FMM-101A	2	M	137	Y	Y				
Range G-1 Cell 8	FMM-101A	2	M	138	Y	Y				
Range G-2 Cell 7	FMM-101A	2	M	139	Y	Y				
Range G-2 Cell 8	FMM-101A	2	M	140	Y	Y				
Range G-1 Cell 9	FMM-101A	2	M	130	Y	Y				
Range G-1 Cell 10	FMM-101A	2	M	131	Y	Y				
Range G-2 Cell 9	FMM-101A	2	M	132	Y	Y				

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							5	Range G - cont'd
Range G-2 Cell 10	FMM-101A	2	M	133	Y	Y		
Range G-1 Cell 11	FMM-101A	2	M	125	Y	Y		
Range G-1 Cell 12	FMM-101A	2	M	126	Y	Y		
Range G-2 Cell 11	FMM-101A	2	M	127	Y	Y		
Range G-2 Cell 12	FMM-101A	2	M	128	Y	Y		
							6	G-H Rec Area
Rec Area South West	FAPT-851	2	D	121	Y	Y		
Rec Area South East	FAPT-851	2	D	120	Y	Y		
Rec Area North West	FAPT-851	2	D	118	Y	Y		
Rec Area North East	FAPT-851	2	D	119	Y	Y		
							7	Range H
H-1 Hall North	FAPT-851	2	D	106	Y	Y		
H-1 Hall South	FAPT-851	2	D	107	Y	Y		
H-2 Hall North	FAPT-851	2	D	85	Y	Y		
H-2 Hall South	FAPT-851	2	D	84	Y	Y		
Dining North	FAPT-851	2	D	83	Y	Y		
Dining South	FAPT-851	2	D	82	Y	Y		
Range H-1 Cell 1	FMM-101A	2	M	114	Y	Y		
Range H-1 Cell 2	FMM-101A	2	M	115	Y	Y		
Range H-2 Cell 1	FMM-101A	2	M	116	Y	Y		
Range H-2 Cell 2	FMM-101A	2	M	117	Y	Y		

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							7	Range H
Range H-1 Cell 3	FMM-101A	2	M	109	Y	Y		
Range H-1 Cell 4	FMM-101A	2	M	110	Y	Y		
Range H-2 Cell 3	FMM-101A	2	M	111	Y	Y		
Range H-2 Cell 4	FMM-101A	2	M	112	Y	Y		
Range H-1 Cell 5	FMM-101A	2	M	102	Y	Y		
Range H-1 Cell 6	FMM-101A	2	M	103	Y	Y		
Range H-2 Cell 5	FMM-101A	2	M	104	Y	Y		
Range H-2 Cell 6	FMM-101A	2	M	105	Y	Y		
Range H-1 Cell 7	FMM-101A	2	M	97	Y	Y		
Range H-1 Cell 8	FMM-101A	2	M	98	Y	Y		
Range H-2 Cell 7	FMM-101A	2	M	99	Y	Y		
Range H-2 Cell 8	FMM-101A	2	M	100	Y	Y		
Range H-1 Cell 9	FMM-101A	2	M	92	Y	Y		
Range H-1 Cell 10	FMM-101A	2	M	93	Y	Y		
Range H-2 Cell 9	FMM-101A	2	M	94	Y	Y		
Range H-2 Cell 10	FMM-101A	2	M	95	Y	Y		
Range H-1 Cell 11	FMM-101A	2	M	87	Y	Y		
Range H-1 Cell 12	FMM-101A	2	M	88	Y	Y		
Range H-2 Cell 11	FMM-101A	2	M	89	Y	Y		
Range H-2 Cell 12	FMM-101A	2	M	90	Y	Y		

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision		Zone Number	Notes or comments for customer's attention and/or action
								10	Range I
I-1 Hall North	FAPT-851	2	D	66	Y	Y			
I-1 Hall South	FAPT-851	2	D	67	Y	Y			
I-2 Hall North	FAPT-851	2	D	78	Y	Y			
I-2 Hall South	FAPT-851	2	D	79	Y	Y			
Dining Room North	FAPT-851	2	D	80	Y	Y			
Dining Room South	FAPT-851	2	D	8	Y	Y			
Range I-1 Cell 1	FMM-101A	2	M	74	Y	Y			
Range I-1 Cell 2	FMM-101A	2	M	75	Y	Y			
Range I-2 Cell 1	FMM-101A	2	M	76	Y	Y			
Range I-2 Cell 2	FMM-101A	2	M	77	Y	Y			
Range I-1 Cell 3	FMM-101A	2	M	69	Y	Y			
Range I-1 Cell 4	FMM-101A	2	M	70	Y	Y			
Range I-2 Cell 3	FMM-101A	2	M	71	Y	Y			
Range I-2 Cell 4	FMM-101A	2	M	72	Y	Y			
Range I-1 Cell 5	FMM-101A	2	M	62	Y	Y			
Range I-1 Cell 6	FMM-101A	2	M	63	Y	Y			
Range I-2 Cell 5	FMM-101A	2	M	64	Y	Y			
Range I-2 Cell 6	FMM-101A	2	M	65	Y	Y			
Range I-1 Cell 7	FMM-101A	2	M	57	Y	Y			
Range I-1 Cell 8	FMM-101A	2	M	58	Y	Y			
Range I-2 Cell 7	FMM-101A	2	M	59	Y	Y			
Range I-2 Cell 8	FMM-101A	2	M	60	Y	Y			
Range I-1 Cell 9	FMM-101A	2	M	52	Y	Y			
Range I-1 Cell 10	FMM-101A	2	M	53	Y	Y			
Range I-2 Cell 9	FMM-101A	2	M	54	Y	Y			

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							10	Range I - cont'd
Range I-2 Cell 10	FMM-101A	2	M	55	Y	Y		
Range I-1 Cell 11	FMM-101A	2	M	47	Y	Y		
Range I-1 Cell 12	FMM-101A	2	M	48	Y	Y		
Range I-2 Cell 11	FMM-101A	2	M	49	Y	Y		
Range 1-2 Cell 12	FMM-101A	2	M	50	Y	Y		
							13	I-J Rec Area
Rec Area North East	FAPT-851	2	D	45	Y	Y		
Rec Area North West	FAPT-851	2	D	44	Y	Y		
Rec Area South East	FAPT-851	2	D	42	Y	Y		
Rec Area South West	FAPT-851	2	D	43	Y	Y		
							14	Range J
J-1 Hall East	FAPT-851	2	D	30	Y	Y		
J-2 Hall West	FAPT-851	2	D	31	Y	Y		
J-2 Hall East	FAPT-851	2	D	9	Y	Y		
J-2 Hall West	FAPT-851	2	D	8	Y	Y		
Dining Area East	FAPT-851	2	D	7	Y	Y		
Dining Area West	FAPT-851	2	D	1	Y	Y		
Range J-1 Cell 1	FMM-101A	2	M	38	Y	Y		
Range J-1 Cell 2	FMM-101A	2	M	39	Y	Y		
Range J-2 Cell 1	FMM-101A	2	M	40	Y	Y		
Range J-2 Cell 2	FMM-101A	2	M	41	Y	Y		
Range J-1 Cell 3	FMM-101A	2	M	33	Y	Y		

[illegible]

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							17	Gallery - Mech Area
S-2-190 Mech Rm Exit	MPS-950KBX	1	M	34	Y	Y		
S2 - 190 Mech Rm Exit	Keyswitch	1	M	35	Y	Y		
S Gallery North End	MPS-950KBX	1	M	48	Y	Y		
S Gallery North End	Keyswitch	1	M	49	Y	Y		
N Gallery Ctrl Room Stairs	MPS-950KBX	1	M	50	Y	Y		
N Gallery Ctrl Rm Stairs	Keyswitch	1	M	51	Y	Y		
N Gallery West Side	MPS-950KBX	1	M	77	Y	Y		
N Gallery West Side	Keyswitch	1	M	76	Y	Y		
N Gallery East Side Catwalk	MPS-950KBX	1	M	66	Y	Y		
N Gallery East Side Catwalk	Keyswitch	1	M	67	Y	Y		
N Gallery BSCS Exit	MPS-950KBX	1	M	55	Y	Y		
N Gallery BSCS Exit	Keyswitch	1	M	56	Y	Y		
South Gallery Stairs	MPS-950KBX	1	M	36	Y	Y		
South Gallery Stairs	Keyswitch	1	M	37	Y	Y		
Gallery South End	FAPT-851	1	D	47	Y	Y		0.71%
Gallery West	FAPT-851	1	D	52	Y	Y		0.71%
Gallery East	FAPT-851	1	D	57	Y	Y		0.71%
Unit Ctrl Stairtop	FAPT-851	1	D	54	Y	Y		0.71%
Mech Room S-Supply Air	Duct Detector	1	D	40	Y	Y		05%
Mech Room N-Supply Air	Duct Detector	1	D	42	Y	Y		05%
Stairtop No. 2	FAPT-851	1	D	33				0.71%
Gallery South End	FAPT-851	1	D	45				0.71%
S2-190 Mech Rm UPS	Track Superv	1	M	41				
Mech Rm by MCC	FMM-1A	1	M	103	Y	Y		Cell Exhaust Fan off - Device verified 09/09/08-KO

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							18	Communications Room
BSCS South End	FAPT-851	1	D	59	Y	Y		X-Zone activates L1M87, 0.71%
BSCS North End	FAPT-851	1	D	58	Y	Y		X-Zone activates L1M87, 0.71%
BSCS Release Solenoid	FCM-1A	1	M	87	Y	Y	ZR0	2nd Floor Mechanical - X-Zone to, 1D59, 1D58
Ctrl Room Solenoid	FCM-1A	1	M	90	Y	Y	ZR1	1D20, 1D23, 1D24
							23	Sprinklers
Mech Room S2-141	Flow Sw	1	M	28	Y	Y		
Mech Room S2-141	Flow Sw	1	M	30	Y	Y		T.D. 32 seconds
Mech Room S2-190	Flow Sw	1	M	44	Y	Y		2nd Floor T.D. 40 seconds
East Catwalk	Flow Sw	1	M	71	Y	Y		Range I-2 T.D. 38 seconds
East Catwalk	Flow Sw	1	M	72	Y	Y		Range I-1 T.D. 32 seconds
West Catwalk	Flow Sw	1	M	74	Y	Y		Range H-2 T.D. 22 seconds
West Catwalk	Flow Sw	1	M	75	Y	Y		Range H-1 T.D. 36 seconds
West Catwalk	Flow Sw	1	M	78	Y	Y		Range G-2 T.D. 32 seconds
West Catwalk	Flow Sw	1	M	79	Y	Y		Range G-1 T.D. 30 seconds
East Catwalk S2-150	Flow Sw	1	M	64	Y	Y		Range J-1 T.D. 25 seconds
East Catwalk S2-150	Flow Sw	1	M	65	Y	Y		Range J-2 T.D. 36 seconds
Mech Room	Flow Sw	1	M	94	Y	Y		
Sprinkler Room Admin	Flow Sw	1	M	95	Y	Y		Low Air Pressure to Control Room
Admin Standpipe Flow	Flow Sw	1	M	25	Y	Y		T.D. 33 seconds
Control Rm Flow	Flow Sw	1	M	91	Y	Y		Instant
BSCS Water Flow	Flow Sw	1	M	88	Y	Y		T.D. 30 seconds

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							24	Sprinkler Supervisory
S2-141	Valve	1	M	27	Y	Y		Main Ctrl Shutoff
S2-141	Valve	1	M	29	Y	Y		Admin
S2-190	Valve	1	M	43	Y	Y		2nd Floor
S2-150	Valve	1	M	62	Y	Y		Range J-2
S2-150	Valve	1	M	63	Y	Y		Range J-1
S2-150	Valve	1	M	69	Y	Y		Range I-2
S2-150	Valve	1	M	76	Y	Y		Range I-1
S2-150	Valve	1	M	80	Y	Y		Range G2
S2-150	Valve	1	M	81	Y	Y		Range G1
S2-150	Valve	1	M	84	Y	Y		Range H2
S2-150	Valve	1	M	85	Y	Y		Range H1
	Valve	1	M	86	Y	Y		BSCS Preaction Upper Shutoff
	Valve	1	M	89	Y	Y		BSCS Preaction Lower
Unit Control	Valve	1	M	93	Y	Y		Ctrl Valve
Control Room	Valve	1	M	92	Y	Y		Shutoff Valve
Firehose Monitor Range G		1	M	97	Y	Y		Ctrl from Unit control, module in BSCS Room
Firehose Monitor Range H		1	M	98	Y	Y		Ctrl from Unit control, module in BSCS Room
Firehose Monitor Range I		1	M	99	Y	Y		Ctrl from Unit control, module in BSCS Room
Firehose Monitor Range J		1	M	100	Y	Y		Ctrl from Unit control, module in BSCS Room
Firehose Monitor Admin Area		1	M	101	Y	Y		Ctrl from Unit control, module in BSCS Room
Firehose Monitor Unit Control Rm		1	M	102	Y	Y		Ctrl from Unit control, module in BSCS Room

Field Inspection Sheet

Addressable Fire Alarm Systems

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
Range G2 West	P4RA	4	M	3	Y	Y	1	Horn Cct. 1
Range G2 East	P4RA	4	M	3	Y	Y		1.372 A Metered
Range G-1 West	P4RA	4	M	3	Y	Y		APS-6R 3AMP
Range G-1 East	P4RA	4	M	3	Y	Y		
G-H Rec Area, H Wall	P4RA	4	M	3	Y	Y		
G-H Rec Area, G Wall	P4RA	4	M	3	Y	Y		
Range G Dining	P4RA	4	M	3	Y	Y		
Range H-2 North West	P4RA	4	M	3	Y	Y		
Range H-2 South East	P4RA	4	M	3	Y	Y		
Range H-1 North West	P4RA	4	M	3	Y	Y		
Range H-1 South East	P4RA	4	M	3	Y	Y		
Range H Dining	P4RA	4	M	3	Y	Y		
Range I-2 North East	P4RA	4	M	3	Y	Y		
Range 1-2 South East	P4RA	4	M	3	Y	Y		
Range I-1 North East	P4RA	4	M	3	Y	Y		
Range I-1 South West	P4RA	4	M	3	Y	Y		
I-J Rec Area I Wall	P4RA	4	M	3	Y	Y		
I-J Rec Area J Wall	P4RA	4	M	3	Y	Y		
Range J-2 East	P4RA	4	M	3	Y	Y		
Range J-2 West	P4RA	4	M	3	Y	Y		
Range J-1 East	P4RA	4	M	3	Y	Y		
Range J-1 West	P4RA	4	M	3	Y	Y		
Range J Dining Area	P4RA	4	M	3	Y	Y		

**Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan**

[illegible]

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

[illegible]

Prince Albert Penitentiary
96 Bed Maximum Living Unit
Prince Albert, Saskatchewan

[illegible]