

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							44	B - 2 Upper
North Stairtop	6249	6	M	30			45	
Switchboard Rm	CF-135	6	M	23				Offender Mgt
Records Rm W	CF-135							Offender Mgt
Records Rm E	73304							Key 6M4
Records Rm E	6249							
Records Rm E	6249							
Records Rm E	6249							
Offender Mgt Exit	73304	6	M	23				Key 6M4 - E.O.L.
NE Corner	CF-135							
Server Closet	CF-135							
Office 257	CF-135							
Ladies Washroom 258	CF-135							
Office 251	CF-135							
Janitor Closet 281	CF-135							
Office 262	CF-135							
Office 263	CF-135							
Office 264	CF-135							
Office 265	CF-135							
Office 267	CF-135							
by Exit to Dome	CF-135							
Office 270	CF-135							
Office 271	CF-135							
Office 272	CF-135							
Office 273	CF-135							
Office 274	CF-135							
Office 275	CF-135	6	M	23				

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
Intake Area							48	B-4 Intake Access
Intake Cell 1	73401 - ION	6	M	32				Key L6M6
Laundry Rm	CR-135							
Shower Rm	CR-135							
Cell 2	Smoke Detector							
Cell 3	Smoke Detector							
Cell 4	Smoke Detector							D
Cell 5	Smoke Detector							
Cell 6	Smoke Detector							O
Cell 7	Smoke Detector							
Cell 8	Smoke Detector							N
Cell 9	Smoke Detector							
Cell 10	Smoke Detector							II
Cell 11	Smoke Detector							
Cell 12	Smoke Detector							
Guard Rm		6	M	32				GA
Staff Washroom	CR-135							
Guard Rm	CR-135							
Intake Exercise Yard	CF-135	6	M	32				
Intake Exercise Yard	CF-135	6	M	32				
Intake Exercise Yard	CF-135	6	M	32				
Intake Exercise Yard	CF-135	6	M	32				
Intake Elevator Shaft	CF-135							Should be smoke
Intake Elevator Mach Rm	Fix/Restore							Access from Dome Main Fl.

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
Unit 2 Area							48	Bldg B-4
Unit 2 - W-Ent	73304	6	M	33				Key
Unit 2 - E-Ent	73304	6	M	33				Key
In Rm 1312	Smoke Detector							
In Rm 1318	Smoke Detector							
In Rm 1313	Smoke Detector							
In Rm 1316	Smoke Detector							
Rm 1314	Smoke Detector							
In Rm 1317	Smoke Detector							
Hall by Rm 1316	Smoke Detector							
Hall by Rm 1336	Smoke Detector							
Hall by Rm 1329	Smoke Detector							
In Rm 1336	Smoke Detector							
Coffee Room	CF-135							
Janitor Closet	CF-135							
In Rm 1327	Smoke Detector							
In Rm 1328	Smoke Detector							
In Rm 1329	Smoke Detector	6	M	33				Fixed
In Rm 1330	Smoke Detector							
In Rm 1331	Smoke Detector							
In Rm 1332	Smoke Detector	6	M	33				Fixed
Hall by Rm 1324	Smoke Detector							
Room 1319	Smoke Detector							
Room 1320	Smoke Detector							
Room 1321	Smoke Detector							
Room 1322	Smoke Detector							
Room 1323	Smoke Detector							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

Addressable Fire Alarm Systems		Loop Number	Module or Device	Address No.	Operation	Supervision		Zone Number	Notes or comments for customer's attention and/or action
Location of Equipment Tested	Device Type of Model Number								
								48	Bldg B-4
School Passage	All Devices	6	M	33					
Library Office	All Devices	6	M	33					Key
Library Office	CF-135								
Library Book Handout	CF-135								
Library Resource Rm	CF-200								
Library Resource Rm	CF-135								
Library Rm 355	281-A								
Library Rm 356	281-A								
Library Rm 354	281-A								
Library Washroom	CR-135								
Library Rm 358	CF-135								
Janitor Rm 360	CR-135								
Chapel Stairs	73304	6	M	32				48	Key B-4 Alarm
Chapel Stairs	CF-135								
Chapel Lobby	CF-135								
Chapel Office 422	CF-135								
Chapel Rm 423	CF-135								
Chapel Rm 420	CF-135								
Chapel Rm 421	CF-135								
Chapel Rm 419	CF-135								
Chapel Rm 416	CF-135								Access through 417
Chapel	CF-135								
Chapel Storage 426	No Device								
Chapel Storage 427	No Device								
Chapel S - Stair Exit	CF-135								Should be smoke detector

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							52	B-8 Lower
Old Weight Pit	CF-135	6	M	37				Painted
	CF-135	6	M	37				
Lower Ent. Old Gun Cage	CF-135	6	M	37				Damaged
Upper Old Gun Cage	CF-135	6	M	36			52	B-8 Upper
Old Gun Cage Storage	CF-135	6	M	36			52	
								B-8 Basement
Basmt Stairs	CF-135	6	M	38			52	Test by shorting
	73304							Key 6M7
Electrical Rm	No Device				-			
Basmt Open Area	CF-135							
Old Freezer 561	CF-135							
Old Freezer 561	CF-135							
W Corner B8	CF-135							
Old Freezer 562	CF-135							
Old Freezer 563	CF-135							
Open Area S W	CF-135							
Room 564	No Device							
Lower B8 NE	CF-135							
Lower B8 NW	CF-135							
Old Weight Pit	Bell	6	M	89/90				
Basement	Bell							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
In Gun Cage 559	CF-135						52	Bldg B-8 Upper
Stairtop N-Side Gun Cage	CF-135							
Catwalk B8 - to Gym	6249	6	M	36				
Catwalk B8 - to Gym	6249	6	M	36				
2nd FI Stairtop W.	1400-A	6	M	36				
2nd FI Vestibule	1400-A	6	M	36				
2nd FI Vestibule	MPS-950KB-X	6	M	45				Key
Supervisor Office 547	CF-135							
Supervisor Office 547	CF-135							
Assembly Rm	CF-135							
Assembly Rm	CF-135							
Office 538	CF-135							
Office 539	CF-135							
Office 540	CF-135							
Office 541	CF-135							
Inmate Washroom	CF-135							
Washroom 544	CF-135							
Office 545	No Device							Being renovated
3rd FI B-8 Upper Hall	NFM-950KB-X	6	M	36				by Door 558 Key 637
In Rm 557	CF-135							
In Rm 557	CF-135							
In Rm 556	284							
Hall by 556	Smoke							
Rm 554	CF-135							
Rm 381	CF-135							Access by 554
Rm 553	CF-135							Painted

Item Number	Model or Device	Access No.	Location	Provision	Item Number

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							56	Building B-12
Hospital Main Floor	270-GAO	6	M	39				
Hospital Air Duct	Monitor	6	M	40				
Hospital Basement	270-GAO	6	M	41				
							57	Building B-12 Evacuation
S-29 Keyswitch	270-GAO	6	M	8				
PS-30 Keyswitch	270-GAO	6	M	8				
PS-31 Keyswitch	270-GAO	6	M	8				
							58	Building B-13
A&D Sprinkler Main Flow	Water Flow	6	M	47				Does not clear of alarm
A&D Sprinkler Tamper	Tamper	6	M	47				
A&D 3rd Floor Sprinkler	Flow Switch	6	M	48				
A&D 2nd Floor Sprinkler	Flow Switch	6	M	49				
A&D 1st Floor Sprinkler	Flow Switch	6	M	50				
A&D Stair 201	Monitor	6	M	51				
A&D Stair 210	Monitor	6	M	52				
A&O Penthouse	Monitor	6	M	55				
A&O 2nd Floor	Monitor	6	M	56				
A&O 1st Floor	Monitor	6	M	57				

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
N-Side		6	M	39			56	B-12 Hospital Wing
Laundry Rm	CF-135							
Storage 644	CF-135							
Kitchen	CF-135							
Call Hallway	CF-135							
Call Hallway - Center	73304 - Pull	6	M	39				GA
N - Cells Smokes 1	73401							
N - Cells Smokes 2	73401							Very dirty replace
- Cells Smokes 3	73401							
S - Cell Smokes 1	73401							
S - Cell Smokes 2	73401							
S - Cell Smokes 3	73401							
Center of Hall	CR-135							
Hall by Guards	Smoke Det							
Cleaning Storage	CF-135							
Nursing Office 660	CF-135							
Drug Storage	CF-135							
Guard Rm	284-A							
Treatment Rm 661	CF-135							
X-ray Rm	CF-135							
Developing Rm	CF-135							
Chief of Health Care	CF-135							
Chief of Health Care	CF-135							
Health Care Clerk	CF-135							
Guard Office	Tamper Cord	6	M	23				
by Guard Office	Flow	6	M	23				T.D. 35 seconds

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
		6	M	39			56	B-12 Hospital Wing
Office Hallway	Smoke Det.							
Doctor's Office 665	284							Tested by shorting
Record Storage 664	CF-135							Tested by shorting
Staff Coffee Rm	CF-135							Tested by shorting
Isolation Cell Mech Rm	CHD-F200							Access outside
Crawlspace								
Crawlspace Entrance	73304	6	M	39				Key L6M8
Row 1 Dev 1	CF-135	6	M	41				Tested by shorting
Row 1 Dev 2	CF-135							Dated 1980
Row 1 Dev 3	CF-135							Dated 1980
Row 1 Dev 4	CF-135							Dated 1980
Row 2 Dev 1	CF-135							Dated 1980
Row 2 Dev 2	CF-135							Dated 1980
Row 2 Dev 3	CF-135							Dated 1980
Row 2 Dev 4	CF-135							Dated 1980
Row 3 Dev 1	CF-135							Dated 1980
Row 3 Dev 2	CF-135							Dated 1980
Row 3 Dev 3	CF-135							Dated 1980
Row 3 Dev 4	CF-135							Dated 1980
Return Air Duct	Statatrol 500L7	6	M	40				

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							58	B-13 A&D Lower
by Gate 205	73304	6	M	57			59	Key 6M18
by Gate 205	73471 Smoke							
by Holding Rm 679	73471							
Hallway to Hospital	73471							
Hallway to Hospital	MPS-950KB	6	M	57				Key 6M18
Hallway to Hospital	73471	6	M	57				
mate Personal Effects	MPS-950KB	6	M	57				Key 6M18
								B-13 Upper
Hall by 690	Smoke	6	M	56				
Exit 690	73304							Key 6M18
Exit 700	73304							E.O.L. Key 6M18
by Exit 700	Smoke							E.O.L.
East Stairtop	Smoke	6	M	52				E.O.L. in Hall
SW Stairtop	Smoke	6	M	51				
								B-13 Penthouse
Penthouse Exit	73304	6	M	55				Key 6M18 E.O.L.

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							63	Bldg C-2 Paint Shop Lower
Maint. Paint W	CF-135	10	M	56				
Maint. Paint E	CF-135							
Solvent Rm	CF-135							
Spray Rm	?							Painted
S E Cage	CF-135							
Washroom	?							Painted
Paint Storage	CF-135							
Mezzanine Office	73304							
Mezzanine Office	CF-135							
								Bldg C-2 Lower Wood Shop
Tool Room	CF-135	10	M	56			63	
Storage Rm	CF-135							
Woodworking Area	CF-135							
Woodworking Area								
Woodworking Area								
Woodworking Area								
Woodworking Area								
Woodworking Area								
Office	CF-135							
Office	CF-135							
Office	73304							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							63	C-2 Upper Taylor Shop
Taylor Shop Office	73304	10	M	55				
Taylor Shop Office	Key	6	M	10				
Serving Area N-1	CF-135	10	M	55				E.O.L. on Wall
Serving Area N-2	CF-135							
Serving Area N-3	CF-135							
Serving Area N-4	CF-135							
Serving Area S-1	CF-135							
Serving Area S-2	CF-135							
Serving Area S-3	CF-135							
Serving Area S-4	CF-135							
Mechanical Rm 797	CF-135	10	M	55				
Mechanical Rm 798	CF-135							Damaged
Mechanical Rm 799	CF-135	10	M	35				E.O.L.
Mechanical Rm 799	Duct Det	10	M	57				
Stair to C-3 Landing	284-A			N/A			65	C-3 Landing
Office 757	73304	6	M	43				E.O.L.
Office 757	Key	6	M	31				
Office 757	Smoke Det	6	M	43				
Board Rm	Smoke Det							
Rm 755	CF-135							
C-3 Laundry	CF-135							
C-3 Laundry	CF-135							
C-3 Laundry	CF-135							
C-3 Laundry	CF-135							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							65	C - 3 Upper
In Rm 776	CF-135	6	M	43				Wrong label
In Rm 771	CF-135		M					C-1 Dome
Computer Storage	CF-135		M					
C-3 Landing Rm 1290	CF-135	6	M	43				
C-3 Landing Rm 1290	CF-135							
-3 Landing Rm 750	CF-135							Access by Rm 1290
C-3 Landing Rm 1289	CF-135							
C-3 Landing Rm 1289	CF-135							
C-3 Stair to Gun Cage	CF-135							
C-3 Gun Cage	73304	10	M	58			65	
	Key	6	M	11			66	
C-3 Attic	Smoke Det	10	M	58				
	Smoke Det							
	Smoke Det							
	Smoke Det							
	Smoke Det							
	Smoke Det							
	Smoke Det							
	Smoke Det							
C-3 W-Landing Stairs	CF-135							

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

[illegible]

[illegible]

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision		Zone Number	Notes or comments for customer's attention and/or action
								82	Building B-2 MCCP Evac.
MCCP Exit	NFM-950B-X Key	10	M	93					
MCCP Exit	Key	10	M	94					
MCCP Room	Relay	10	M	79					Fan Shutdown
								83	FOSB Building 1st Stage
									B-10 Bldg
South Main Entrance	MPS-950B-X	9	M	9					GA L9M29
North Rear Exit	MPS-950B-X	9	M	10					GA L9M30
West Exit	MPS-950B-X	9	M	11					GA L9M31
Main Entrance	FSI-751A	9	D	30					
West Hallway	FSI-751A	9	D	31					
North Hallway	FSI-751A	9	D	32					
North Exit	FSI-751A	9	D	33					
Gym Area	FSI-751A	9	D	34					
Computer Room	FSI-751A	9	D	35					
Computer Room Storage	FST-751RA	9	D	36					
Gym Storage	FST-751RA	9	D	37					
Hallway Storage	FST-751RA	9	D	38					
N.E. Room	FSI-751A	9	D	39					
Kitchen Area	FSI-751A	9	D	40					
Furnace Room	FST-751RA	9	D	41					
Crawl space - N.E.	FSI-751A	9	D	42					
Crawl space - N. Center	FSI-751A	9	D	43					
Crawl space - N.W.	FSI-751A	9	D	44					

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type or Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							77	Bldg C-29 Laundry
In Laundry Office	MPS-950KB-X	6	M	21			78	Key L6M19 E.O.L.
In Laundry Office	284-A							
Laundry NW	284-A							
Laundry SW	284-A							
Laundry Cntr N	284-A							
Laundry Cntr S	284-A							Wires hanging out
behind Dryers	CR-135							Disconnected
behind Dryers	CR-135							Disconnected
Janitor Closet	284-A							
Washroom	284-A							
Large Washroom	284-A							
Officers Issue Rm	284-A							
Issue Rm Storage	284-A							
Issue Rm Storage	284-A							
Issue Rm Storage	284-A							
SW corner	E.O.L.							
Main Entrance	284-A							
Basement Stairs	CF-135							
Basement Stairs	73304							Key
3smt South	CF-135							
3smt Cnt W	CF-135							
3smt Cntr	CF-135							
3smt Cntr E	CF-135							
3smt NW	CF-135							
3smt N Cntr	CF-135							
3smt N	CF-135							

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

		Loop Number	Module or Device	Address No.	Operation	Supervision		Zone Number	
Location of Equipment Tested	Device Type of Model Number								Notes or comments for customer's attention and/or action
								83	FOSB Building 1st Stage
									B-10 Bldg - cont'd
Crawlspace - S.E.	FSI-751A	9	D	45					
Crawlspace - S. Center	FSI-751A	9	D	46					
Crawlspace - S.W.	FSI-751A	9	D	47					
								84	B-10 Bldg Evac.
South Main Entrance	MPS-950B-X	9	M	29					Keyswitch 2nd Stage
North Rear Exit	MPS-950B-X	9	M	30					Keyswitch 2nd Stage
West Exit	MPS-950B-X	9	M	31					Keyswitch 2nd Stage
								85	Bldg A-3 Staff
Staff Lounge Pnl.	Contacts	6	M	19					
Main Entrance	Edwards-2280	6	M	19					A-3
Battery Test									
Tic to Squad Off.	Relay Alarm								
	Trouble								Not Monitored
								1	Main Floor
Main E Entrance	270-SPO								
W - Exit	270-SPO								
Storage Rm 25	CF-135								
Old Kitchen Janitor Rm	CF-135								
Kitchen Exit	270-SPO								

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
							4	Bsmt Mech Rm
Mech Rm	CF-200							E.O.L. Test by shorting
							5	N W Stairs
Stairtop	DI-3							E.O.L.
							6	S - E Stairs
Stairtop	DI-3							E.O.L.
							7	Duct Detector
Not located	Duct Det			N/A				Not located
							8	Elevator Shaft
Top of Shaft	73342							Test by shorting - (should be smoke det)
							9	**Spare
							10	**Spare

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								Horns / Strobes / Bells
In Main F.A. Panel								B-12 Hospital
Hospital Horns	1st Stage	4	M	51			56	
Hospital Horns	2nd Stage	4	M	52			57	
	Bells							
								Bldg B-12 Hospital
		4	M	51				Activated by z56
		4	M	52				Activated by z57
by Treatment Rm 661	Sentron 306							
by Strip Cells	Sentron 306							
In Crawlspace	Sentron 306							
In Main F.A. Panel								C-2 Bells
C-2 Building	1st Stage	4	M	53			63	See Zone 63
C-2 Building	2nd Stage	4	M	54			64	
	Bell							
In Main F.A. Panel								C-1 Bells
C-1 Building	1st Stage	4	M	55			60	See Zone 60
C-1 Building	2nd Stage	4	M	56			61	
Dome Office	Bell							
In Main F.A. Panel								C-3 Bells
C-3 Building	1st Stage	4	M	57			65	
C-3 Building	2nd Stage	4	M	58			66	
Electrical Storage	Bell							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								Block A - 4th Floor Strobes
	1st Stage	4	M	75			47	
	2nd Stage	4	M	76			47	
West	P2415-A							
East	P2415-A							E.O.L.
								Block A - 2nd Floor Horns
	1st Stage	4	M	77				
	2nd Stage	4	M	78				
West	P2415-A							
East	P2415-A							E.O.L.
								Block A - 2nd Floor Strobes
	1st Stage	4	M	79				
	2nd Stage	4	M	80				
West	P2415-A							
East	P2415-A							E.O.L.
								B-9
	1st Stage			81			54	
	2nd Stage			82			55	
Office Hallway	P2415-A							
Hallway	P2415-A							E.O.L.

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								Block B-3&5 Cells
	1st Stage	5	M	3			5	Xzone (5,6,7,8,9,10,11,12)
	2nd Stage	5	M	4			5	
								C-7
	1st Stage	5	M	5				Xzone (23,24,25,26,27,28)
	2nd Stage	5	M	6				Xzone (29,30,31)
								C-6
	1st Stage	5	M	7				Xzone (23-28)
	2nd Stage	5	M	8				Xzone (29-31)
								C-5
	1st Stage	5	M	9				Xzone (23-28)
	2nd Stage	5	M	10				Xzone (29-31)
								B-7
	1st Stage	5	M	11				Xzone (16-19) Xzone (13,14,15)
	2nd Stage	5	M	12			32	
Main Floor	MASS-24							
2nd Floor	MASS-24							
3rd Floor	MASS-24							
Penthouse	MASS-24							E.O.L.

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								Bldg C-7
	1st Stage	5	M	5				x-zone (z23,24,25,26,27,28)
	2nd Stage	5	M	6				x-zone (z29,30,31)
Lower Level East W-End	MASS-24							
Lower Level Shop	MASS-24							Not working
Upper Level E-Wall	MASS-24							Damaged
Upper Level N-Wall	MASS-24							
								Bldg C-6
	1st Stage	5	M	7				x-zone (z23-28)
	2nd Stage	5	M	8				x-zone (z29-31)
Upper Level South	MASS-24							
Upper Level North	MASS-24							
Lower North	MASS-24							
Lower South	MASS-24							
								Bldg C-5
	1st Stage	5	M	9				x-zone (z23-28)
	2nd Stage	5	M	10				x-zone (z29-31)
Upper Level North	MASS-24							
Lower Level South	MASS-24							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								C-19
	1st Stage	5	M	13			33	
	2nd Stage	5	M	14			34	
	Horn/Strobe							
Gym Canteen	MASS-24							
Gym Canteen	MASS-24							
Gym	MASS-24							
Gym	MASS-24							
eight Rm	MASS-24							
Mech Rm	MASS-24							
								E-F 1-2
	1st Stage	6	M	63		9	10	
	2nd Stage	6	M	64		9	10	
								C 3-4 F4 - Strobe
		6	M	65				
		6	M	66				
In Dome Entrance	Strobe							
								F-3 Strobe
	1st Stage	6	M	67			11	
	2nd Stage	6	M	68			11	
Dome Entrance	Strobe							E.O.L.
								A-B 1-2
	1st Stage	6	M	69		5	6	
	2nd Stage	6	M	70		5	6	
	Strobe							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
 Prince Albert, Saskatchewan

Location of Equipment Tested	Device Type of Model Number	Loop Number	Module or Device	Address No.	Operation	Supervision	Zone Number	Notes or comments for customer's attention and/or action
								Building C-13-14
	1st Stage	10	M	38			69	
	2nd Stage	10	M	39			70	
	Bells							
								C-20
	1st Stage	10	M	40				Removed from program 09/30/05 - KO Building gone
	2nd Stage	10	M	41				
	Bell							
								C-21
	1st Stage	10	M	42			73	Removed from program 09/30/05 - KO Building gone
	2nd Stage	10	M	43			74	
	Bell							
								C-22
	1st Stage	10	M	44			75	
	2nd Stage	10	M	45			76	
	Bells							

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]

Addressable Fire Alarm Systems

Prince Albert Penitentiary
Prince Albert, Saskatchewan

[illegible]