



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Avenue
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Northern Contaminated Site Program
ATB Place North Tower
10025 Jasper Avenue
Edmonton
Alberta
T5J 1S6

Title - Sujet Garden River Remediation	
Solicitation No. - N° de l'invitation EW699-171528/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PARKS EW699-171528	Date 2016-12-23
GETS Reference No. - N° de référence de SEAG PW-\$NCS-003-10933	
File No. - N° de dossier NCS-6-39181 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-01-20	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Bilous, Isabelle	Buyer Id - Id de l'acheteur ncs003
Telephone No. - N° de téléphone (780) 782-8714 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. – N° de l'invitation
EW699-171528/A

Amd. No. – N° de la modif
001

Buyer ID – ID de l'acheteur
ncs003

Client Ref No. – N° de réf/ du client
PARKS EW699-171528

File No. – N° du dossier
NCS-6-39181

This amendment is raised to modify solicitation EW699-171528/A as follows:

Questions and Answers:

Question 1: Please provide a gradation on the clear stone. Is this a washed rock?

Answer 1: The specification for the clear stone is for a 50 mm, uniformly graded clear stone, with L.A. Abrasion test result of 40% loss or less. Gradation requirements are as follows: 90 – 100% passing 53 mm sieve; 0-15% passing 19 mm sieve; 0 – 2% passing 75 µm. The material does not need to be washed.

Question 2: Where are the drawings located?

Answer 2: The drawings are contained within the specification documents and are not contained in a separate file or folder. Disregard the empty "Drawings" folder.

All other terms and conditions remain unchanged.