



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions Travaux**  
**publics et Services gouvernementaux Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Building Site Rehabilitation	
<b>Solicitation No. - N° de l'invitation</b> EZ899-171601/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2016-12-28
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-025-7920	
<b>File No. - N° de dossier</b> PWY-6-39221 (025)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-01-11</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Fung, Donna(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy025
<b>Telephone No. - N° de téléphone</b> (604) 671-9689 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada (PCA) - Gulf of Georgia Cannery National Historic Site - Richmond, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

**Les documents français seront disponibles sur demande.**

This Amendment No. 001 is raised to:

- 1) extend the solicitation closing date, and
- 2) incorporate Addendum No. 001.

**Extension of Time**

Building Site Rehabilitation

Gulf of Georgia Cannery National Historic Site, Richmond, BC

**Solicitation No: EZ899-171601/A**

Notice is hereby given that the time for reception of tenders previously due at  
2:00 p.m. on 4 January 2017 is hereby extended to  
**2:00 p.m. on 11 January 2017.**

Please see the attached Addendum No. 001

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.**

\*\*\*\*\*

**AVIS AUX SOUMISSIONNAIRES:** Veuillez utiliser l'étiquette d'adresse ci-dessous et bien l'affixer à l'extérieur de l'enveloppe ou du paquet renfermant votre offre. Dans le cas de modifications à des offres soumises par télécopieur (Fax: (604) 775-9381), servez-vous de la feuille comme page couverture. Assurez-vous de toujours inscrire lisiblement le nom de votre compagnie, l'adresse de retour, le numéro de l'offre et la date limite sur l'extérieur de votre offre.

**Marchés immobiliers  
Travaux publics et Services gouvernementaux Canada  
800, rue Burrard, bureau 219  
Vancouver (C.-B.) V6Z 0B9**

Offre no: EZ899-162132/A

Date et heure limites de  
reception des soumissions: le 11 janvier 2017, 1400h

Sujet: Remise en état du site du bâtiment  
Lieu historique national Gulf of Georgia Cannery, Richmond (C.-B.)

DF

**1) All drawings;**

- .1 PWGSC Project No. corrected to include decimal after 'R' ie. R.0670702.001

**2) L5.0 – Detail 5, L5.1 – Detail 1 & 2;**

- .1 (4) 10M longitudinal reinforcement bars added to 300mm wide CIP concrete paving band, typical.

**3) L5.6 – Detail 2**

- .1 Transition plate clarified as 'checker-plate' per 05 50 00  
.2 Reinforced CIP concrete footing detail revised to support extension of metal beam (complete with base plate and fasteners)

**4) Specification Revisions, typical,**

- .1 03 20 00:  
1.4 'MEASUREMENT FOR PAYMENT' deleted
- .2 05 50 00:  
1.5 'MEASUREMENT FOR PAYMENT' deleted
- .3 06 20 00:  
1.7 'MEASUREMENT FOR PAYMENT' deleted
- .4 12 93 00:  
1.7 'MEASUREMENT FOR PAYMENT' deleted
- .5 31 12 13:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .6 31 22 13:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .7 31 23 16:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .8 32 01 90:  
1.8 'MEASUREMENT FOR PAYMENT' deleted
- .9 32 12 16:  
1.4 'MEASUREMENT FOR PAYMENT' deleted
- .10 32 13 13:  
1.5 'MEASUREMENT FOR PAYMENT' deleted
- .11 32 14 13:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .12 32 14 43:  
1.2 'MEASUREMENT FOR PAYMENT' deleted

- .13 32 15 40:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .14 32 91 21:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .15 32 92 23:  
1.2 'MEASUREMENT FOR PAYMENT' deleted
- .16 32 93 10:  
1.2 'MEASUREMENT FOR PAYMENT' deleted

**5) Section 03 20 00;**

- .1 Clause 1.1.2: revised to reference section 32 13 13 correctly
- .2 Clause 2.1.1: revised to replace reference to "Contractor's Engineer" with "Departmental Representative"
- .3 Clause 1.3.1.1 / 2.1.10 and 3.3.1 revised to reference latest edition of CSA "CAN/CSA-A23.1/A23.2-09"

**6) Questions received by PWGSC (prior to December 23, 2016):**

- .1 *Section 1.5 (Hoarding) under Temporary Barriers & Enclosures has two different requirements for temporary site enclosures ~ painted plywood & timber vs. 1.2m snow fencing on posts. Which specification takes precedence for this project?*

Refer to L0.1 Demolition and Site Protection Plan Notes 6 and 8 for clarification. Both types of barriers are required depending on context. Snow fencing will be used primarily for tree protection. See Item 16 for further clarification.

- .2 *Please clarify detail 5-L5.1 Note 2 'every second metal plate to have stencil along length of track'. Would every other plate have no lettering on it.*

Yes – every other plate would have no lettering.

- .3 *Detail 2-L5.5 note: 'where possible use existing materials as supplied by the owner to replace mesh panels.' Please confirm quantity of material supplied by owner.*

Upon request Departmental Representative will allow Contractor to determine extent of materials stored on-site for re-use.

- .4 *Detail 4/L5.3 asks for laser jet text Helvetica w/stencil cut. Could you clarify the quantity and location and laser cut and stencil work to be done on interpretive sign blade?*

Refer to L1.0 Materials Plan for location of interpretive signs. Stencil laser cut at base of sign as shown on Detail 4/L5.3.

- .5 *Detail 1/L5.6 confirm W200 and C200 sizing. W200 x ? and C200 x ?*

Steel framing to be engineered by the Contractor per Note 1 on L5.6 and specification section 05 50 00 clause 1.1.5.

Revision to Note 1 / L5.6 to read: "Contractor to submit engineered shop drawings for approval by Departmental Representative prior to fabrication showing all gates and screen and gangway ramp, including all steel framing connections and anchor bolts."

- .6 *In specifications section Metal Fabrications item 2.5.5.2 the sign base is described, assumed as item #14 'West Coast Fishery Sign Base' from L1.0, but description matches item #31 'metal interpretive sign blade'. Please confirm finishes for both item #14 and #31.*

The specification section referenced above refers only to the Interpretive Sign Blade. The West Coast Fishery sign is an existing site element (Item Q / L0.1) that is being mounted per Detail 3/L5.5.

- .7 *In the specification section Health and Safety Requirements 1.8.1.1 identifies Appendix 1, 2 and 3 for lead paint abatement. Appendix 1, 2 and 3 are not listed in the table of contents. Is there lead paint abatement in this contract?*

Lead abatement is not a requirement of this project and is not anticipated. This clause has been deleted from the specifications.

- .8 *General instructions 1.9.1 notes that if works take place after 17:30 then the contractor must pay for the services of a commissionaire. Do you have hourly rates?*

This clause has been deleted from the specifications.

- .9 *Confirm requirement noted in Specifications Construction Facilities 1.9.1 to have a full time security.*

This clause has been deleted from the specifications.

- .10 *Confirm location of site office and tool shed as listed in Specifications Construction Facilities 1.10 and 1.11*

Location is to be proposed by the Contractor as part of Logistic Plan to be submitted for approval to Departmental Representative per Note 11 / L0.1.

- .11 *Will moduloc fencing or equivalent be acceptable for temporary site hoarding?*

Yes - secure moduloc fencing is considered acceptable.

**END OF ADDENDUM #1**