

ATT. 007

Question:

Are there any temporary support members required to be installed by the contractor before removing the bottom chord members?

Answer:

Per Section 05 12 33 (structural steel for bridges), Sub-section 1.5 (submittals), the contractor is required to submit the following;

- .5 Submit description of methods, temporary bracing and strengthening, sequence of erection and type of equipment proposed for use in erecting structural steel signed and sealed by a Licensed Professional Engineer.
- .6 Submit description of methods, temporary bracing and strengthening, sequence of removals and type of equipment proposed for use in removing structural steel signed and sealed by a Licensed Professional Engineer.