



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Emergency Genset Replacement	
Solicitation No. - N° de l'invitation KM571-170516/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client KM571-170516	Date 2017-01-05
GETS Reference No. - N° de référence de SEAG PW-\$PWU-201-10912	
File No. - N° de dossier PWU-6-39221 (201)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-01-13	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ho (RPC), Hector	Buyer Id - Id de l'acheteur pwu201
Telephone No. - N° de téléphone (780) 901-0989 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: See Herein	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
KM571-170516/A
Client Ref. No. - N° de réf. du client
KM571-170516

Amd. No. - N° de la modif.
006
File No. - N° du dossier
PWU-6-39221

Buyer ID - Id de l'acheteur
pwu201
CCC No./N° CCC - FMS No./N° VME

This amendment has been raised to make the following changes:

Please see attached Addendum #004

**The following changes in the Tender Documents are effective IMMEDIATELY.
This addendum will form part of the Contract Documents**

Amend/revise the Standard Contract Documents as follows:

MODIFICATION TO THE WORK

1. Refer to Drawing G1.0 General Note 1 – Revise to say “Equipment screen shall be Archlouvers V4JS series. Finishes to be confirmed by owner. Supplied and installed by contractor.”
2. Refer to Specification 01 11 55 Note 28 – Add “The patching shall match the existing level of patching in the area. Where possible, sealant/patch shall match existing colors. Penetrations shall be filled with approved sealant.”
3. Refer to Specification 26 36 23 -- Cummins transfer switch shall be accepted as equal.
4. Refer to attached Specification 01 74 20 -- Waste Management & Disposal. This specification section was not included in the original tender package.

ADDITIONAL INFORMATION FOR CLARIFICATION

1. Refer to Addendum 1 for instructions regarding roof repair.
2. Refer to Specification 03 33 00 for concrete pad thickness. Concrete pad must extend at least 1.2m from all equipment to maintain electrical clearances. Exact dimensions may vary depending on generator and load bank manufacturers.
3. No structural work is taking place inside the building.

END OF ADDENDUM 4

PART 1 - GENERAL

1.1 CONSTRUCTION & DEMOLITION WASTE

- .1 Carefully deconstruct and source separate materials/equipment and divert, from D&C waste destined for landfill to maximum extent possible. Target for this project is 75% diversion from landfill. Reuse, recycle, compost, anaerobic digest or sell material for reuse except where indicated otherwise. On site sales are not permitted.
- .2 Source separate waste and maintain waste audits in accordance with the Environmental Protection Act,
 - .1 Provide facilities for collection, handling and storage of source separated wastes.
 - .2 Source separate the following waste:
 - .1 Brick and portland cement concrete.
 - .2 Corrugated cardboard.
 - .3 Wood, not including painted or treated wood or laminated wood.
 - .4 Gypsum board, unpainted.
 - .5 Steel.
 - .6 Items indicated in a Deconstruction and Waste Products Workplan Summary.
- .3 Submit a waste reduction workplan indicating the materials and quantities of material that will be recycled and diverted from landfill.
 - .1 Indicate how material being removed from the site will be reused, recycled, composted or anaerobically digested in a Deconstruction and Waste Products Workplan Summary.
- .4 Submit proof that all waste is being disposed of at a licensed land fill site or waste transfer site. A copy of the disposal/waste transfer site's license and a letter verifying that said landfill site will accept the waste must be supplied to Departmental Representative prior to removal of waste from the demolition site.

PART 2 - PRODUCTS

- .1 Not Used.

PART 3 - EXECUTION

- .1 Not Used.

END OF SECTION