



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Parks Canada Agency
1300 - 635 8 Ave SW
Calgary, AB T2P3M3
Bid Fax: (403) 292-4475

AMENDMENT / MODIFICATION

005

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
Suite 1300
635 - 8 Ave SW
Calgary, AB T2P3M3

Title-Sujet Monarch Creek Culvert Replacement and Bank Stabilization Yoho National Park		
Solicitation No. - No. de l'invitation 5P420-16-5309/A	Date: January 9, 2017	
GETS Reference No. - No de reference de SEAG PW-16-00760203	Amendment No. - N° de la modif. 005	
Solicitation Closes:		
at - à 02:00 PM	on - le January 10, 2017	Time Zone - Fuseau horaire MST - HNR
F.O.B. - F.A.B.		
Plant-Usine: <input type="checkbox"/>	Destination: <input checked="" type="checkbox"/>	Other-Autre: <input type="checkbox"/>
Address Inquiries to: - Adresser toute demande de renseignements à :		
Jen Maheu		
Telephone No. - No de téléphone	Fax No. - No de FAX:	
(403) 292-8502	(403) 292-4475	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:		
See Herein - Voir ici		

TO BE COMPLETED BY THE BIDDER (type or print)

Vendor/Firm Name	
Address - Adresse	
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur	
Titale - Titre	
Telephone No. - N° de telephone:	_____
Facsimile No. - N° de télécopieur:	_____
Signature	Date

Amendment 05

This amendment is being raised to distribute a bidder question and answer.

A) BIDDER QUESTION

Q12 Are we able to cast the culvert footing in place with appropriate hoarding and testing provided?

A12 The footings can be cast in place provided:

-Proper heating/hoarding is in place

-Cold weather placement standards are followed

-Concrete hauling time does not exceed maximum allowable time limit

-Field quality control is required including test cylinders cured on site under the same conditions as the footings.

All other terms and conditions remain unchanged.