



TENDER AMENDMENT

RETURN BIDS TO:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

Issuing Office:

Parks Canada Agency
635 – 8 Avenue S.W., Suite 1300
Calgary, AB T2P 3M3

MODIFICATION D'APPEL D'OFFRES

RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300,
Calgary, AB T2P 3M3
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Bureau de distribution :

Agence Parcs Canada
635 – 8 Avenue S.O., pièce 1300
Calgary (AB) T2P 3M3

Title: Staff Housing Construction, Phase 2, Waterton Lakes National Park		
Solicitation No.: / N° de l'invitation : 5P420-16-5333/A	Amendment No.: / N° de modification de l'invitation : 001	Date: January 16, 2017 Date : 16 janvier 2017
GETS Reference No.: / N° de référence de SEAG : PW-17-00762497		
Solicitation Closes: / L'invitation prend fin :		
At: 02:00 PM	On: January 26, 2017	Time Zone: Mountain Standard Time (MST)
À : 14h00	Le : 26 janvier 2017	Fuseau horaire : Heure normale des Rocheuses (HNR)
Address Inquiries to: / Adresser toute demande de renseignements à : Nicole Levesque-Welch		
Telephone No.: / N° de téléphone : (403) 292-4691	Fax No.: / N° de télécopieur : (403) 292-4475	Email Address: / Courriel : nicole.levesque-welch@pc.gc.ca
TO BE COMPLETED BY THE BIDDER (type or print) À ÊTRE COMPLÉTER PAR LE SOUMISSIONNAIRE (taper ou écrire en caractères d'imprimerie)		
Vendor/Firm Name – Nom du fournisseur/de l'entrepreneur		
Address - Adresse		
Name of person authorized to sign on behalf of the Vendor/Firm Nom de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur		
Title - Titre		
Signature		Date



AMENDMENT 001

This amendment is being raised to respond to questions submitted in response to solicitation 5P420-16-5333/A:

A. QUESTIONS AND ANSWERS

Q1. The detail for the small penetrations on A001 both have the bottom building paper lapping over top of the membrane. It's reversed so that water will not shed properly.

A1. Peel and stick membrane is applied to wall and turned onto the penetrating pipe to seal the opening. Provide building paper lapped as shown.

Q2. The Wall Assembly Detail on A002 for wall type EW2 shows the face of the brick cladding (assuming 50mm for the thickness of the brick cladding) 192.5mm from the plywood sheathing attached to the supporting wall studs. The assembly is 50mm of stone + 25mm of mortar + 15.5mm plywood + 64mm furring + 38mm furring. What supports this whole assembly?

A2. Cladding load is transferred through perpendicular wood furring connections back to the main wall framing.

All other terms and conditions remain the same.