



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Brunswick
E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

All questions are to be submitted in writing to the Contracting Officer, Gisèle Doucet - Email: gisele.doucet@pwgsc.gc.ca or Fax no. (506) 636-4376.

Vendor/Firm Name and Address
Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works Government Services Canada- Bid
Receiving / Réception des soumissions
189 Prince William Street
Room 405
Saint John
New Bruns
E2L 2B9

Title - Sujet Marine Fuel Dispensing-Courtenay,NB	
Solicitation No. - N° de l'invitation EC016-172199/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.070007.016	Date 2017-01-17
GETS Reference No. - N° de référence de SEAG PW-\$PWB-004-4039	
File No. - N° de dossier PWB-6-39154 (004)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-01	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet, Gisele PWB	Buyer Id - Id de l'acheteur pwb004
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EC016-172199 /A

Client Ref. No. - N° de réf. du client

R.070007.016

Amd. No. - N° de la modif.

003

File No. - N° du dossier

PWB-6-39154

Buyer ID - Id de l'acheteur

pwb004

CCC No./N° CCC - FMS No./N° VME

This Solicitation Amendment No. three (3) is raised to include the following addendum no. 3.

The following addendum to the tender documents is effective immediately. This addendum shall form part of the contract documents.

All other terms and conditions remain the same.

Addendum No. 3.

1. QUESTIONS AND ANSWERS

Q6 - E-Stop and Keyed Stations: We need specifications on these units, Manufacturer Reference # if possible, CSA or NEMA ratings, and enclosure types-PVC/Steel/Fiberglas, etc.?

A6 - E-stop and keyed stations to be NEMA 4x rated or better. Enclosure types are indicated on the drawings, except the temperature control cabinet which is required to also be NEMA 4x rated or better and made of a weather resistant material.

Q7 - Specification Section-26 05 21: Page-02: Item-2.3 Control Cables – Can you confirm where these would be used as the details on Dwg-400 do not indicate the requirement for this type of cable. Control indicated is line voltage!

A7 - The current system arrangement does not include low voltage control cables, however, if during construction a change is required to use low voltage control cables, the cables should be as specified. Where line voltage controls are required, use cables as specified in Section 26 05 21, Part 2.1 and 2.2.