

GENERAL

1.01 RELATED SECTIONS

- .1 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .2 Section 03 10 00 - Concrete Forming and Accessories
- .3 Section 03 30 00 - Cast-in-Place Concrete

1.02 REFERENCES

- .1 Canadian Standards Association (CSA)
 - .1 CAN/CSA-A23.1, Concrete Materials and Methods of Concrete Construction.
 - .2 CAN/CSA-A23.2-00, Methods of Test for Concrete.
 - .3 CAN/CSA-A3000-98-A5-98, Portland Cement.
 - .4 CAN/CSA-G30.18-M92(R1998), Billet-Steel Bars for Concrete Reinforcement.

1.03 SUBMITTALS

- .1 Shop Drawings
 - .1 Submit placing drawings prepared in accordance with plans to clearly show size, shape, location and all necessary details of reinforcing.
 - .2 Submit drawings showing formwork and falsework design to: CAN/CSA-A23.1.
 - .3 Drawings to bear stamp and signature of qualified professional engineer registered or licensed in Province of New Brunswick, Canada.

1.04 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 19 - Construction/Demolition Waste Management And Disposals.
- .2 Collect and separate plastic, paper packaging and corrugated cardboard in accordance with Waste Management Plan.
- .3 Place materials defined as hazardous or toxic in designated containers.
- .4 Ensure emptied containers are sealed and stored safely.
- .5 Use trigger operated spray nozzles for water hoses.
- .6 Designate cleaning area for tools to limit water use and runoff.

PRODUCTS

2.01 MATERIALS

TYPICAL REQUIREMENTS, UNLESS ALTERNATIVE REQUIREMENTS ARE SPECIFIED IN THE SCOPE OF WORK.

- .1 Portland cement: to CAN/CSA-A3000-A5, Type 10.
- .2 Reinforcing bars: to CAN/CSA-G30.18, Grade 400W.
- .3 Water: to CAN/CSA-A23.1
- .4 Aggregates: to CAN/CSA-A23.1. Coarse aggregate to be normal density.
- .5 Air Entraining Admixture: to ASTM C 260.
- .6 Chemical admixtures: to ASTM C 494. Departmental Representative to approve accelerating or set retarding admixtures during cold weather placing.
- .7 Concrete Retarders: to ASTM C 494, low VOC, solvent free. Do not allow moisture of any kind to come in contact with the retarder film
- .8 Joint sealer/filler: grey, to CAN/CGSB-19.24, Type 1, Class B.
- .9 Sealer: proprietary poly-siloxane resin blend.
- .10 Other concrete materials: to CAN/CSA-A23.1.

2.02 MIXES

- .1 Proportion concrete in accordance with CAN/CSA-A23.1.
- .2 Minimum compressive strength at 35 MPa OR as specified by Departmental Representative.
- .3 Nominal maximum size of coarse aggregate: to CAN/CSA-A23.1.
- .4 Slump: to CAN/CSA-A23.1.
- .5 Air content: concrete to contain purposely entrained air in accordance with CAN/CSA-A23.1, Table 10.
- .6 Admixtures: to CAN/CSA-A23.1.
- .7 Do not use calcium chloride or compounds containing calcium chloride.
- .8 Weigh aggregates, cement, water and admixtures separately when batching. Inspect and test scales for accuracy as directed. Accuracy to be such that successive quantities can be measured to within one percent of desired amounts. Tests certificates to be submitted to Departmental Representative upon request.

- .9 Provide certification that plant, equipment and all materials to be used in concrete comply with the requirements of CSA A23.1-00.
- .10 Provide certification from independent testing and inspection company that mix proportions selected will produce concrete specified quality and can be effectively placed and finished for all work under this contract.

3 EXECUTION

3.01 PREPARATION

- .1 Obtain Departmental Representative's approval before placing concrete. Provide 24 hours notice to placing concrete.
- .2 Pumping of concrete is permitted only after approval of equipment mixture.

3.02 CONSTRUCTION

- .1 Do concrete work in accordance with CAN/CSA-A23.1.
- .2 If allowable by Departmental Representative, pump concrete to following requirements.
 - .1 Arrange equipment so that no vibrations result which might damage freshly placed concrete.
 - .2 Where concrete is conveyed and placed by mechanically applied pressure, provide suitable equipment.
 - .3 Operate pump so that concrete, without air pockets, is produced.
 - .4 When pumping is discontinued and concrete remaining in pipe line is to be used, void pipe line in a manner that prevents contamination of concrete or separation of ingredients.
- .3 Concrete will be deposited in all cases as neatly as practical, directly in its final position, and will not be caused to flow in a manner to permit or cause segregation.

3.03 INSERTS

- .1 Cast in sleeves, ties, slots, anchors, reinforcement, frames, conduit, bolts, waterstops, joint fillers and other inserts required to be built-in. Sleeves and openings greater than 100 mm x 100 mm not indicated, must be approved by Departmental

Representative.

3.04 FINISHES

- .1 AS SPECIFIED IN THE SCOPE OF WORK
 - .1 Screed to plane surfaces and use wood floats.
 - .2 Provide round edges and joint spacings using standard tools.
 - .3 Trowel smooth and provide lightly brushed non-slip finish.

3.05 CONTROL JOINTS

- .1 Cut control joints in slabs on grade and cope walls at locations indicated, in accordance with CAN/CSA-A23.1 and install specified joint sealer/filler.

3.06 CURING

- .1 Cure and protect concrete in accordance with CAN/CSA-A23.1.
 - .1 Do not use curing compounds where bond is required by subsequent topping or coating.

3.07 SEALING

- .1 Following curing, apply poly-siloxane resin blend sealer at 4 m²/L.

3.08 SITE TOLERANCES

- .1 Finishing tolerance in accordance with CAN/CSA-A23.1.

3.09 FIELD QUALITY CONTROL

- .1 Concrete testing: to CAN/CSA-A23.2 by testing laboratory designated and paid for by Departmental Representative.

1 GENERAL

1.01 RELATED REQUIREMENTS

- .1 Section 03 30 00 - Cast-in-Place Concrete.

1.02 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CSA-A23.1-04/A23.2-04, Concrete Materials and Methods of Concrete Construction/Methods of Test and Standard Practices for Concrete.
 - .2 CSA-O86S1-05, Supplement No. 1 to CAN/CSA-O86-01, Engineering Design in Wood.
 - .3 CSA O121-M1978(R2003), Douglas Fir Plywood.
 - .4 CSA O151-04, Canadian Softwood Plywood.
 - .5 CSA O153-M1980(R2003), Poplar Plywood.
 - .6 CAN/CSA-O325.0-92(R2003), Construction Sheathing.
 - .7 CSA O437 Series-93(R2006), Standards for OSB and Waferboard.
 - .8 CSA S269.1-1975(R2003), Falsework for Construction Purposes.
 - .9 CAN/CSA-S269.3-M92(R2003), Concrete Formwork, National Standard of Canada
- .2 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S701-05, Standard for Thermal Insulation, Polystyrene, Boards and Pipe Covering.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Submit shop drawings for formwork and falsework.
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of New Brunswick, Canada.
- .3 Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 01 47 15 - Sustainable Requirements: Construction and Section 02 81 01 - Hazardous Materials.
- .4 Indicate method and schedule of construction, shoring, stripping and re-shoring procedures, materials, arrangement of joints, exposed finishes, ties, liners, and locations of temporary embedded parts. Comply with CSA S269.1, for falsework drawings, Comply with CAN/CSA-S269.3 for formwork drawings.
- .6 Indicate formwork design data: permissible rate of concrete placement, and temperature of concrete, in forms.
- .7 Indicate sequence of erection and removal of formwork/falsework as directed by Departmental Representative.
- .8 When slip forming and flying forms are used, submit details of equipment and procedures for review by Departmental Representative.

1.04 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 47 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Place materials defined as hazardous or toxic in designated containers.
 - .3 Divert wood materials from landfill to a facility as approved by Departmental Representative.
 - .4 Divert plastic materials from landfill to a facility as approved by Departmental Representative.
 - .5 Divert unused form release material from landfill to an official hazardous material collections site as approved by the Departmental Representative.

2 PRODUCTS

2.01 MATERIALS

- .1 Formwork materials:
 - .1 For concrete without special architectural features, use wood and wood product formwork materials to CSA-O121, CSA O437 Series, CSA-O153.
 - .2 Rigid insulation board: to CAN/ULC-S701 .
- .6 Form ties:
 - .1 For concrete not designated 'Architectural', use removable or snap-off metal ties, fixed or adjustable length, free of devices leaving holes larger than 25 mm diameter in concrete surface.
- .7 Form liner:
 - .1 Plywood: Douglas Fir to CSA O121.
- .8 Form release agent: non-toxic, biodegradable, low VOC.
- .9 Form stripping agent: colourless mineral oil, non-toxic, biodegradable, low VOC, free of kerosene, with viscosity between 70 and 110s Saybolt Universal 15 to 24 mm² /s at 40 degrees C, flashpoint minimum 150 degrees C, open cup.
- .10 Falsework materials: to CSA-S269.1.
- .11 Sealant: to Section 07 92 00 = Joint Sealants.

3 EXECUTION

3.01 FABRICATION AND ERECTION

- .1 Verify lines, levels and centres before proceeding with formwork/falsework and ensure dimensions agree with drawings.
- .2 Hand trim sides and bottoms and remove loose earth from earth forms before placing concrete.
- .3 Fabricate and erect falsework in accordance with CSA S269.1.

- .4 Fabricate and erect formwork in accordance with CAN/CSA-S269.3 to produce finished concrete conforming to shape, dimensions, locations and levels indicated within tolerances required by CSA-A23.1/A23.2.
- .5 Align form joints and make watertight.
 - .1 Keep form joints to minimum.
- .6 Use 25 mm chamfer strips on external corners and/or 25 mm fillets at interior corners, joints, unless specified otherwise.
- .7 Form chases, slots, openings, drips, recesses, expansion and control joints as indicated.
- .8 Build in anchors, sleeves, and other inserts required to accommodate Work specified in other sections.
 - .1 Ensure that anchors and inserts will not protrude beyond surfaces designated to receive applied finishes, including painting.
- .9 Clean formwork in accordance with CSA-A23.1/A23.2, before placing concrete.
- .10 When slip forming and flying forms are used, submit details as indicated in PART 1 - SUBMITTALS.
- .11 Verify field dimensions to determine applicable sizes to formwork.
- .12 Design and construct formwork to allow adequately for proper placement and consolidation while confirming with shape and dimensions shown on plans.
- .13 Formwork design will include closures at both top and bottom of form, and all necessary hardware to support the forms.
- .14 Upon request, submit drawings for review by the Departmental Representative, at least three (3) weeks before placement of concrete. Drawings will show formwork details and illustrate dimensions, method of placing of concrete connections, and support.

3.02 REMOVAL AND RESHORING

- .1 Remove formwork when concrete has reached 80 % of its design strength or minimum period noted above, whichever comes later, and replace immediately with adequate reshoring.
- .3 Provide necessary reshoring of members where early removal of forms may be required or where members may be subjected to additional loads during construction as required.
- .4 Space reshoring in each principal direction at not more than 3000 mm apart.
- .5 Re-use formwork and falsework subject to requirements of CSA-A23.1/A23.2.

END OF SECTION

1 GENERAL

1.01 RELATED REQUIREMENTS

- .1 Section 03 30 00 - Cast-in-Place Concrete.

1.02 REFERENCES

- .1 American Concrete Institute (ACI)
 - .1 SP-66-04, ACI Detailing Manual 2004.
- .2 ASTM International
 - .1 ASTM A 82/A 82M-07, Standard Specification for Steel Wire, Plain, for Concrete Reinforcement.
 - .2 ASTM A 143/A 143M-07, Standard Practice for Safeguarding Against Embrittlement of Hot-Dip Galvanized Structural Steel Products and Procedure for Detecting Embrittlement.
 - .3 ASTM A 185/A 185M-07, Standard Specification for Steel Welded Wire Reinforcement, Plain, for Concrete.
 - .4 ASTM A 775/A 775M-07b, Standard Specification for Epoxy-Coated Reinforcing Steel Bars.
- .3 CSA International
 - .1 CSA-A23.1-09/A23.2-09, Concrete Materials and Methods of Concrete Construction/Test Methods and Standard Practices for Concrete.
 - .2 CAN/CSA-A23.3-04(R2010), Design of Concrete Structures.
 - .3 CSA-G30.18-09, Carbon Steel Bars for Concrete Reinforcement.
 - .4 CSA-G40.20/G40.21-04(R2009), General Requirements for Rolled or Welded Structural Quality Steel/Structural Quality Steel.
 - .5 CAN/CSA-G164-M92(R2003), Hot Dip Galvanizing of Irregularly Shaped Articles.
 - .6 CSA W186-M1990(R2007), Welding of Reinforcing Bars in Reinforced Concrete Construction.
- .4 Reinforcing Steel Institute of Canada (RSIC)
 - .1 RSIC-2004, Reinforcing Steel Manual of Standard Practice.

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Prepare reinforcement drawings in accordance with RSIC Manual of Standard Practice and SP-66.
- .3 Shop Drawings:
 - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of New Brunswick, Canada.
 - .1 Indicate placing of reinforcement and:
 - .1 Bar bending details.
 - .2 Lists.
 - .3 Quantities of reinforcement.
 - .4 Sizes, spacings, locations of reinforcement and mechanical

splices if approved by Departmental Representative, with identifying code marks to permit correct placement without reference to structural drawings.

- .5 Indicate sizes, spacings and locations of chairs, spacers and hangers.
- .2 Detail lap lengths and bar development lengths to CAN/CSA-A23.3, unless otherwise indicated.
 - .1 Provide type A, B, C tension lap splices where indicated or unless otherwise indicated.

1.04 QUALITY ASSURANCE

- .1 Submit in accordance with Section 01 45 00 - Quality Control and as described in PART 2 - SOURCE QUALITY CONTROL.
 - .1 Mill Test Report: upon request, provide Departmental Representative with certified copy of mill test report of reinforcing steel, minimum 4 weeks prior to beginning reinforcing work.
 - .2 Upon request submit in writing to Departmental Representative proposed source of reinforcement material to be supplied.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labeled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground, in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Replace defective or damaged materials with new.

2 PRODUCTS

2.01 MATERIALS

- .1 Substitute different size bars only if permitted in writing by Departmental Representative.
- .2 Reinforcing steel: billet steel, grade 300, deformed bars to CSA-G30.18, unless indicated otherwise.
- .3 Reinforcing steel: weldable low alloy steel deformed bars to CSA-G30.18.
- .4 Cold-drawn annealed steel wire ties: to ASTM A 82/A 82M.
- .5 Deformed steel wire for concrete reinforcement: to ASTM A 82/A 82M.
- .6 Welded steel wire fabric: to ASTM A 185/A 185M.
 - .1 Provide in flat sheets only.
- .7 Welded deformed steel wire fabric: to ASTM A 82/A 82M.

- .1 Provide in flat sheets only.
- .8 Epoxy Coating of non-prestressed reinforcement: to ASTM A 775/A 775M.
- .9 Galvanizing of non-prestressed reinforcement: to CAN/CSA-G164, minimum zinc coating 610 g/m².
 - .1 Protect galvanized reinforcing steel with chromate treatment to prevent reaction with Portland cement paste.
 - .2 If chromate treatment is carried out immediately after galvanizing, soak steel in aqueous solution containing minimum 0.2% by weight sodium dichromate or 0.2% chromic acid.
 - .1 Temperature of solution equal to or greater than 32 degrees and galvanized steels immersed for minimum 20 seconds.
 - .3 If galvanized steels are at ambient temperature, add sulphuric acid as bonding agent at concentration of 0.5% to 1%.
 - .1 In this case, no restriction applies to temperature of solution.
 - .4 Chromate solution sold for this purpose may replace solution described above, provided it is of equivalent effectiveness.
 - .1 Provide product description as described in PART 1 - ACTION AND INFORMATIONAL SUBMITTALS.
- .10 Chairs, bolsters, bar supports, spacers: to CSA-A23.1/A23.2.
- .11 Mechanical splices: subject to approval of Departmental Representative.
- .12 Plain round bars: to CSA-G40.20/G40.21.

2.02 FABRICATION

- .1 Fabricate reinforcing steel in accordance with CSA-A23.1/A23.2, SP-66 and Reinforcing Steel Manual of Standard Practice by the Reinforcing Steel Institute of Canada.
 - .1 SP-66 unless indicated otherwise.
- .2 Obtain Departmental Representative's written approval for locations of reinforcement splices other than those shown on placing drawings.
- .3 Upon approval of Departmental Representative, weld reinforcement in accordance with CSA W186.
- .4 Ship bundles of bar reinforcement, clearly identified in accordance with bar bending details and lists.
 - .1 Ship epoxy coated bars in accordance with ASTM A 775A/A 775M.

2.03 SOURCE QUALITY CONTROL

- .1 Upon request, provide Departmental Representative with certified copy of mill test report of reinforcing steel, showing physical and chemical analysis, minimum 4 weeks prior to beginning reinforcing work.
- .2 Upon request inform Departmental Representative of proposed source of material to be supplied.

3 EXECUTION

3.01 PREPARATION

- .1 Galvanizing to include chromate treatment.
 - .1 Duration of treatment to be 1 hour per 25 mm of bar diameter.
- .2 Conduct bending tests to verify galvanized bar fragility in accordance with ASTM A 143/A 143M.

3.02 FIELD BENDING

- .1 Do not field bend or field weld reinforcement except where indicated or authorized by Departmental Representative.
- .2 When field bending is authorized, bend without heat, applying slow and steady pressure.
- .3 Replace bars, which develop cracks or splits.

3.03 PLACING REINFORCEMENT

- .1 Place reinforcing steel as indicated on placing drawings and in accordance with CSA-A23.1/A23.2.
- .2 Use plain round bars as slip dowels in concrete.
 - .1 Paint portion of dowel intended to move within hardened concrete with one coat of asphalt paint.
 - .2 When paint is dry, apply thick even film of mineral lubricating grease.
- .3 Prior to placing concrete, obtain Departmental Representative's approval of reinforcing material and placement.
- .4 Ensure cover to reinforcement is maintained during concrete pour.
- .5 Protect epoxy and paint coated portions of bars with covering during transportation and handling.

3.04 FIELD TOUCH-UP

- .1 Touch up damaged and cut ends of epoxy coated or galvanized reinforcing steel with compatible finish to provide continuous coating.

3.05 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PSPC
MINOR WORKS NB SOUTH/NORTH
VARIOUS LOCATIONS
PROVINCE OF NEW BRUNSWICK
PROJECT NO. R.076349.001

CONCRETE REINFORCING

SECTION 03 20 00

PAGE 5

END OF SECTION

1 GENERAL

1.01 RELATED REQUIREMENTS

- .1 Section 03 20 00 - Concrete Reinforcing
- .2 Section 03 37 26 - Underwater Placed Concrete

1.02 REFERENCES

- .1 Abbreviations and Acronyms:
 - .1 Portland Cement: hydraulic cement, blended hydraulic cement (XXb = b denotes blended) and Portland-limestone cement.
 - .1 Type GU, GUb and GUL - General use cement.
 - .2 Type MS and MSb - Moderate sulphate-resistant cement.
 - .3 Type MH, MHb and MHL - Moderate heat of hydration cement.
 - .4 Type HE, HEb and HEL - High early-strength cement.
 - .5 Type LH, LHb and LHL - Low heat of hydration cement.
 - .6 Type HS and HSb - High sulphate-resistant cement.
 - .2 Fly ash:
 - .1 Type F - with CaO content less than 15%.
 - .2 Type CI - with CaO content ranging from 15 to 20%.
 - .3 Type CH - with CaO greater than 20%.
 - .3 GGBFS - Ground, granulated blast-furnace slag.
- .2 Reference Standards:
 - .1 ASTM International
 - .1 ASTM C 260/C 260M-10a, Standard Specification for Air-Entraining Admixtures for Concrete.
 - .2 ASTM C 309-07, Standard Specification for Liquid Membrane-Forming Compounds for Curing Concrete.
 - .3 ASTM C 494/C 494M-10a, Standard Specification for Chemical Admixtures for Concrete.
 - .4 ASTM C 1017/C 1017M-07, Standard Specification for Chemical Admixtures for Use in Producing Flowing Concrete.
 - .5 ASTM D 412-06ae2, Standard Test Methods for Vulcanized Rubber and Thermoplastic Elastomers-Tension.
 - .6 ASTM D 624-00(2007), Standard Test Method for Tear Strength of Conventional Vulcanized Rubber and Thermoplastic Elastomer.
 - .7 ASTM D 1751-04(2008), Standard Specification for Preformed Expansion Joint Filler for Concrete Paving and Structural Construction (Nonextruding and Resilient Bituminous Types).
 - .8 ASTM D 1752-04a(2008), Standard Specification for Preformed Sponge Rubber Cork and Recycled PVC Expansion Joint Fillers for Concrete Paving and Structural Construction.
 - .2 Canadian General Standards Board (CGSB)
 - .1 CAN/CGSB-37.2-M88, Emulsified Asphalt, Mineral Colloid-Type, Unfilled, for Dampproofing and Waterproofing and for Roof Coatings.
 - .2 CAN/CGSB-51.34-M86(R1988), Vapour Barrier, Polyethylene Sheet for

- Use in Building Construction.
- .3 Canada Green Building Council (CaGBC)
 - .1 LEED Canada-NC Version 1.0-2004, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Package For New Construction and Major Renovations (including Addendum 2007).
 - .2 LEED Canada-CI Version 1.0-2007, LEED (Leadership in Energy and Environmental Design): Green Building Rating System Reference Guide For Commercial Interiors.
 - .4 CSA International
 - .1 CSA A23.1/A23.2-09, Concrete Materials and Methods of Concrete Construction/Methods of Test and Standard Practices for Concrete.
 - .2 CSA A283-06, Qualification Code for Concrete Testing Laboratories.
 - .3 CSA A3000-08, Cementitious Materials Compendium (Consists of A3001, A3002, A3003, A3004 and A3005).

1.03 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Provide testing results and reports for review by Departmental Representative and do not proceed without written approval when deviations from mix design or parameters are found.
- .3 Concrete hauling time: provide for review by Departmental Representative deviations exceeding maximum allowable time of 120 minutes for concrete to be delivered to site of Work and discharged after batching.
- .6 Provide two copies of WHMIS MSDS in accordance with Section 01 35 29.06 - Health and Safety Requirements, 01 35 43 - Environmental Procedures.

1.04 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 45 00 - Quality Control.
- .2 Provide Departmental Representative, minimum 4 weeks prior to starting concrete work, with valid and recognized certificate from plant delivering concrete.
 - .1 Provide test data and certification by qualified independent inspection and testing laboratory that materials and mix designs used in concrete mixture will meet specified requirements.
- .3 Minimum 4 weeks prior to starting concrete work, provide proposed quality control procedures for review by Departmental Representative on following items:
 - .1 Falsework erection.
 - .2 Hot weather concrete.
 - .3 Cold weather concrete.
 - .4 Curing.
 - .5 Finishes.
 - .6 Formwork removal.
 - .7 Joints.

1.05 DELIVERY, STORAGE AND HANDLING

- .1 Delivery and Acceptance Requirements:
- .1 Concrete hauling time: deliver to site of Work and discharged within 120 minutes maximum after batching.
 - .1 Do not modify maximum time limit without receipt of prior written agreement from Departmental Representative and concrete producer as described in CSA A23.1/A23.2.
 - .2 Deviations to be submitted for review by Departmental Representative.
- .2 Concrete delivery: ensure continuous concrete delivery from plant meets CSA A23.1/A23.2.

2 PRODUCTS UNLESS SPECIFIED DIFFERENTLY IN THE STATEMENT OF WORK

2.01 DESIGN CRITERIA

- .1 Alternative 1 - Performance: to CSA A23.1/A23.2.

2.02 PERFORMANCE CRITERIA

- .1 Quality Control Plan: ensure concrete supplier meets performance criteria of concrete as established by Departmental Representative and provide verification of compliance as described in PART 1 - QUALITY ASSURANCE.

2.03 MATERIALS UNLESS SPECIFIED DIFFERENTLY IN THE STATEMENT OF WORK

- .1 Blended hydraulic cement: Type GUb to CSA A3001.
- .3 Portland-limestone cement: Type GUL to CSA A23.1.
- .4 Supplementary cementing materials to CSA A3001.
- .5 Water: to CSA A23.1.
- .6 Aggregates: to CSA A23.1/A23.2.
- .7 Admixtures:
 - .1 Air entraining admixture: to ASTM C 260.
 - .2 Chemical admixture: to ASTM C 494/ ASTM C 1017. Departmental Representative to approve accelerating or set retarding admixtures during cold and hot weather placing.
- .8 Shrinkage compensating grout: premixed compound consisting of non-metallic aggregate, Portland cement, water reducing and plasticizing agents to CSA A23.1/A23.2.
 - .1 Compressive strength: 35 MPa at 28 days.
 - .2 Net shrinkage at 28 days: maximum 0.5 %.
- .9 Non premixed dry pack grout: composition of non metallic aggregate Portland

cement with sufficient water for mixture to retain its shape when made into ball by hand and capable of developing compressive strength of 35 MPa at 28 days.

- .10 Post-Tensioning Ducts: to CSA A23.1/A23.2.
- .11 Curing compound: to CSA A23.1/A23.2 white and ASTM C 309.

2.04 MIXES

- .1 The contractor shall be responsible for the concrete mix design.
- .2 It shall be the responsibility of the contractor to ensure that the mixture proportions shall be properly batched, mixed, placed and cured such that the concrete conforms to the specification.
- .3 Proportion normal density concrete in accordance with CAN/CSA-A23.1, Alternative 1, to give following properties:
 - .1 Cement: GUb-F/SF.
 - .2 Minimum compressive strength at 28 days: 35 MPa.
 - .3 Minimum cement content: 400 kg/m³ of concrete.
 - .4 Maximum water/cement ratio: 0.40.
 - .5 Class of exposure: C-1.
 - .6 Nominal size of coarse aggregate: 20 mm.
 - .7 Slump at time and point of discharge: 50 to 100 mm.
 - .8 Air content: 5 to 8%.

3 EXECUTION

3.01 PREPARATION

Concrete General

- .1 Obtain Departmental Representative's written approval before placing concrete.
 - .1 Provide 24 hours minimum notice prior to placing of concrete.
- .2 Place concrete reinforcing in accordance with Section 03 20 00 - Concrete Reinforcing.
- .3 During concreting operations:
 - .1 Development of cold joints not allowed.
 - .2 Ensure concrete delivery and handling facilitates placing with minimum of re-handling, and without damage to existing structure or Work.
- .4 Pumping of concrete is permitted only after approval of equipment and mix.
- .5 Ensure reinforcement and inserts are not disturbed during concrete placement.
- .6 Prior to placing of concrete obtain Departmental Representative's approval of proposed method for protection of concrete during placing and curing in adverse weather .

- .7 Maintain accurate records of poured concrete items to indicate date, location of pour, quality, air temperature and test samples taken.
- .8 Do not place load upon new concrete until authorized by Departmental Representative.

3.02 INSTALLATION/ APPLICATION

- .1 Do cast-in-place concrete work to CSA A23.1/A23.2.
- .2 Sleeves and inserts:
 - .1 Do not permit penetrations, sleeves, ducts, pipes or other openings to pass through joists, beams, column capitals or columns, except where indicated or approved by Departmental Representative.
 - .2 Where approved by Departmental Representative, set sleeves, ties, pipe hangers and other inserts and openings as indicated or specified elsewhere.
 - .3 Sleeves and openings greater than 100 x 100 mm not indicated, must be reviewed by Departmental Representative.
 - .4 Do not eliminate or displace reinforcement to accommodate hardware. If inserts cannot be located as specified, obtain written approval of modifications from Departmental Representative before placing of concrete.
 - .5 Confirm locations and sizes of sleeves and openings shown on drawings.
 - .6 Set special inserts for strength testing as indicated and as required by non-destructive method of testing concrete.
- .3 Anchor bolts:
 - .1 Set anchor bolts to templates in co-ordination with appropriate trade prior to placing concrete.
 - .2 Grout anchor bolts in preformed holes or holes drilled after concrete has set only after receipt of written approval from Departmental Representative.
 - .1 Formed holes: 100 mm minimum diameter.
 - .2 Drilled holes: 25 mm minimum diameter larger than bolts used or to manufacturers' recommendations.
 - .3 Protect anchor bolt holes from water accumulations, snow and ice build-ups.
 - .4 Set bolts and fill holes with shrinkage compensating grout or epoxy grout.
 - .5 Locate anchor bolts used in connection with expansion shoes, rollers and rockers with due regard to ambient temperature at time of erection.
- .6 Grout under base plates using procedures in accordance with manufacturer's recommendations which result in 100 % contact over grouted area.
- .7 Reinforcing Steel:
 - .1 Place new reinforcing steel according to Section 03 20 00.
 - .2 Provide 75mm minimum cover for all reinforcing steel unless indicated otherwise on drawings.
- .8 Formwork:

- .1 As per section 03 10 00.
- .9 Finishing and curing:
 - .1 Finish concrete to CSA A23.1/A23.2.
 - .2 Use procedures as reviewed by Departmental Representative or those noted in CSA A23.1/A23.2 to remove excess bleed water. Ensure surface is not damaged.
 - .3 Use curing compounds compatible with applied finish on concrete surfaces. Provide written declaration that compounds used are compatible.
 - .4 Rub exposed sharp edges of concrete with carborundum to produce 3 mm minimum radius edges unless otherwise indicated.

3.03 SURFACE TOLERANCE

- .1 Concrete tolerance to CSA A23.1 Straightedge Method. Provide a smooth surface of uniform texture, true to required grade and cross section.

3.04 FIELD QUALITY CONTROL

- .1 Site tests: conduct tests as follows in accordance with Section 01 45 00 - Quality Control.
 - .1 Concrete pours.
 - .2 Slump.
 - .3 Air content.
 - .4 Compressive strength at 7 and 28 days.
 - .5 Air and concrete temperature.
- .2 Inspection and testing of concrete and concrete materials will be carried out by testing laboratory designated by Departmental Representative for review to CSA A23.1/A23.2.
 - .1 Ensure testing laboratory is certified to CSA A283.
- .3 Ensure test results are distributed for discussion at pre-pouring concrete meeting between testing laboratory and Departmental Representative.
- .4 Departmental Representative will pay for costs of tests as specified in Section 01 29 83 - Payment Procedures for Testing Laboratory Services.
- .5 Departmental Representative will take additional test cylinders during cold weather concreting. Cure cylinders on job site under same conditions as concrete which they represent.
- .6 Non-Destructive Methods for Testing Concrete: to CSA A23.1/A23.2.
- .7 Inspection or testing by Consultant will not augment or replace Contractor quality control nor relieve Contractor of his contractual responsibility.

PSPC
MINOR WORKS NB SOUTH/NORTH
VARIOUS LOCATIONS
PROVINCE OF NEW BRUNSWICK
PROJECT NO. R.076349.001

CAST-IN-PLACE CONCRETE

SECTION 03 30 00

PAGE 7

3.05 CLEANING

- .1 Clean in accordance with Section 01 74 11 - Cleaning.

END OF SECTION