Materiel and Procurement Services 200 Kent Street, Station 9S018 Ottawa, Ontario K1A 0E6

January 25, 2017

Subject: Invitation to Tender: FP802-160389

Title: Fit-up Accommodations, Office and Garage Buildings

Work site location: Gimli, Manitoba

ADDENDUM: No. 1

Further to the above mentioned Invitation to Tender documentation previously posted on the Government Electronic Tendering Site (GETS), BuyandSell.gc.ca, Addendum (#1) is hereby issued.

Department of Fisheries and Oceans

Bid Closing Date: Thursday, February 2, 2017

Time: 14:00 Hours (2:00 pm) Eastern Daylight Time (EDT)

RFP File No: FP802-160389

** THE FOLLOWING QUESTION WAS SUBMITTED BY A POTENTIAL BIDDER TO THE CONTRACTING AUTHORITY IN RELATION TO THE SUBJECT ITT**

Q.1 Will the Department of Fisheries and Oceans accept substitutions or equivalents to the specifications where not stated in the ITT?

A.1 The Department of Fisheries and Oceans will NOT accept substitutions or equivalents to the specifications.

- Q.2 What is the lowest obstruction/headroom available above this overhead door? I'm asking to determine if this overhead door needs high-lift added to the tracks or if standard lift is suitable.
- A.2 For the workshop overhead door, the nearest obstruction is approximately 1200mm above top of door.
- Q.3 Can you confirm what section 08 36 00 Products: 1.C.i and ii
- Aluminum sash section with DSB glazing? is this an aluminum section on the top section of this door with glazing? I'm unsure about what the aluminum sash section is referring to.
- A.3 DELETE all references to sash. All windows fixed.

All other Terms and Conditions for this requirement remain unchanged.

<u>Tenderers are to acknowledge this Addendum by signing in the space provided below and enclosing a copy of this document with their tender submission.</u>

Regards

Michael Vanek Senior Contracting Officer Telephone: (613) 993-8935

Email: michael.vanek@dfo-mpo.gc.ca

RECEIPT ACKNOWLEDGED	
Name of Company	
Signature	