



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency
National Contracting Services**

**3, passage du Chien-d 'Or
Quebec, QC
G1R 3Z8**

INVITATION TO TENDER
APPEL D'OFFRES

AMENDMENT #1 TO:

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission à: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaires

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency
3, passage du Chien-d 'Or
Quebec, QC, G1R 3Z8

Title-Sujet SALT STORAGE FACILITY – ROCKY HARBOUR		Date January 27, 2017
Solicitation No. - No. de l'invitation 5P300-16-5635		Client Ref. No. – No. de réf du client.
GETS Reference No. – No de reference de SEAG		
Solicitation Closes L'invitation prend fin – at – à 2:00 PM on – le 2017-02-15		Time Zone Fuseau horaire - EASTERN STANDARD TIME (EST)
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Sylvie Lagacé sylvie.lagace@pc.gc.ca		
Telephone No. - No de téléphone 418 648-5006		Fax No. – No de FAX: 418 649-6971
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur Telephone No. - No de téléphone: _____ Facsimile No. - N° de télécopieur: _____		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur _____		
Name / Nom		Title / Titre
Signature		Date

QUESTIONS&ANSWERS #1

THE PUPOSE OF THIS AMENDMENT IS TO SHARE ANSWERS TO QUESTIONS ASKED BY POTENTIAL BIDDERS. YOU MUST CONSIDER THE INFORMATION IN THE EVALUATION OF YOUR BID.

Question 1.

Is an inner fabric liner mandatory?

Answer 1.

No. If proponent's ARE including and inner fabric liner in their bid, please indicate in the technical proposal how it adds value to the finished product. Conversely, if proponent's ARE NOT including and inner fabric liner in their bid, please indicate in the technical proposal why it has been left out of the finished product.

Question 2.

After reviewing the summary of work for this Tender I came across a few questions.

In the summary of work it states

"The major Work Items of this Contract comprises erection of a pre-engineered structure on concrete foundations (built by others) and the installation of membrane roofing system and other building supplied element as set out in the project Terms of Reference."

This I understand, but then in the description of project is states:

"Potential contractors are advised this work consists of the design, supply, and erection of a new tension membrane structure to be installed on top of a 10 foot high by 1.0 foot thick reinforced concrete foundation. »

I wanted to clarify this tender is to construct the building, design building along with engineer stamped drawings?

Answer 2.

This tender is seeking a qualified contractor to perform the removal and proper disposal/re-use of the existing salt shed, then the design and erection of a new salt shed (including concrete foundation and membrane structure).

Question 3.

In the above RFP there is a mention of a slab on grade in **Section 3.0 Key Objectives** as well as an Asphalt Floor (option based on available funding) in the foundation description. Does this mean Parks Canada wants a slab on grade in the structure and may pave the slab on grade or may choose to use an asphalt floor instead of a slab on grade depending on funding? As the asphalt floor is not a definite part of the scope I will keep it separate from the total bid price as an option to the Owner if they wish to pursure. I just want to make sure I am pricing it right.

Answer 3.

Answer: All references to concrete slab-on-grade should be ignored. The intention is to incorporate a compacted gravel floor into the final build, with the option to pave it with asphalt if the funding is available. Please provide a separate price to pave with asphalt in your proposal.

Question 4.

Can Parks Canada please confirm if the interior floor is to be located on the top of the footing allowing the full 10' high concrete wall to be utilized for storage or if the strip footing may be sunk into the ground to provide less than 10' high exposed interior wall.

Answer 4.

Proponent's must submit their design proposal's as part of their "Technical" submission. Proponents' submissions will be evaluated by Parks Canada, and MUST meet the functional requirements outlined in the Statement of Work.

Question 5.

What size large door opening is required? Is the same size large door opening required on both end walls?

Answer 5.

The door opening needs to be large enough to facilitate the safe loading and unloading of salt from the facility. It is up to proponents to determine if door openings are required on both end walls.

Question 6.

Can Parks Canada please confirm that the storage facility will only use salt, or will there be a potential situation where sand will be stockpiled as well? This will affect the structural design.

Answer 6.

Only salt will be stockpiled in the new facility.

End of section.

THE BID CLOSING DATE REMAINS THE SAME.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

**Signed copy of this amendment should accompany each tender. If your tender has already been submitted please sign and fax the amendment along with any revisions to tender price, to this office before the close of Tender.
Fax: 418 649-6971.**