

## MECHANICAL ADDENDUM No. MADD-02

---

INNISFAIL RCMP Detachment Renovations

NORR Project No.: NCCA16-0095

TO: ALL BIDDERS OF RECORD

RE: ADDENDUM NO. 02, Date: 2017-01-31  
MAD

ADDENDUM NO. MADD-02:

### Mechanical

---

**Refer to Question number 1: to reuse the existing R22 refrigerant in both systems or to use a new R22 refrigerant.**

1. It is recommended to use a new R22 refrigerant because of the age of the existing.
2. We don't know the existing volume but the contractor to verify on site.

**Refer to question number 2: regarding the compressor part number.**

**Refer to drawing M00-00 (Drawing list& Mechanical Schedules& Schematics):**

- .1 Revise Compressor Schedule, manufacturer and model/series to Copeland/ZB58KC-TF5.

END OF ADDENDUM No. MADD02

---