

Feb 2, 2017

SASKATOON RESEARCH AND DEVELOPMENT CENTRE
CONTRACT NO. 35 – GENERATOR INSTALLATION
CONTRACT #465-1-28-C35

Addendum #1

Q1 - What is the voltage of the generator?

A1 - New Generator - Voltage-347/600, 3 Phases, Wye, 4 Wires

Q2 – When will the drawings be available?

A2 - No additional drawings will be provided. The installation of the new Genset is straightforward and the site visit should address all questions.

Colby Collinge
Materiel Manager AAFC
Regina, Saskatchewan

2 février 2017

CENTRE DE RECHERCHE ET DÉVELOPPEMENT DE SASKATOON
CONTRAT N° 35 – INSTALLATION DE GÉNÉRATRICE
CONTRAT #465-1-28-C35

Addenda No 1

Q1 – Quelle est la tension de la nouvelle génératrice?

R1 – Nouvelle génératrice –347/600 volts, 3 phases, Wye, 4 fils.

Q2 – Quand seront les nouveaux dessins disponibles?

R2 – L'installation de la nouvelle génératrice est routinière et ne nécessite aucuns nouveaux dessins.
Toutes autres informations requises seront traitées lors de la visite des lieux.

Colby Collinge
Gestionnaire du matériel, AAC
Regina (Saskatchewan)

