



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> AAFC Facility System Renovation	
<b>Solicitation No. - N° de l'invitation</b> EP922-172162/B	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> AAFC EP922-172162	<b>Date</b> 2017-02-08
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-066-10951	
<b>File No. - N° de dossier</b> PWU-6-39263 (066)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-13</b>	<b>Time Zone</b> Fuseau horaire Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Lee, Mony	<b>Buyer Id - Id de l'acheteur</b> pwu066
<b>Telephone No. - N° de téléphone</b> (780) 224-6675 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

The Bidding Documents are amended as noted in this Addendum, which consists of one (1) page and the following attachments:

1. Q&A
2. Added Specifications: None added.
3. Drawings: None added.

This addendum is issued prior to bid closing to amend the bid documents. This Addendum will form part of the Contract Documents. Include in the Bid price all such revisions which will become part of the Work. Perform all such Work in accordance with the contract documents.

Acknowledge receipt of this Addendum by reference in the Bid Form submitted by the bidding Contractors. Ensure that all parties submitting bids are aware of all items included in this addendum.

**1. Q&A**

<b>1</b>	<b>Q</b>	As per included spec section 23 01 31 1.3.1.2, please clarify whether or not the whole facility is to be covered in this scope. Also, please confirm that new ductwork servicing only the mechanical room is to meet the requirements found within section 23 01 31.
	<b>A</b>	Cleaning plan and video survey will not be required. The new ductwork installed in the mechanical room does not need to meet the requirements of Section 23 01 31.

**END OF ADDENDUM #03**