



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fire Panel and Fire Suppression Ref	
Solicitation No. - N° de l'invitation F1700-164450/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client F1700-164450	Date 2017-02-10
GETS Reference No. - N° de référence de SEAG PW-\$PWY-033-7980	
File No. - N° de dossier PWY-6-39321 (033)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-23	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Siopongco, Philip PWY	Buyer Id - Id de l'acheteur pwy033
Telephone No. - N° de téléphone (604) 351-6139 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Fire Panel and Fire Suppression Refurbishment – Seal Cove Base - Prince Rupert, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

N° de l'invitation - Solicitation No.
F1700-164450/A
N° de réf. du client - Client Ref. No.
F1571-164450

N° de la modif. - Amd. No
003
N° du dossier - File No.
PWY-6-39321

Id de l'acheteur Buyer ID
PWY033
FMS No./N°VME - CCC No./N° CCC

Les documents français seront disponibles sur demande.

This Solicitation Amendment 003 is raised:

A. Incorporate Addendum # 2, responses to questions received to date into the solicitation document

Reminder:

Previously issued Bid and Acceptance Form was replaced with **Bid and Acceptance Form – Revised 02-08-2017 (see Amendment 002).**

The revised **Bid and Acceptance Form – Revised 02-08-2017** must be used when submitting your bid. Any bid submitted on a previous version of the Bid and Acceptance Form will be considered non-compliant and therefore disqualified.

A. See Addendum # 2 (attached)

All other conditions remain the same

ADDENDUM



Project:	Seal Cove Fire Alarm and Fire Suppression Refurbishment	Addendum No.:	2
Project No.:	131-12992-10	Date:	2017-February-10
Contract No.:			
Distribution:			

GENERAL

This Addendum forms part of the Contract Documents and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

Please see below tender clarifications based on bidder questions

1. The riser E300 has existing Mircom FA panels in the administration bldg. and workshop bldg. Some new sprinkler points will be required connected to the existing Mircom. a 'New Network Integration Panel' can be provided. is pricing from Mircom required for panel modifications and verification? (or can the panels be changed to Simplex)

Please refer to drawings E300 & E400. Contractor to provide all network hardware required to connect existing Mircom panels to the new system.

Section 36.10 on E400 states:

PROVIDE NETWORK INTEGRATION PANELS TO ALLOW CONNECTION OF EXISTING CONVENTIONAL MIRCOM PANELS IN THE ADMIN AND WORKSHOPS BUILDINGS TO THE SITE NETWORK. THE NETWORK INTEGRATION PANEL SHALL BE PROVIDED WITH A BATTERY BACKED POWER SUPPLY. CONTRACTOR TO PROVIDE SUITABLE BATTERIES AND WIRING / CIRCUITRY. THE NETWORK INTEGRATOR SHALL PROVIDE ISOLATED VOLTAGE MONITOR INPUTS AND DRY CONTACT RELAY OUTPUTS TO MONITOR SYSTEM STATUS OF THE EXISTING PANELS AND RELAY ALL ALARMS AND TROUBLE SIGNALS TO THE FIRE ALARM NETWORK. THE STATUS OF EACH DETECTION / FIRE SUPPRESSION ZONE SHALL BE RELAYED TO THE NETWORK. A COMMON TROUBLE / SUPERVISORY FROM EACH BUILDING SHALL BE RELAYED TO THE NETWORK.

2. The drawings show speakers. The spec has no mention of speakers. Are the symbols indicating speakers actually horns?

Provide addressable horn / sounder as spec. Where combined with a strobe these should be combination units

3. If there are speakers and not horns, where are the paging facilities to be located?

No paging facility required

ADDENDUM



4. The spec 38.15 & .16 indicate individual addressed sounders and strobes. This is workable. Are the sounders horns or speakers?

Horns

5. The spec 38.17 calls for 'Touch Screen LCD Site Graphic Annunciators'. Is this a multi-line (8) display?

As included the specifications provide touch screen annunciator. Annunciator to have sufficient lines to display two simultaneous alerts / alarms

End of Addendum