



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions Travaux**  
**publics et Services gouvernementaux Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Fire Panel and Fire Suppression Ref	
<b>Solicitation No. - N° de l'invitation</b> F1700-164450/A	<b>Amendment No. - N° modif.</b> 003
<b>Client Reference No. - N° de référence du client</b> F1700-164450	<b>Date</b> 2017-02-10
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-033-7980	
<b>File No. - N° de dossier</b> PWY-6-39321 (033)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-02-23</b>	
<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Standard Time PST	
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Siopongco, Philip PWY	<b>Buyer Id - Id de l'acheteur</b> pwy033
<b>Telephone No. - N° de téléphone</b> (604) 351-6139 ( )	<b>FAX No. - N° de FAX</b> ( ) -
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Fire Panel and Fire Suppression Refurbishment – Seal Cove Base - Prince Rupert, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
F1700-164450/A  
Client Ref. No. - N° de réf. du client  
F1700-164450

Amd. No. - N° de la modif.  
003  
File No. - N° du dossier  
PWY-6-39321

Buyer ID - Id de l'acheteur  
PWY033  
CCC No./N° CCC - FMS No./N°VME

---

This Solicitation Amendment 003 is raised:

A. Incorporate Addendum # 2, responses to questions received to date into the solicitation document

**Reminder:**

Previously issued Bid and Acceptance Form was replaced with **Bid and Acceptance Form – Revised 02-08-2017 (see Amendment 002)**.

The revised **Bid and Acceptance Form – Revised 02-08-2017** must be used when submitting your bid. Any bid submitted on a previous version of the Bid and Acceptance Form will be considered non-compliant and therefore disqualified.

A. See Addendum # 2 (attached)

**All other conditions remain the same**

## ADDENDUM



<b>Project:</b>	Seal Cove Fire Alarm and Fire Suppression Refurbishment	<b>Addendum No.:</b>	2
<b>Project No.:</b>	131-12992-10	<b>Date:</b>	2017-February-10
<b>Contract No.:</b>			
<b>Distribution:</b>			

### GENERAL

*This Addendum forms part of the Contract Documents and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.*

Please see below tender clarifications based on bidder questions

1. The riser E300 has existing Mircom FA panels in the administration bldg. and workshop bldg. Some new sprinkler points will be required connected to the existing Mircom. a 'New Network Integration Panel' can be provided. is pricing from Mircom required for panel modifications and verification? (or can the panels be changed to Simplex)

*Please refer to drawings E300 & E400. Contractor to provide all network hardware required to connect existing Mircom panels to the new system.*

*Section 36.10 on E400 states:*

*PROVIDE NETWORK INTEGRATION PANELS TO ALLOW CONNECTION OF EXISTING CONVENTIONAL MIRCOM PANELS IN THE ADMIN AND WORKSHOPS BUILDINGS TO THE SITE NETWORK. THE NETWORK INTEGRATION PANEL SHALL BE PROVIDED WITH A BATTERY BACKED POWER SUPPLY. CONTRACTOR TO PROVIDE SUITABLE BATTERIES AND WIRING / CIRCUITRY. THE NETWORK INTEGRATOR SHALL PROVIDE ISOLATED VOLTAGE MONITOR INPUTS AND DRY CONTACT RELAY OUTPUTS TO MONITOR SYSTEM STATUS OF THE EXISTING PANELS AND RELAY ALL ALARMS AND TROUBLE SIGNALS TO THE FIRE ALARM NETWORK. THE STATUS OF EACH DETECTION / FIRE SUPPRESSION ZONE SHALL BE RELAYED TO THE NETWORK. A COMMON TROUBLE / SUPERVISORY FROM EACH BUILDING SHALL BE RELAYED TO THE NETWORK.*

2. The drawings show speakers. The spec has no mention of speakers. Are the symbols indicating speakers actually horns?

*Provide addressable horn / sounder as spec. Where combined with a strobe these should be combination units*

3. If there are speakers and not horns, where are the paging facilities to be located?

*No paging facility required*

## ADDENDUM



4. The spec 38.15 & .16 indicate individual addressed sounders and strobes. This is workable. Are the sounders horns or speakers?

*Horns*

5. The spec 38.17 calls for 'Touch Screen LCD Site Graphic Annunciators'. Is this a multi-line (8) display?

*As included the specifications provide touch screen annunciator. Annunciator to have sufficient lines to display two simultaneous alerts / alarms*

End of Addendum