
























LIGHTING


-  1'x4' (305x1219mm) SURFACE OR SUSPENDED FLUORESCENT FIXTURE
-  2'x8' (53x2400mm) PENDANT MOUNT LED DIRECT, 1% DIMMING DRIVER, SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  2'x7' (53x2100mm) PENDANT MOUNT LED DIRECT, 1% DIMMING DRIVER, SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  2'x7' (53x2100mm) PENDANT MOUNT LED DIRECT, 10% DIMMING DRIVER, SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  WALL MOUNTED LUMINAIRE, SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  RECESSED LED POTLIGHT, SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  EXISTING 610mm ROUND PENDANT MOUNT FLUORESCENT LUMINAIRE
-  EXISTING 1219mm LINEAR PENDANT MOUNT FLUORESCENT LUMINAIRE
-  INDICATES LIGHTING CONTROL ZONE #
INDICATES CIRCUIT #
INDICATES PANEL #
-  1220 WALL MTD NIGHT LIGHT FIXTURES ON EMERGENCY POWER. SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  305x1220 SURFACED MTD NIGHT LIGHT FIXTURES ON EMERGENCY POWER SEE LUMINAIRE SCHEDULE FOR DESCRIPTION
-  305x1220 RECESSED NIGHT LIGHT FIXTURES ON EMERGENCY POWER. SEE LUMINAIRE SCHEDULE FOR DESCRIPTION


LIFE SAFETY SYSTEM

-  LED EXIT LIGHT CEILING MOUNTED
-  LED EXIT LIGHT RECESSED MOUNTED
-  EMERGENCY BATTERY UNIT - DOUBLE HEAD
-  EMERGENCY BATTERY REMOTE - DOUBLE HEAD






SWITCHING

-  SWITCH - SINGLE POLE
-  SWITCH - DIMMER
-  SWITCH - LOW VOLTAGE
-  SWITCH - VACANCY SENSOR
-  SWITCH - OCCUPANCY SENSOR
-  SWITCH - HORSEPOWER RATED TOGGLE
-  OCCUPANCY SENSOR







-  CCI-1-11
INDICATES INPUT #
INPUT
INDICATES THE UNIT #
CONTACT CLOSURE INTERFACE

-  CCI-1-01
INDICATES OUTPUT #
OUTPUT
INDICATES THE UNIT #
CONTACT CLOSURE INTERFACE



POWER DEVICES

-  RECEPTACLE - DUPLEX
-  RECEPTACLE - DUPLEX / USB
-  PANEL AS NOTED SURFACE MOUNTED
-  PANEL AS NOTED RECESSED IN WALL
-  DIRECT CONNECTION






ACCESS FLOOR SYSTEMS

-  PDB-2-1
UNDERFLOOR NORMAL POWER DISTRIBUTION BOX
-  INDICATES BOX #
INDICATES FLOOR #
-  EPDB-2-1
UNDERFLOOR EMERGENCY POWER DISTRIBUTION BOX
-  INDICATES BOX #
INDICATES FLOOR #
-  FB-1-1
RECESSED POWER/DATA/TEL WORKSTATION SERVICE BOX
-  INDICATES BOX #
INDICATES FLOOR #





MECHANICAL

-  MAGNETIC MOTOR STARTER
-  MOTOR AS NOTED



WIRING/CABLING

-  JUNCTION/PULLBOX - FLUSH MOUNTED IN FINISHED AREAS OR WHERE INDICATED
-  WIRING IN CEILING OR WALLS
3 #12 IN 16mm EMT C. UNLESS NOTED OTHERWISE
-  WIRING IN CEILING SPACE FROM JUNCTION BOX
TO FIXTURE, 3C #12 AC90 OR AS INDICATED
-  WIRING IN/UNDER FLOOR
-  HOME RUN TO DESIGNATED SERVICE




SECURITY SYSTEM

-  DOOR CONTACT (RECESSED TYPE)
SUPPLIED BY DIV.8, WIRED BY DIV.16
-  ELECTRIC STRIKE
SUPPLIED BY DIV.8, WIRED BY DIV.16
-  EXIT DEVICE
(MOTION SENSOR TYPE)
-  ELECTRIC DOOR CARD
READER








ELECTRICAL FIRE PROTECTION

-  SPEAKER RECESSED IN CEILING (SPEAKER CCT A)
-  SPEAKER RECESSED IN CEILING (SPEAKER CCT B)

TELECOMMUNICATIONS & DATA SYSTEMS

-  STANDARD DATA/VOICE COMBO WALL OUTLET
C/W WALL MODULAR JACK INSERT PLATES,
TERMINATION HARDWARE, TWO HORIZONTAL DATA
AND ONE HORIZONTAL VOICE CABLES AND
LABELLING.
-  COMMUNICATION DISTRIBUTION BOX - CDB
-  INDICATES BOX #
INDICATES FLOOR #

MISCELLANEOUS

-  ABOVE FINISHED FLOOR
-  COMPLETE WITH
-  CONDUIT
-  ROOM NUMBER
-  EXISTING FIXTURE / DEVICE TO REMAIN
-  EXISTING FIXTURE / DEVICE TO BE RELOCATED
-  EXISTING FIXTURE / DEVICE TO BE REMOVED

 Public Works and
Government Services
Canada

Travaux Publics et
Services gouvernementaux
Canada

63 Fitzroy St.
P.O. Box 1719
Charlottetown, PE
Canada C1A 7N4
Ph: 902-566-4449
Fax: 902-566-1235
architects@bghj.com
Web: www.bghj.com


**BERGMARK
GUIMOND
HAMMARLUND
JONES
ARCHITECTS**

RICHARDSON ASSOCIATES
(1993) Limited
Engineering Consultants



Telephone 902 568 4044
Facsimile 902 568 4059
E-mail bsear@ral93.com

P.O. Box 1057
565 North River Road, Suite 1
Charlottetown, Prince Edward Island
Canada C1A 7N4




3	ISSUED FOR TENDER	JAN 30 2017
2	99% DRAWINGS	MAR 27 2015
1	66% DRAWINGS	MAR 06 2015
revisions		date

project projet

**DESIGNATED SUPPORT
SPACE - FIRST FLOOR
JEAN CANFIELD G.O.C.B.
CHARLOTTETOWN
QUEENS CO., PEI**

drawing dessin

SYMBOL LEGEND

designed	RAL93	conçu
date	2017-01-30	
drawn	JH	dessiné
date	2017-01-30	
approved	RLS	approuvé
date	2017-01-30	
Tender		Soumission
PWGSC Project Manager	Administrateur de projets TPSGC	
project number	no. du projet	
	R.086261.003	
drawing no.	no. du dessin	
	E5 of E5	