



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave. Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6  
Bid Fax: (780) 497-3510

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address**  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada  
ATB Place North Tower  
10025 Jasper Ave./10025 ave Jasper  
5th floor/5e étage  
Edmonton  
Alberta  
T5J 1S6

<b>Title - Sujet</b> Greenstone Building Fit-Up	
<b>Solicitation No. - N° de l'invitation</b> EW038-172580/A	<b>Amendment No. - N° modif.</b> 002
<b>Client Reference No. - N° de référence du client</b> PWGSC EW038-172580	<b>Date</b> 2017-02-13
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWU-107-10995	
<b>File No. - N° de dossier</b> PWU-6-39304 (107)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-02-21</b>	<b>Time Zone</b> Fuseau horaire Mountain Standard Time MST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Anthony, Mary	<b>Buyer Id - Id de l'acheteur</b> pwu107
<b>Telephone No. - N° de téléphone</b> (780) 237-7582 ( )	<b>FAX No. - N° de FAX</b> (780) 497-3510
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> Raison sociale et adresse du fournisseur/de l'entrepreneur	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

<b>1.0</b>	<b>GENERAL</b>	<b>NOT USED</b>
<b>2.0</b>	<b>ARCHITECTURAL</b>	
.1	Subject:	Specifications
	Refer:	Contract Documents
	Instructions:	General Building conditions;
		.1 No parking is allowed on site for construction.
		.2 Washrooms may be used during construction. Washrooms to be kept clean.
		.3 Materials delivery; the rear loading bay may be used to stage material delivery. The elevator may be used to transport materials. Pads must be used for the elevator. Pads are available from building maintainer. Delivery to take place after hours or on weekends.
		.4 Noise; noisy activities to be scheduled after hours or on weekends.
		.5 Power and water to be made available at no charge during construction
		.6 Work after hours; a commissioner is required for after hours work. Provide 24 hours notice for request. There is no charge for the commissioner.
		.7 Building work security; Reliability status is required for all workers. The procurement officer will assist in processing the form.
		.8 All furniture and Owner's materials will be removed prior to Contractor's mobilization.
<b>3.0</b>	<b>STRUCTURAL</b>	<b>NOT USED</b>
<b>3.0</b>	<b>MECHANICAL</b>	<b>NOT USED</b>
<b>4.0</b>	<b>ELECTRICAL</b>	
.1	Subject:	Specifications
	Refer:	Contract Documents
	Instructions:	Refer to electrical Addendum E-01.

**END OF ADDENDUM No. 01**

## Electrical Addendum E-01

Project Name: PWGSC 3 <sup>rd</sup> Floor Renovation Greenstone Building	
Client: PSAV Architects Ltd.	
Project No.: 35004.00	Date: February 13, 2017
Distribution:	
Gene Drouin	PSAV Architects Ltd gene@psav.ca

This addendum forms part of the Contract Documents and is to be read, interpreted, and coordinated with all other parts. The cost of all work contained herein is to be included in the Contract Sum. The specifications and drawings are complementary. Items listed under the specification in this addendum and having influence on the drawings are so deemed to alter the drawings. Items listed under the drawings in this addendum and having influence on the specification are so deemed to alter the specification.


### 1. Revisions to Drawings

#### 1.1 Drawing E04

- .1 All new exit lights and all existing exit lights are to be replaced with new LED running man type exit signs. Exit signs to be equal to Aimlite RPST-U-M-WHT-BAT with arrows and faces and mounting as indicated on drawings.

Prepared by,

Williams Engineering Canada Inc.



**BEN RAJEWSKI P. Eng., LC**

**Electrical**

T 780.409.3147 F 867.873.2547

E brajewski@williamsengineering.com

/

End of Electrical Addendum No. E-01

X:\02-Yellowknife\Projects\0035004.00\50\_Tender\02\_Addenda\0035004\_Elec Addendum E-01.docx