



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Greenstone Building Fit-Up	
Solicitation No. - N° de l'invitation EW038-172580/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client PWGSC EW038-172580	Date 2017-02-13
GETS Reference No. - N° de référence de SEAG PW-\$PWU-107-10995	
File No. - N° de dossier PWU-6-39304 (107)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-21	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Anthony, Mary	Buyer Id - Id de l'acheteur pwu107
Telephone No. - N° de téléphone (780) 237-7582 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

1.0	GENERAL	NOT USED
2.0	ARCHITECTURAL	
.1	Subject:	Specifications
	Refer:	Contract Documents
	Instructions:	General Building conditions;
		.1 No parking is allowed on site for construction.
		.2 Washrooms may be used during construction. Washrooms to be kept clean.
		.3 Materials delivery; the rear loading bay may be used to stage material delivery. The elevator may be used to transport materials. Pads must be used for the elevator. Pads are available from building maintainer. Delivery to take place after hours or on weekends.
		.4 Noise; noisy activities to be scheduled after hours or on weekends.
		.5 Power and water to be made available at no charge during construction
		.6 Work after hours; a commissioner is required for after hours work. Provide 24 hours notice for request. There is no charge for the commissioner.
		.7 Building work security; Reliability status is required for all workers. The procurement officer will assist in processing the form.
		.8 All furniture and Owner's materials will be removed prior to Contractor's mobilization.
3.0	STRUCTURAL	NOT USED
3.0	MECHANICAL	NOT USED
4.0	ELECTRICAL	
.1	Subject:	Specifications
	Refer:	Contract Documents
	Instructions:	Refer to electrical Addendum E-01.

END OF ADDENDUM No. 01

Electrical Addendum E-01

Project Name: PWGSC 3 rd Floor Renovation Greenstone Building		
Client: PSAV Architects Ltd.		
Project No.: 35004.00		Date: February 13, 2017
Distribution:		
Gene Drouin	PSAV Architects Ltd	gene@psav.ca

This addendum forms part of the Contract Documents and is to be read, interpreted, and coordinated with all other parts. The cost of all work contained herein is to be included in the Contract Sum. The specifications and drawings are complementary. Items listed under the specification in this addendum and having influence on the drawings are so deemed to alter the drawings. Items listed under the drawings in this addendum and having influence on the specification are so deemed to alter the specification.


1. Revisions to Drawings

1.1 Drawing E04

- .1 All new exit lights and all existing exit lights are to be replaced with new LED running man type exit signs. Exit signs to be equal to Aimlite RPST-U-M-WHT-BAT with arrows and faces and mounting as indicated on drawings.

Prepared by,

Williams Engineering Canada Inc.



BEN RAJEWSKI P. Eng., LC

Electrical

T 780.409.3147 F 867.873.2547

E brajewski@williamsengineering.com

/

End of Electrical Addendum No. E-01

X:\02-Yellowknife\Projects\0035004.00\50_Tender\02_Addenda\0035004_Elec Addendum E-01.docx