


**ADDENDUM PAGEAU MOREL NO. 2**

Mechanical

**1 GENERAL**

- 1.1 This addendum is part of and shall be read jointly with the tender documents. In the case of contradiction, this document has precedence.

**2 SCOPE**

- 2.1 Informations and clarifications to the documents.

**3 ELECTROMECHANICAL DESCRIPTION**

- 3.1 Specification – Section 25 01 11

- 3.1.1 Article 2.2 is added as follows:

**2.2 MANUFACTURERS**

- .1 *Use regulation system components of the same type of the existing to ensure compatibility. Those components include numerical regulators, command/regulation devices (faucets and actuators) and transmitters.*
- .2 *All devices from a particular category must be of the same type and must come from the same manufacturer.*
- .3 *Provided products shall have been on the market for at least three (3) years.*
- .4 *Acceptable products for the components other than the numerical control system:*
  - .1 *Honeywell.*
  - .5 *Acceptable products for the numerical control system:*
    - .1 *VCI Controls – Envision.*
    - .6 *Acceptable installation: Supplier/Manufacturer of components.*

- 3.2 MECHANICAL Drawings

- 3.2.1 No revision of the drawings.

## **ADDENDUM PAGEAU MOREL NO. 2**

- 3.3 ELECTRICAL Drawings
- 3.3.1 No revision of the drawings.