



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works & Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax,(N.E.)
B3J 1T3
Halifax
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Atlantic Region Acquisitions/Région de l'Atlantique
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.E.)
B3J 3C9
Halifax
Nova Scot

Title - Sujet CCGC Pool Renovations	
Solicitation No. - N° de l'invitation EB144-172646/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client EB144-17-2646	Date 2017-02-17
GETS Reference No. - N° de référence de SEAG PW-\$PWA-310-5519	
File No. - N° de dossier PWA-6-76136 (310)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-21	Time Zone Fuseau horaire Atlantic Standard Time AST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Stevenson, Jacquelyn	Buyer Id - Id de l'acheteur pwa310
Telephone No. - N° de téléphone (902) 403-3520 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

de l'invitation - Sollicitation No.
W7707-172646/A
N° de réf. du client - Client Ref. No.
W7707-172646

N° de la modif - Amd. No.
004
File No. - N° du dossier
PWA-6-76136

Id de l'acheteur - Buyer ID
PWA 310
N° CCC / CCC No./ N° VME - FMS

AMENDMENT 004

Amendment 004 is being raised to address the following:

Q: Section 01 11 00, Item # 5:

Can we get a mechanical layout of the piping / check valves for the pool regarding filling the pool? Also, the wording may be incorrect. It asks to fill the pool, check leaks, drain, then waterproof. Item # 2.2 is the opposite of Item # 1.5. Item # 1.5 would require another filling. Please provide additional information or clarify.

A: Please refer to **Division 01 11 00, Work Sequence; Section 1.04.** This section outlines the minimum stages required. The pool is to be filled after epoxy injection, drained, waterproofing is to be then applied, filled for the second time, drained, install tile and filled for the third time. These are the minimum stages required, if pool does not pass a leak test at any stage, additional fills will be required.

Drawings of existing piping will be made available to the successful bidder. Water supply is available onsite.