



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Fire Panel and Fire Suppression Ref	
Solicitation No. - N° de l'invitation F1700-164450/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F1700-164450	Date 2017-02-17
GETS Reference No. - N° de référence de SEAG PW-\$PWY-033-7980	
File No. - N° de dossier PWY-6-39321 (033)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-23	
Time Zone Fuseau horaire Pacific Standard Time PST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Siopongco, Philip PWY	Buyer Id - Id de l'acheteur pwy033
Telephone No. - N° de téléphone (604) 351-6139 ()	FAX No. - N° de FAX () -
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Fire Panel and Fire Suppression Refurbishment – Seal Cove Base - Prince Rupert, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation
F1700-164450/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
PWY033

Client Ref. No. - N° de réf. du client
F1700-164450

File No. - N° du dossier
PWY-6-39321

CCC No./N° CCC - FMS No./N° VME

Les documents français seront disponibles sur demande.

This Amendment #004 is raised to post the site visit attendee list and to issue addendum #3.

Site Visit Attendees

Houle Electric
Apple Electric Ltd.
Acadia Mechanical
Pacific Northwest Electric & Controls
Western Canada Fire Protection

See attached addendum #3.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.

ADDENDUM



Project:	Seal Cove Fire Alarm and Fire Suppression Refurbishment	Addendum No.:	3
Project No.:	131-12992-10	Date:	2017-February-17
Contract No.:			
Distribution:			

GENERAL

This Addendum forms part of the Contract Documents and amends the original drawings and Specifications. The following revisions supersede the information contained in the original drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

Drawing E203

1. Add a keyswitch adjacent the aspirator detection system. Key switch to be used to prevent false alarm during relocation of helicopters to and from the hangar. Upon activation of the keyswitch, any alarms originating from the aspirating detection system will not result in a building wide fire alarm annunciation. Operation of the switch will result in a trouble signal on the fire alarm panel.
2. Provide three weatherproof audible / visible notification devices on the south wall of the helicopter hangar building above the sliding doors. Horn to produce min 99dBA at 3m. Strobe to be minimum 185cd.

Drawing E201

3. Replace three smoke detectors shown in the office, oil storage and paint storage areas of the flammable storage building (zone 6) with combination fixed temperature and rate of rise heat detectors

End of Addendum