

ADDENDUM

PROJECT: Government of Canada Multi-Purpose Training Facility Mechanical Renovation Regina, Saskatchewan	ADDENDUM NUMBER: M-4
PROJECT NO : 05.004.F	DATE : February 17th, 2017

The following amendments to the tender documents shall be incorporated in, and form part of, the tender documents the same as if these had been written into the original tender documents.

REFER TO SPECIFICATIONS

1. Refer to Section 25 09 70 "SEQUENCE OF OPERATIONS".
 - a. Delete line 4.7.4.11: "Pump P-1 Speed AI from VFD"

REFER TO DRAWINGS

2. Refer to Equipment Schedule on Drawing M-0
 - a. Item AS-1 shall read: air separator Taco model "4904A". Pressure drop shall be less than 1.4 kPa (0.2 psi). 50mm (2") connection size. Dimensions 292 mm D X 355mm H (11.5" x 14"). Weight 13 kg (30 lbs).

-- END OF ADDENDUM --