

Your consideration for Equals on the above-mentioned project would be appreciated on the following:

<u>Spec.</u>	<u>Proposed Equal</u>
<b>HX-1, HX-2: Heat exchangers</b> Bell & Gossett	A.I.C. heat exchangers
Approved	YES - <del>NO</del> - ALTERNATE

<u>Spec.</u>	<u>Proposed Equal</u>
<b>ET-1: Expansion Tank</b> Bell & Gossett	Amtrol
Approved	<del>YES</del> - NO - ALTERNATE

<u>Spec.</u>	<u>Proposed Equal</u>
<b>UH-9: Horizontal Unit Heater</b> Modine	Reznor
Approved	<del>YES</del> - NO - ALTERNATE
	<u>Proposed Equal</u>
	Beacon Morris
Approved	YES - <del>NO</del> - ALTERNATE

<u>Spec.</u>	<u>Proposed Equal</u>
<b>Triple Duty Valves &amp; Suction Diffusers</b>	Grundfos
Approved	<del>YES</del> - NO - ALTERNATE