



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
Pacific Region  
401 - 1230 Government Street  
Victoria, B.C.  
V8W 3X4  
Bid Fax: (250) 363-3344

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
401 - 1230 Government Street  
Victoria, B. C.  
V8W 3X4

|   |  |
|---|--|
| <b>Title - Sujet</b><br>CCGS Gordon Reid - Generator  |  |
| <b>Solicitation No. - N° de l'invitation</b><br>F1782-16C723/A  | <b>Amendment No. - N° modif.</b><br>004      |
| <b>Client Reference No. - N° de référence du client</b><br>F1782-16C723   | <b>Date</b><br>2017-02-21                    |
| <b>GETS Reference No. - N° de référence de SEAG</b><br>PW-\$XLV-176-7164  |  |
| <b>File No. - N° de dossier</b><br>XLV-6-39063 (176)  | <b>CCC No./N° CCC - FMS No./N° VME</b>       |
| <b>Solicitation Closes - L'invitation prend fin</b><br><b>at - à 02:00 PM</b><br><b>on - le 2017-02-23</b>  |  |
| <b>Time Zone</b><br>Fuseau horaire<br>Pacific Standard Time<br>PST  |  |
| <b>F.O.B. - F.A.B.</b><br><b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/> |  |
| <b>Address Enquiries to: - Adresser toutes questions à:</b><br>Godin, Andre   | <b>Buyer Id - Id de l'acheteur</b><br>xlv176 |
| <b>Telephone No. - N° de téléphone</b><br>(250) 216-2504 ( )  | <b>FAX No. - N° de FAX</b><br>( ) -          |
| <b>Destination - of Goods, Services, and Construction:</b><br><b>Destination - des biens, services et construction:</b>   |  |

**Instructions: See Herein**

**Instructions: Voir aux présentes**

|  |  |
|--|--|
| <b>Delivery Required - Livraison exigée</b>  | <b>Delivery Offered - Livraison proposée</b> |
| <b>Vendor/Firm Name and Address</b><br><b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>   |  |
| <b>Telephone No. - N° de téléphone</b><br><b>Facsimile No. - N° de télécopieur</b>   |  |
| <b>Name and title of person authorized to sign on behalf of Vendor/Firm</b><br><b>(type or print)</b><br><b>Nom et titre de la personne autorisée à signer au nom du fournisseur/<br/>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b> |  |
| <b>Signature</b>   | <b>Date</b>                                  |

Solicitation amendment No: 4 is to promulgate

1) Bidder questions and Canada responses.

| Questions Number | Bidder Questions   | Canada Response   |
|------------------|--|---|
| 1                | Is a direct air cooled engine such as Deutz or similar acceptable instead of a radiator?   | No, the engine must be provided as specified, please refer to the specification for exact details and requirements. |
| 2                | Is it possible to extend the RFP closing date to by one week?  | Solicitation closing date is extended from February 16, 2017 to February 23, 2017.                                  |
| 3                | <p>We do not want a "resetting warranty". The warranty is one year (unlimited hours) from commissioning. We request that all of crossed out part below from 2010A 09 (2014-09-25) be removed:</p> <ol style="list-style-type: none"> <li>1. Despite inspection and acceptance of the Work by or on behalf of Canada and without restricting any provisions of the Contract or any condition, warranty or provision imposed by law, the Contractor, if requested by Canada to do so, must replace, repair or correct, at its own option and expense any work that becomes defective or fails to conform to the requirements of the Contract, where applicable. The warranty period will be 12 months after delivery and acceptance of the Work or the length of the Contractor's or manufacturer's standard warranty period, whichever is longer.</li> <li>2. Canada must pay the transportation cost associated with returning the Work or any part of the Work to the Contractor's plant for replacement, repair or making good, and the Contractor must pay the transportation cost associated with forwarding the replacement or returning the Work or part of the Work when rectified to the delivery point specified in the Contract or to another location as directed by Canada. If, in the opinion of Canada, it is not expedient to remove the Work from its location, the Contractor must carry out any necessary repair or making good of the Work at that location and will be reimbursed its reasonable travel and living expenses.</li> <li><del>3. The warranty period is automatically extended by the duration of any period or periods where the Work is unavailable for use or cannot be used because of a</del></li> </ol> | Canada agrees to this change.   |

|   |   |   |
|---|---|---|
|   | <p><del>defect or non-conformance during the original warranty period. The warranty applies to any part of the Work replaced, repaired or corrected pursuant to subsection 1, for the greater of:</del></p> <p><del>a. the warranty period remaining, including the extension, or</del></p> <p><del>b. 90 days or such other period as may be specified for that purpose by agreement between the Parties.</del></p>  |   |
| 4 | <p>Requests that the part below be crossed out from 2010A 25 (2008-05-12) Right to set off.</p> <p>“Without restricting any right of set-off given by law, Canada may set-off against any amount payable to the Contractor under the Contract, any amount payable to Canada by the Contractor under the Contract <del>or under any other current contract.</del>”</p>   | <p>Solicitation and contract terms and conditions remain the same as published.</p>   |
| 5 | <p>Requests a cap on liability of the value of the contract.</p>  | <p>Solicitation and contract terms and conditions remain the same as published.</p>   |
| 6 | <p>In section 1.3 Critical Criteria it states the dimensions.</p> <p>1) My genset package with the duplex filters installed is too wide. Requirement is 863 mm. My genset is 942 mm.</p> <p>2) My filters and oil level gauge is on the left side not the right side of the package. I have attached the drawings. I just received a reply back from Caterpillar and they will not relocate the filters so it is something that we will have to do here.</p> <p>My questions are:</p> <ol style="list-style-type: none"> <li>1. Is 942 mm width acceptable?</li> <li>2. Are remote mounted filters acceptable?</li> </ol> | <p>1) Bidder to meet the specified width as per SOR article 1.3.A Available space maximum dimension width: .863 M. The bidder though is welcome to meet that dimension by disassembling the engine or components of the engine as long as it is done at the contractor's expense and it does not void the warranty.</p> <p>2) Oil Filter:<br/>       The oil filters can be remote mounted, but this will be at the contractor's expense.</p> |