



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
Cabot Place, Phase II, 2nd Floor
Box 4600
St. John's, NL
A1C 5T2
Bid Fax: (709) 772-4603

SOLICITATION AMENDMENT

MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
PWGSC / TPGSC - Nfld. Region
Cabot Place, Phase II, 2nd Floor
Box 4600
St. John's, NL
A1C 5T2

| | | |
|---|--|--|
| Title - Sujet Bldg. Material - Makkovik & Cartwri | | |
| Solicitation No. - N° de l'invitation F6879-167026/A | | Amendment No. - N° modif. 004 |
| Client Reference No. - N° de référence du client F6879-167026 | | Date 2017-02-22 |
| GETS Reference No. - N° de référence de SEAG PW-\$Xaq-025-6782 | | |
| File No. - N° de dossier Xaq-6-39200 (025) | CCC No./N° CCC - FMS No./N° VME | |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-02-28 | | Time Zone Fuseau horaire Newfoundland Standard Time NST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | | |
| Address Enquiries to: - Adresser toutes questions à: Hoskins, Nicole | | Buyer Id - Id de l'acheteur xaq025 |
| Telephone No. - N° de téléphone (709) 772-8192 () | | FAX No. - N° de FAX () - |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation
F6879-167026/A

Amd. No. - N° de la modif.
004

Buyer ID - Id de l'acheteur
xaq025

Client Ref. No. - N° de réf. du client
F6879-167026

File No. - N° du dossier
XAQ-6-39200

CCC No./N° CCC - FMS No./N° VME

SOLICITATION AMENDMENT 004

THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE AMENDMENT SHALL FORM A PART OF THE CONTRACT DOCUMENTS.

QUESTIONS AND ANSWERS:

Q1. For the metal siding and roof there are no fittings listed, screws, flashing's, or ridge cap. Should this be included in the bid?

A1. Don't include any fittings, screws, etc. Just the siding.

Q2. There is a Duchene 15 mil ultra plus vapor barrier listed that Duchene does not make. They have an ultra x that is used for beneath slab. Would this be ok to use?

A2: Ultra x would be fine for the vapour barrier.

Q3. Need further clarification on line 7, 1x4x10 pt strapping. Is this dressed to 1" thick? If so, it would be 5/4 x 4 x 10 pt is what the spec would call for. Just wondering as there is no 3/4" pt strapping.

A3. Should be 5/4.

Q4. Is the gate being placed in the middle of the fence line or will it be on its own and not intersect with the fence?

A4. Assume the gate is placed in the middle of the fence line.

Q5. Can you please provide info on the fencing portion of the quote? Looking for dimensions and corners required.

A5. The required 150 linear metre of chain link fence for the Cartwright site is designated for a "rectangular yard" with long dimension 47m and short dimension of 28m.

The required 132 linear metre of chain link fence for the Makkovik site is designated for a "rectangular yard" with long dimension 36m and short dimension of 30m.

Q6. On line 10 it calls us 1/2" G1S t&g plywood. Wondering if someone can confirm if this is correct? So far I have contacted a few building supply wholesalers and this product is not available.

A6. We can accept 1/2" G1S plywood.

By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all amendments and has included all costs of these requirements in the Total Bid Amount.

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED.
