



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS Á:

Parks Canada Agency Mailroom 30 Victoria Street Gatineau, Quebec, J8X 0B3

Amendment #2

INVITATION TO TENDER
APPEL D'OFFRES

Tender To: Parks Canada Agency

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

Soumission aux: l'Agence Parcs Canada

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente aux annexes cijointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency Mailroom 30 Victoria Street Gatineau, Quebec, J8X 0B3

| Title-Sujet | | Date |
|--|--------------------------------|----------------------------------|
| Deer Arm Brook Bridge Replacement | | 2 March , 2017 |
| Solicitation No No. de l'invitation Client 5P300-17-5064 | | Ref. No. – No. de réf du client. |
| GETS Reference No. – No de reference de SEAG | | |
| Solicitation Closes L'invitation prend fin – | Time Zone Fuseau horaire - | |
| at – à 02:00 PM on – le 2017-03-09 | Eastern Standard Time (EST) | |
| F.O.B F.A.B. Plant-Usine: □ Destination: ⊠ Other-Autre: □ | | |
| Address Inquiries to: - Adresser toute demande de renseignements à : | | |
| Patrick Sullivan at Patrick.Sullivan@pc.gc.ca | | |
| Telephone No No de téléphone | Fax N | Io. – No de FAX: |
| (819) 420-9557 | | |
| Destination of Goods, Services, and Construction: Destinations des biens, services et construction: | | |
| See Herein | | |
| | | |
| | | |
| Vendor/Firm Name and Address | | |
| Raison sociale et adresse du fournisseur/de l'entrepreneur | | |
| | | |
| | | |
| | | |
| Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur | | |
| | | |
| | | |
| Signature | | Date |







AMENDMENT #2

THE PURPOSE OF THIS AMENDMENT IS TO POST QUESTIONS AND ANSWERS AND TO ALSO PROVIDE ADDITIONAL AND REVISED DOCUMENTS

- **1. Q.** Can you advise whether the contractor will be able to use the Cod Knotts quarry for the production of rock fill and Class A and B aggregates?
 - **A**. Refer to the following amendment to the specification below:

Section 31 05 16

ADD:

"Production of rock fill, class A or class B aggregates may be extracted from the Cod Knotts Quarry located in Gros Morne National Park provided all material meets the project specifications. Any existing crushed rock located in the quarry at the beginning of the project must be replaced upon completion of project if used. (what's on the ground now, has to be on the ground when you leave). Upon removal of the detour structure, rock material may be disposed of in the Cod Knotts quarry as approved by Departmental Representative. No royalties or fees will be charged for use of the quarry. All work in the quarry will be in accordance with Appendix D - Cod Knotts Quarry - Rock Extraction Plan.

Co-operate with other Contractors using the quarry in carrying out their respective works and carry out instructions from Departmental Representative. Additional payments or schedule extensions due to work or scheduling conflicts with other Contractors in this quarry will not be considered.

Note: this guarry will not be used for asphalt granulars."

- 2. Q. Drawing #C01 "Existing Conditions and Removals Plan" mentions the extension of an existing 1500 mm CSP Culvert. Item # 29 in the unit price table calls for the extension material to be HDPE pipe. I am wondering how the connection is to be made? Or, would a CSP extension be allowable?
 - A. see attached Addendum.
- 3. Q: Section 01 35 43 1.13.3 of the specification says there are no borrow areas available in the Park. However, apparently there is a borrow area very near this worksite, probably 3-5 km and has likely been used for previous park projects. Will this borrow area be available for this project also?

A: The pit located in Rocky Barrichois will not be available for use.

ALL OTHER TERMS AND CONDITIONS OF THE ITT REMAIN UNCHANGED

