



1
-
DETAIL - CONTROL STATION
SCALE: N.T.S.




- NOTES:
- RELAY TO BE APPROVED FOR USE IN ELECTRICAL SAFETY CIRCUIT TO CSA Z-432 CLASS 3.
 - MANUAL RESET
 - POSITIVELY GUIDED CONTACT
 - PULSE TRAIN SIGNAL FOR MONITORING LOOP
 - POWER SUPPLY:
 - EFFICIENCY: > 88%
 - 10A, 24VDC OUTPUT, < 0.5 RIPPLE
 - 120V INPUT
 - PROVIDE CONTROL POWER FOR SIX (6) CONTROL DEVICE.
 - SURFACE RUN CABLE: USE NYLON FASTENERS EVERY 1.5m.
 - ONE CABLE FOR EACH DEVICE

2
-
SCHEMATIC
SCALE: N.T.S.




- NOTES:
- VALVES PROVIDED AND INSTALLED BY MECHANICAL.


3
-
SCHEMATIC - SIMPLIFIED FLOW DIAGRAM
SCALE: N.T.S.



4
-
SCHEMATIC - FVNR 3PH MOTOR STARTER
N.T.S.



KEY PLAN: N.T.S.



C02	2017/01/24	RE-ISSUED FOR TENDER	
C01	2016/10/14	ISSUED FOR TENDER	
NO.	DATE	REVISION	APPR.

SCALE / ÉCHELLE
SCALE AS SHOWN

LOCATION / EMPLACEMENT
BLDG. D200
CFB HALIFAX
NS

PROJECT / PROJET
HIGH PRESSURE AIR TEST FACILITY

TRADE / MÉTIER
ELECTRICAL

DATE
2016/05/02

SUBJECT / SUJET
SCHEMATICS AND DIAGRAMS

PRODUCTION	DESIGNED / ÉTUDIÉ	REVIEWED / REVU	ENG O / ING	DES O / AGENT CONC
M.A.T.				
DRAWN / DESSINÉ	CHECKED / VÉRIFIÉ	D.C.	COORDINATION	FIRE / INCENDIE

WBS NO. / NO. OTP
TI-15-003

PF NO. / NO. DP
R.077547.001

DWG. NO. / NO. DESSIN
4476681-502