



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave. Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6
Bid Fax: (780) 497-3510

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
ATB Place North Tower
10025 Jasper Ave./10025 ave Jasper
5th floor/5e étage
Edmonton
Alberta
T5J 1S6

Title - Sujet Sinclair Canyon Electrical Upgrade	
Solicitation No. - N° de l'invitation EP922-172961/A	Amendment No. - N° modif. 008
Client Reference No. - N° de référence du client Parks EP922-172961	Date 2017-03-07
GETS Reference No. - N° de référence de SEAG PW-\$PWU-183-11007	
File No. - N° de dossier PWU-6-39328 (183)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-03-16	Time Zone Fuseau horaire Mountain Standard Time MST
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Tikhonovitch (RPC), Alex	Buyer Id - Id de l'acheteur pwu183
Telephone No. - N° de téléphone (780) 901-7940 ()	FAX No. - N° de FAX (780) 497-3510
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Sinclair Canyon Electrical Upgrade and Site Rehabilitation, BC
The following outlines responses to requests for information:

19	Detail "A" on Drawing C 208, Rev 6, has a note referring to information being on E200 and E201, these drawings have not been provided. Please supply the missing information, (drawings).	Drawings are to be revised negating the inclusion of electrical reference. The JB and associated components will be removed from the set and new drawings will be posted shortly.	2017-Mar-06
20	With regard to the replacement of curbs adjacent to existing asphalt, currently the asphalt pavement is much higher than the lip of gutter, at what elevation should the gutter be placed, if you want the LOG to be match the edge of pavement, then the grade for the curb will have to be raised. If the intent is to have the asphalt and LOG match, then any sidewalk adjacent to the curb will also have to be raised, please advise.	Widen the section of road to be cut as per the specifications from 0.3m to 0.5m. Taper in the existing asphalt to tie to the new lip of gutter while not changing the existing lip of gutter grades.	2017-Mar-06
21	Is there a disposal site with in the Park for the asphalt, concrete, timber and misc. demolition debris?	The local landfill is the Columbia Valley Landfill. No disposal site exists within the park. The contractor shall complete waste management in accordance with spec.	2017-Mar-06
22	The plans call for the tangent wall to be drilled and poured in proximity to the existing metal bin. In order for this to take place, we indicted to you and the Parks Canada Rep, the drilling rig does not have the reach to drill from the road surface and thus a section of the road would need to be excavated to allow for a solid flat platform to drill the piles. We indicated that we would need the whole right (outside) lane excavated down approximately 1 meter (3+ feet to the top of the existing metal bin). We anticipated this conversation and approval in the minutes. Is this type of excavation allowed?	The distance from the curb is a maximum, the piles can be drilled closer to the curb if desired limiting the slope management and remediation requirements. Equivalent design can also be provided in advance of bid closing should the contractor perceive cost savings while maintaining the same performance requirements in accordance with bid requirements.	2017-Mar-06

Sinclair Canyon Electrical Upgrade and Site Rehabilitation, BC

23	Can we just get confirmation whether the galvanized pipe size for the handrails are metric or imperial. Details "A" and "F" on C208 are the handrails.	All Dimensions are in Metric	2017- Mar-07
----	---	------------------------------	-----------------