

PART 1 GENERAL

1.1 REFERENCES

- .1 ASTM International
 - .1 ASTM A126-15, Standard Specification for Gray Iron Castings for Valves, Flanges and Pipe Fittings.
 - .2 ASTM B 62-15, Standard Specification for Composition Bronze or Ounce Metal Castings.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
 - .1 Submit manufacturer's instructions, printed product literature and data sheets for plumbing products and include product characteristics, performance criteria, physical size, finish and limitations.
 - .2 Submit 2 copies of WHMIS MSDS in accordance with Section 01 35 29 - Health and Safety Requirements. Indicate VOC's:
- .3 Shop Drawings:
 - .1 Indicate on drawings to indicate materials, finishes, method of anchorage, number of anchors, dimensions construction and assembly details and accessories.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for plumbing specialties and accessories for incorporation into manual.
 - .1 Description of plumbing specialties and accessories, giving manufacturers name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.

1. DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
 - .1 Store materials off ground in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
 - .2 Store and protect plumbing materials from nicks, scratches, and blemishes.
 - .3 Replace defective or damaged materials with new.

PART 2 PRODUCTS

2.1 ROOF DRAINS

- .1 RD-1; Standard coated roof drain with cast iron body 381 mm diameter, with aluminum dome, under-deck clamp to suit roof construction, flashing clamp ring with integral gravel stop.
 - .1 Acceptable Product: Zurn Z-100-C, Jay R. Smith, MIFAB, Watts.

2.2 PLUMBING ROOF VENT (FLAT ROOF)

- .1 Telescoping cap design that weatherproofs the outside of the sleeve to the inside of the vent stack pipe.
- .2 Cap shall be fixed to the top of the vent pipe while the sleeve is free to "ride" up and down with the deflecting or moving roof deck.
- .3 Vent to extend minimum of 200 mm above finished roof surface.
- .4 Vent pipe should extend at least 20 mm higher than the sleeve to allow for the telescoping action.
- .5 Secure cap to inside top edge of vent pipe with plastic cement.
- .6 Roof: Flat two-ply modified bitumen.
- .7 Vent stack sleeve and cap shall be fabricated from stainless spun aluminum with caps selected to properly fit the type and size of pipe at each location.
- .8 Vent stack cover shall be factory-insulated with 13 mm thick closed cell neoprene foam rubber providing a minimum RSI value of 0.35. Insulation shall be water and mildew resistant.
- .9 Acceptable products: Lexsucu VSC-S, or approved equal.

PART 3 EXECUTION

3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for plumbing specialties and accessories installation in accordance with manufacturer's written instructions.
 - .1 Visually inspect substrate in presence of Departmental Representative.
 - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
 - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.3 INSTALLATION

- .1 Install in accordance with National Plumbing Code of Canada, provincial codes, and local authority having jurisdiction.
- .2 Install in accordance with manufacturer's instructions and as specified.

3.4 CLEANOUTS

- .1 Install cleanouts at base of soil and waste stacks, and rainwater leaders, at locations required code, and as indicated.
- .2 Bring cleanouts to wall or finished floor unless serviceable from below floor.
- .3 Building drain cleanout and stack base cleanouts: line size to maximum NPS 4.

3.5 PLUMBING VENT STACK COVERS

- .1 Plumbing vent stack covers to be supplied by Mechanical Contractor for installation by General Contractor.
- .2 Cutting of roof deck to allow installation of vent piping shall be the responsibility of the General Contractor.

- .3 Flashing of plumbing vent stack covers to the roof shall be the responsibility of the General Contractor.

3.6 TESTING AND ADJUSTING

- .1 Timing:
 - .1 After deficiencies rectified.
 - .2 After certificate of completion has been issued by authority having jurisdiction.
- .2 Roof drains:
 - .1 Check location at low points in roof.
 - .2 Check security, removability of dome.
 - .3 Adjust weirs to suit actual roof slopes, meet requirements of design.
 - .4 Clean out sumps.
 - .5 Verify provisions for movement of roof systems.

3.7 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 74 11 - Cleaning.
 - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 74 11 - Cleaning.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

3.8 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Repair damage to adjacent materials caused by plumbing specialties and accessories installation.

END OF SECTION