



**RETURN BIDS TO:**

**RETOURNER LES SOUMISSIONS À:**

**Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada**  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

**Comments - Commentaires**

Contracting Officer

Chris Huchzermeyer  
Tel: (604)365-2956  
Email: Chris.Huchzermeyer@pwgsc.gc.ca

**Vendor/Firm Name and Address**

**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**

Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Démolition du complexe d'habitation	
<b>Solicitation No. - N° de l'invitation</b> EZ899-171499/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-03-10
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-034-8006	
<b>File No. - N° de dossier</b> PWY-6-39349 (034)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-03-16</b>	<b>Time Zone</b> Fuseau horaire Pacific Standard Time PST
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Huchzermeyr, Chris(PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy034
<b>Telephone No. - N° de téléphone</b> (604) 365-2956 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> Parks Canada - Pacific Rim National Park - Vancouver Island, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation

EZ899-171499/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWY-6-39349

Buyer ID - Id de l'acheteur

Pwy034

CCC No./N° CCC - FMS No./N° VME

---

**Les documents français seront disponibles sur demande.**

\*\*\*\*\*

This Amendment 004 is raised to:

- 1) Incorporate Addendum 3

\*\*\*\*\*

- 1) Please see the attached Addendum 3 dated 10 March 2017

**All other terms and conditions remain unchanged.**

# ADDENDUM

---

Project: Parks Canada 8-plex Staff Housing Complex Demolition

Ucluelet, BC

Project No.: R.079939.001

Requisition No.: EZ899-171499/A

**Addendum No.: 003**

March 10, 2017

---

## **GENERAL**

This Addendum forms part of the Contract Documents for **Project No. R.079939.001** and amends the original Drawings and Specifications. The following revisions supersede the information contained in the original Drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

This Addendum consists of one (1) page. This Addendum is in response to questions from bidders.

1. The Hazardous Materials report on the lead does not have anything for the TCLP report that is required for disposal under MOE regulations. Is there a TCLP report being completed?

- Leachate testing has not been conducted, nor is any report forthcoming.
- Per the specifications:  
Section 026133 – Hazardous Materials Abatement  
3.6.4.1 - Lead-based paints and their matrices of application are considered hazardous materials and must be disposed of as hazardous waste.
- Should the Contractor choose to pursue alternate disposal options for various painted waste streams, the Contractor will be responsible to arrange and pay for lead leachate testing, if the disposal method or disposal facility requires such testing. Any such testing records must be provided to the Departmental Representative for approval, prior to disposal of waste.

2. Can the deadline be extended?

There is no current intention to extend the deadline.

End of Addendum