



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada**
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Contracting Officer

Chris Huchzermyer
Tel: (604)365-2956
Email: Chris.Huchzermyer@pwgsc.gc.ca

Vendor/Firm Name and Address

**Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution

Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

| | |
|--|--|
| Title - Sujet Demolition of Staff housing Complex | |
| Solicitation No. - N° de l'invitation EZ899-171499/A | Amendment No. - N° modif. 004 |
| Client Reference No. - N° de référence du client | Date 2017-03-10 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWY-034-8006 | |
| File No. - N° de dossier PWY-6-39349 (034) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-03-16 | Time Zone Fuseau horaire Pacific Standard Time PST |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Huchzermyr, Chris(PWY) | Buyer Id - Id de l'acheteur pwy034 |
| Telephone No. - N° de téléphone (604) 365-2956 () | FAX No. - N° de FAX (604) 775-6633 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Parks Canada - Pacific Rim National Park - Vancouver Island, BC | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation

EZ899-171499/A

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

004

File No. - N° du dossier

PWY-6-39349

Buyer ID - Id de l'acheteur

Pwy034

CCC No./N° CCC - FMS No./N° VME

This Amendment 004 is raised to:

- 1) Incorporate Addendum 3

- 1) Please see the attached Addendum 3 dated 10 March 2017

All other terms and conditions remain unchanged.

ADDENDUM

Project: Parks Canada 8-plex Staff Housing Complex Demolition

Ucluelet, BC

Project No.: R.079939.001

Requisition No.: EZ899-171499/A

Addendum No.: 003

March 10, 2017

GENERAL

This Addendum forms part of the Contract Documents for **Project No. R.079939.001** and amends the original Drawings and Specifications. The following revisions supersede the information contained in the original Drawings and Specifications issued to the extent referenced and shall become part thereof. No adjustment to the Contract Price will be considered or allowed due to the Contractor or to any sub-contractor or supplier not being familiar with this Addendum.

This Addendum consists of one (1) page. This Addendum is in response to questions from bidders.

1. The Hazardous Materials report on the lead does not have anything for the TCLP report that is required for disposal under MOE regulations. Is there a TCLP report being completed?

- Leachate testing has not been conducted, nor is any report forthcoming.
- Per the specifications:
Section 026133 – Hazardous Materials Abatement
3.6.4.1 - Lead-based paints and their matrices of application are considered hazardous materials and must be disposed of as hazardous waste.
- Should the Contractor choose to pursue alternate disposal options for various painted waste streams, the Contractor will be responsible to arrange and pay for lead leachate testing, if the disposal method or disposal facility requires such testing. Any such testing records must be provided to the Departmental Representative for approval, prior to disposal of waste.

2. Can the deadline be extended?

There is no current intention to extend the deadline.

End of Addendum