

Addendum / Addenda

No./N°
1

Project Description / Description de projet Solicitation No. 16-22151: Water treatment Services for the National Research Council 1200 Montreal rd. campus, Ottawa		
Solicitation No./ N° de sollicitation 16-22151	Project No./N° de projet	W.O. No./N° d'ordre de travail
Departmental Representative / Représentant Ministériel Steve Cassidy	Date March 14, 2017	
On Page 5 of the Statement of work Under the section "Large System Liquid Chemical Addition and Control" The third paragraph reads: "The controller is to be equipped with an automatic system that detects and reacts to Biological Activity real time to base feed and control strategies on both planktonic and sessile bacteria levels. The feed strategies must allow for manual, slug-based or timer feed options. This shall include pre-bleed and lockout capabilities"	It should say: "The controller is to be equipped with an automatic system that also allows for manual, slug-based or timer based feed options. This shall include pre-bleed and lockout capability".	

Upon request, the text above can be provided in French.

