



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

Bid Receiving - PWGSC / Réception des soumissions
- TPSGC

11 Laurier St./11 rue Laurier

Place du Portage, Phase III

Core 0B2 / Noyau 0B2

Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

CE DOCUMENT COMPORTE UNE EXIGENCE
EN MATIÈRE DE SÉCURITÉ / THIS
DOCUMENT CONTAINS A SECURITY
REQUIREMENT.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction

11 Laurier St./11 Rue Laurier

3C2, Place du Portage

Phase III

Gatineau, Québec K1A 0S5

Title - Sujet NRC PLANT CHILLED WATER EXTENSION	
Solicitation No. - N° de l'invitation EJ085-170620/A	Amendment No. - N° modif. 002
Client Reference No. - N° de référence du client 20170620	Date 2017-03-15
GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-340-72324	
File No. - N° de dossier fg340.EJ085-170620	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-03-23	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Brouillet, Richard	Buyer Id - Id de l'acheteur fg340
Telephone No. - N° de téléphone (873) 469-4936 ()	FAX No. - N° de FAX (819) 956-8335
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

EJ085-170620/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fg358

Client Ref. No. - N° de réf. du client

20170620

File No. - N° du dossier

fg358EJ085-170620

CCC No./N° CCC - FMS No./N° VME

Amendment 2 is to amend the BID AND ACCEPTANCE FORM (BA) and to attach Addendum's 1 and 2

**Delete original BID AND ACCEPTANCE FORM (BA) and replace with:
BID AND ACCEPTANCE FORM (BA) - COMBINED PRICE FORM - UNIT PRICE TABLE**

Solicitation No. - N° de l'invitation

EJ085-170620/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fg358

Client Ref. No. - N° de réf. du client

20170620

File No. - N° du dossier

fg358EJ085-170620

CCC No./N° CCC - FMS No./N° VME

BID AND ACCEPTANCE FORM (BA) - COMBINED PRICE FORM - UNIT PRICE TABLE

BA01 IDENTIFICATION

Project: R.010720.001 NCR Plant Chilled Water Extension Phase 2
98 Sussex Drive, Ottawa, Ontario.

BA02 BUSINESS NAME AND ADDRESS OF BIDDER

Name: _____

Address: _____

Telephone: _____ Fax: _____ PBN: _____

E-mail address: _____

Industrial Security Program Organisation Number
(ISP-ORG#) _____

BA03 THE OFFER

The Bidder offers to Canada to perform and complete the Work for the above named project in accordance with the Bid Documents for the **TOTAL BID AMOUNT INDICATED IN APPENDIX 3**.

BA04 PRICE VALIDITY PERIOD

The price quoted shall not be withdrawn for a period of thirty (30) days.

BA05 ACCEPTANCE AND CONTRACT

Upon acceptance of the Contractor's offer by Canada, a binding Contract shall be formed between Canada and the Contractor. The documents forming the Contract shall be the contract documents identified in Contract Documents (CD).

BA06 CONSTRUCTION TIME

The Contractor shall perform and complete the Work within one hundred and four (104) weeks from the date of notification of acceptance of the offer.

BA07 SIGNATURE

Name and title of person authorized to sign on behalf of Bidder (Type or print)

Signature

Date

Solicitation No. - N° de l'invitation

EJ085-170620/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fg358

Client Ref. No. - N° de réf. du client

20170620

File No. - N° du dossier

fg358EJ085-170620

CCC No./N° CCC - FMS No./N° VME

APPENDIX 3 - COMBINED PRICE FORM (1 page)

- 1) The prices per unit shall govern in establishing the Total Extended Amount. Any arithmetical errors in this Appendix will be corrected by Canada.
- 2) Canada may reject the bid if any of the prices submitted do not reasonably reflect the cost of performing the part of the work to which that price applies.

LUMP SUM

The Lump Sum Amount designates Work to which a Lump Sum Arrangement applies.

- (a) Work included in the Lump Sum Amount represents all work not included in the unit price table.

LUMP SUM AMOUNT (LSA) Excluding applicable tax(s)	
---	--

UNIT PRICE TABLE

The Unit Price Table designates Work to which a Unit Price Arrangement applies.

- (a) Work included in each item is as described in the referenced specification section.
- (b) The Price per Unit shall not include any amounts for Work that is not included in that unit price item.

Item	Specification Reference	Class of Labour, Plant or Material	Unit of Measurement	Est. Qty. (EQ)	Price per Unit applicable tax(s) extra (PU)	Extended amount (EQ x PU) applicable tax(s) extra
1	Section 31 23 16.26 – ROCK REMOVAL	Material- Excavate, haul and dispose of rock	Cubic Meters	1000		
TOTAL EXTENDED AMOUNT (TEA) Excluding applicable tax(s)						

TOTAL BID AMOUNT (LSA +TEA) Excluding applicable tax(s)	
---	--

Solicitation No. - N° de l'invitation

EJ085-170620/A

Amd. No. - N° de la modif.

002

Buyer ID - Id de l'acheteur

fg358

Client Ref. No. - N° de réf. du client

20170620

File No. - N° du dossier

fg358EJ085-170620

CCC No./N° CCC - FMS No./N° VME

Public Works and Government Services Canada ADDENDUM No. 1

Real Property Contracting PAGE 1 of 1

Gatineau, Quebec

Project Name: NRC Plant Chilled Water Extension Phase 2

Project Number: R.010720.011 Date: February 06, 2017

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

1 M004 Mechanical Equipment Schedules Sheet 1 of 2

.1 REVISE the wording "FLO-TREX VALVE" to "TRIPLE DUTY VALVE" in "CHILLED WATER PRIMARY PUMP SCHEDULE" and "CHILLED WATER SECONDARY PUMP SCHEDULE".

2 M702 Mechanical Details Sheet 3 of 5

.1 REVISE the wording "FLO-TREX VALVE" to "TRIPLE DUTY VALVE" in Detail 4 VERTICAL INLINE PUMP FLOOR MOUNTED INSTALLATION DETAIL

End of Addendum No. 1

Solicitation No. - N° de l'invitation

EJ085-170620/A

Client Ref. No. - N° de réf. du client

20170620

Amd. No. - N° de la modif.

002

File No. - N° du dossier

fg358EJ085-170620

Buyer ID - Id de l'acheteur

fg358

CCC No./N° CCC - FMS No./N° VME

Public Works and Government Services Canada

ADDENDUM No. 2

**Real Property
Contracting**

PAGE 5 of 2

Gatineau, Quebec

Project Name: NRC Plant Chilled Water Extension Phase 2

Project Number: R.010720.011

Date: March 8, 2017

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

DRAWINGS

- 1 DM101 NRC Plant Lower Level Plan – Demolition
 - .1 ADD Drawing Note #21: THE EXISTING DOOR OF THE CONTROL ROOM NEAR TO GRID LINE 3 AND GRID LINE D TO BE RELOCATED FROM THE EASTERN WALL TO THE NORTHERN WALL AS INDICATED.
- 2 M400 L.B.P. Building Basement Plan HVAC Piping – New Work
 - .1 ADD Drawing Note #10: as below.
PROVIDE A NEW DOOR FOR THE NEW MECHANICAL ROOM AS PER THE FOLLOWING REQUIREMENTS:
1 PAIR OF DOORS
2/915MM X 2134MM X 45MM, HMD/PSF, 1 HR/FR
DOOR: QUANTITY - 2, MATERIAL - HM, FINISH - PNT
FRAME: TYPE - F1, SECTION - S2, MATERIAL - HM, FINISH - PNT
C/W DOOR HARDWARE CONFIRMED BY THE DEPARTMENTAL REPRESENTATIVE
- 3 E100 Site Plan Conduit Run & Details
 - .1 DELETE drawing E100 and replace with revised E100 drawing attached.

Solicitation No. - N° de l'invitation

EJ085-170620/A

Client Ref. No. - N° de réf. du client

20170620

Amd. No. - N° de la modif.

002

File No. - N° du dossier

fg358EJ085-170620

Buyer ID - Id de l'acheteur

fg358

CCC No./N° CCC - FMS No./N° VME

4 E305 LBP Building Basement & Partial Single Line Diagram Electrical – New Work

- .1 REVISE drawing note #1 as follows:
"Accommodate for existing electrical conduits to pass through new walls. Exact size and quantity of existing conduits is unknown. Contractor to investigate on site and provide adequate sealant at conduits to maintain room fire rating. Refer to Structural drawing S127 for details on new wall."
- .2 ADD general note #7 to read as follows:
"Switchboard SWB A 05-220-E001 Cell #9 is rated at 65kA."
- .3 ADD general note #8 to read as follows:
"Switchboard SWB D 05-220-D004 2500A circuit breaker is rated at 50kA."

- 5 ADD B-Series drawings as referenced in the designated substances report. Drawings are attached.

SPECIFICATION

- 1 ADD specification section 01 00 01 – General Conditions
- 2 26 05 43.01 Installation of Cables/Conduits in Trenches and in Ducts
 - .1 Add paragraph 2.5.12 to read as follows;
" Comply with CSA/CAN A23.1 and 23.4 requirements and other required CSA Standards, and OPSD 21.10 10 standard."
- 3 28 31 00 Fire Detection and Alarm
 - .1 Add paragraph 2.1.10 to read as follows;
Existing fire alarm is a Tyco system.

End of Addendum No. 2