

Questions and Answers

No./N°
2

Project Description / Description de projet Solicitation No. 16-22151: Water treatment Services for the National Research Council 1200 Montreal rd. campus, Ottawa		
Solicitation No./ N° de sollicitation 16-22151	Project No./N° de projet	W.O. No./N° d'ordre de travail
Departmental Representative / Représentant Ministériel Steve Cassidy	Date March 16, 2017	
Questions: 12. For the closed loops what is the present corrosion inhibitor in each system (nitrite, molybdate, organic etc)? 13. What monitoring is done by NRC Staff?	Answers: 12. <i>Phosphinosuccinic Oligomer</i> 13. <i>The cooling towers are checked at least weekly and the closed loops monthly. Chemical inventories are also monitored and reported by the onsite staff. Most repairs are done by the onsite staff on an as needed basis.</i>	

Upon request, the text above can be provided in French.

