



Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

revisions	description	date
3	ISSUED FOR ADDENDUM #02	2017/03/07
2	ISSUED FOR 66% REVIEW	2013/06/10
1	ISSUED FOR 33% REVIEW	2013/03/15

A	B	C
A	B	C

project
NRC PLANT CHILLED WATER EXTENSION PHASE II
OTTAWA, ON

drawing
MECHANICAL GCP BUILDING MECHANICAL ROOM AND NATIONAL GALLERY TUNNEL PLAN -ABATEMENT

Designed By
Date
Drawn By
Date
Reviewed By
Date
Approved By
Date
Tender

A.WANG, P.ENG./M.E.
2012/06/10
M.CAI, P.ENG./J.E.M.
2013/08/16
J.C.
2013/08/16
C.J.K.
2013/08/16

Conçu par
Dessiné par
Examiné par
Approuvé par
Soumission

Project Manager
Project no.
R.010720.011
Drawing no.
B003

Administrateur de projets
No. du projet
No. du dessin

- GENERAL NOTES**
- CONTRACTOR TO NOTIFY DEPARTMENTAL REPRESENTATIVE IMMEDIATELY OF ANY DISCREPANCIES BETWEEN DRAWING AND SITE CONDITIONS AS NOTED DURING ABATEMENT AND/OR DEMOLITION.
 - THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ARCHITECTURAL, CIVIL, ELECTRICAL, MECHANICAL AND STRUCTURE SERIES DRAWINGS.
 - LEAD BASED PAINT IS PRESENT THROUGHOUT WORK AREA. THIS MATERIAL IS NOT EXPECTED TO REQUIRE ABATEMENT OR DISTURBANCE, HOWEVER IF IT IS DISTURBED PLEASE CONTACT THE DEPARTMENTAL REPRESENTATIVE FOR FURTHER DIRECTION
 - FOLLOW PROPER WORK PROCEDURES OUTLINED IN SILICA PRECAUTIONS SPECIFICATION SECTION 02 82 17 WHEN DISTURBING ALL MASONRY, CONCRETE, BRICKS, MORTAR, OR ANY MATERIAL THAT MAY CONTAIN CRYSTALLINE SILICA. REFER TO ARCHITECTURAL, MECHANICAL AND STRUCTURAL SERIES DRAWINGS FOR POTENTIAL AREAS OF DISTURBANCE.
 - ASBESTOS-CONTAINING INSULATION PRESENT ON DOMESTIC HOT WATER TANK AND ASSOCIATED PIPING. NOTIFY DEPARTMENTAL REPRESENTATIVE IMMEDIATELY IF DOMESTIC PIPING IS TO BE DISTURBED

LEGEND

REMOVE EXISTING BRICK AND ASBESTOS-CONTAINING MORTAR (3% CHRYSOTILE) TO MEET DIMENSIONS FOR NEW CHILLED WATER SUPPLY AND CHILLED WATER RETURN PIPING. REFER TO STRUCTURAL DRAWINGS FOR ACTUAL DIMENSIONS. TREAT ALL WASTE AS ASBESTOS-CONTAINING INCLUDING BRICKS AND MORTAR

