

KWIKWEXWELHP HEALING VILLAGE

APPENDIX C – Device list and Device Locations

| KWIKWEXWELHP HEALING VILLAGE | | | | | | | | | | | | |
|---|----------------------------|---------------------|----------------|----------------|---------------|---------------|-------------|--------------------|--------|------|-------------------|----------------------|
| FIRE PROTECTION SYSTEMS - ASPECT # 1: Fire alarm system/devices | | | | | | | | | | | | |
| Component | main alarm panel | manual pull station | smoke detector | smoke detector | heat detector | heat detector | flow switch | Supervisory device | strobe | bell | ancillary devices | magnetic door holder |
| Device Type | | | duct | photo/ion | fixed temp | rate of rise | | other | | | | |
| BUILDING | Make/Stage | Qty | Qty | Qty | Qty | Qty | Qty | Qty | Qty | Qty | Qty | Qty |
| A | 1 Edwards EST-3 - 2 stage | 7 | | 1 | | | 2 | 4 | 2 | 5 | | |
| B | 2 Edwards EST-3x - 2 stage | 8 | 4 | 13 | | | 2 | 5 | | 11 | 4 | |
| C | 1 Edwards EST-3x - 2 stage | 2 | | | | 4 | | | 2 | 2 | 1 | |
| D | 1 Edwards EST-3x - ? stage | 5 | | 23 | | 1 | 4 | 8 | | 6 | | 4 |
| E | 1 Edwards EST-3x - 2 stage | 5 | | 12 | | | 1 | 7 | | 4 | | 2 |
| F | 1 Edwards EST-3x | 3 | | 13 | | 2 | 2 | 5 | | 5 | | |
| G | 1 Edwards EST-3x | 3 | | 23 | | 6 | 4 | 8 | | 6 | | 4 |
| 1 | 1 fireshield - 1 stage | | | 2 | | | | | | 1 | 2 | |
| 7 | 1 Edwards EST-3x - 2 stage | 2 | | | | 7 | | | | 1 | | |
| 9 | 1 Edwards EST-3x - 2 stage | 3 | | | | 16 | | | | 2 | 2 | |
| 13 | 1 Edwards EST-3 - 2 stage | 3 | | 4 | 1 | 10 | | | | 1 | 1 | |
| 15 | 1 Edwards EST-3x - 2 stage | 3 | | | | 19 | | | | 1 | | |
| 21 | 1 Edwards EST-3 - 2 stage | 4 | | | | 7 | | | | 3 | | |
| 33 | 1 Edwards EST-3x - 1 stage | 2 | | | | 5 | | | | 1 | 1 | |
| 35 | 1 Edwards EST-3x - 1 stage | 3 | | | | 6 | | 2 | | 1 | | |
| TOTAL | 15 | 53 | 4 | 91 | 1 | 83 | 15 | 39 | 4 | 50 | 11 | 20 |

| KWIKWEXWELHP HEALING VILLAGE | | | | | | |
|--|----------------------|----------------------|-------------|---|------------|----------------|
| FIRE PROTECTION SYSTEMS - ASPECT # 2: Sprinkler systems/trees | | | | | | |
| Component | Dry sprinkler system | Wet sprinkler system | check valve | compressor for dry system if applicable | flow valve | shut off valve |
| Device Type | | | | | | |
| BUILDING | Qty | Qty | Qty | Qty | Qty | Qty |
| A | | 1 | 1 | | | 4 |
| B | | | | | | 5 |
| D | 1 | | | | | 5 |
| E | 1 | | | | | 5 |
| F | 1 | | | | | 4 |
| G | 1 | | | | | 5 |
| 33 | 1 | | 1 | 1 | 1 | 1 |
| TOTAL | 5 | 1 | 2 | 1 | 1 | 29 |

KWIKWEXWELHP HEALING VILLAGE
FIRE PROTECTION SYSTEMS - ASPECT # 3: Emergency Lighting

| BUILDING | Location | Make | Watts | # of remote heads |
|-----------------|---------------------|-------------|--------------|--------------------------|
| Bldg B | Mid level stairwell | Ready-lite | 250 | 2 |
| Bldg B | Maintenance rm 108 | Ready-lite | 144 | 2 |
| Bldg B | Hobby Shop | Ready-lite | 144 | 0 |
| Bldg B | rm 2109 | Ready-lite | 200 | 12 |
| Bldg B | rm 2101 | Ready-lite | 100 | 0 |
| Bldg B | rm 1807 | Ready-lite | 200 | 16 |
| Bldg B | rm 1206 | Ready-lite | 100 | 6 |
| Bldg C | elec rm | Lumacell | 360 | 6 |
| Bldg C | gen rm south | Lumacell | 200 | 4 |
| Bldg C | gen rm north | Lumacell | 200 | 4 |
| Bldg D | SALMON HOUSE | lumacell | 200 | 24 |
| Bldg E | EAGLE HOUSE | lumacell | 200 | 18 |
| Bldg 7 | rm 702 | Ready-lite | 150 | 0 |
| Bldg 9 | by 908 | Ready-lite | 44 | 0 |
| Bldg 9 | kitchen | Beghelli | 40 | 0 |
| Bldg 9 | dining area | stanpro | 36 | 0 |
| Bldg 13 | main area | lumacell | 144 | 0 |
| Bldg 13 | main area | lumacell | 144 | 0 |
| Bldg 13 | hallway | lumacell | 144 | 0 |
| Bldg 13 | rm 107 | Ready-lite | 150 | 0 |
| Bldg 15 | front entrance | lumacell | 36 | 0 |
| Bldg 21 | entrance rm 2101 | Ready-lite | 36 | 0 |
| Bldg 21 | rm 2103 | Lithonia | 36 | 0 |
| Bldg 33 | mech rm | stanpro | 250 | 20 |
| Bldg 33 | community kitchen | Ready-lite | 36 | 0 |
| Total | 25 | | | 114 |

| KWIKWEXWELHP HEALING VILLAGE | | | |
|---|-----|---------|----------------------------|
| FIRE PROTECTION SYSTEMS - ASPECT # 4: Fire Extinguishers/Exit lights on battery | | | |
| Type | ABC | K-guard | All exit lights on battery |
| BUILDING | Qty | Qty | Qty |
| A | 8 | | |
| B | 17 | | |
| C | 2 | | |
| D | 10 | | |
| E | 6 | | |
| F | 4 | | |
| G | 10 | | |
| 1 | 1 | | |
| 7 | 3 | | |
| 9 | 5 | 1 | |
| 13 | 3 | | |
| 15 | 2 | | |
| 18 | 2 | | |
| 21 | 3 | | |
| 33 | 2 | 1 | |
| 35 | 3 | | |
| 39 | 1 | | |
| 40 | 1 | | |
| 43 | 1 | | |
| 44 | 1 | | |
| 47 | 1 | | |
| 47A | 1 | | |
| 52 | 1 | | |
| TOTAL | 88 | 2 | none |

KWIKWEXWELHP HEALING VILLAGE**FIRE PROTECTION SYSTEMS - ASPECT # 5:**
Fire Hydrants

| Equipment | Hydrant complete with hose | |
|-----------------------------|----------------------------|--------|
| Location on site | Make | Type |
| In front of bldg D | McAvity | M67 |
| In front of bldg 15 | Terminal city | C71P |
| In front of bldg F | Terminal city | C71P |
| Next to bldg B | Century Mueller | 83w0 |
| In front of bldg 33 | Century Mueller | 12KOOB |
| Next to the "Sweat Grounds" | Century Mueller | 2103A |
| Next to bldg A | Terminal city | C71P |
| TOTAL | 7 | |

KWIKWEXWELHP HEALING VILLAGE**FIRE PROTECTION SYSTEMS - ASPECT # 6:**
Back Flow Preventers

| | Domestic water | Fire | Confined space |
|-----------------|----------------|------------|------------------|
| BUILDING | Qty | Qty | YES or NO |
| A | 1 | 1 | NO |
| B | 1 | 2 | NO |
| D | 1 | 2 | YES |
| E | 1 | 2 | YES |
| F | 1 | 2 | YES |
| G | 1 | 2 | YES |
| 33 | 0 | 1 | YES |
| TOTAL | 6 | 12 | |

KWIKWEXWELHP HEALING VILLAGE**FIRE PROTECTION SYSTEMS - ASPECT # 8:****Kitchen Sprinkler Suppression systems**

| BUILDING | 9-main kitchen | 33-com kitchen |
|--------------------------------|--------------------|------------------|
| Make | Badger Range Guard | Kidde |
| Model | RG-4GM | Wet chem WHDR260 |
| Actuation type | mechanical | mechanical |
| Number of cylinders | 1 | 1 |
| Number of nozzles | 4 | 2 |
| Number of fusible links | 3 | 3 |
| Size of cylinders | 4 gal | 2.66 gal |