

PART 1 - GENERAL

1.1 RELATED  
SECTIONS

- .1 Section 03 20 00 - Concrete Reinforcing.
- .2 Section 03 30 00 - Cast-in-Place Concrete.
- .3 Section 07 92 10 - Joint Sealing.

1.2 REFERENCES

- .1 Canadian Standards Association (CSA)
  - .1 CAN/CSA-A23.1-14/A23.2-14, Concrete Materials and Methods of Concrete Construction.
  - .2 CAN/CSA-O86-14, Engineering Design in Wood.
  - .3 CSA O121-08 (R2013), Douglas Fir Plywood.
  - .4 CSA O151-09, Canadian Softwood Plywood.
  - .5 CSA O153-13, Poplar Plywood.
  - .6 CAN3-0188.0-M78, Standard Test Methods for Mat-Formed Wood Particleboards and Waferboard.
  - .7 CSA O437 Series-93 (R2011), Standards for OSB and Waferboard.
  - .8 CSA S269.1-16 (R2003), Falsework and Formwork for Construction Purposes.

1.3 SHOP DRAWINGS

- .1 Submit shop drawings for formwork and falsework in accordance with Section 01 33 00 - Submittal Procedures.
  - .2 Indicate method and schedule of construction, shoring, stripping and re-shoring procedures, materials, arrangement of joints, special architectural exposed finishes, ties, liners, and locations of temporary embedded parts. Comply with CSA S269.1-16, for falsework drawings Comply with CAN/CSA-S269.1-16 for formwork drawings.
  - .3 Indicate formwork design data, such as permissible rate of concrete placement, and temperature of concrete, in forms.
  - .4 Indicate sequence of erection and removal of formwork/falsework as directed by Departmental Representative.
-

1.3 SHOP DRAWINGS  
(Cont'd)

- .5 Each shop drawing submission shall bear stamp and signature of qualified Professional Engineer registered or licensed in Province of Newfoundland and Labrador, Canada.

1.4 WASTE  
MANAGEMENT AND  
DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal and the Waste Reduction Workplan.
- .2 Place materials defined as hazardous or toxic waste in designated containers.
- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.
- .4 Use sealers, form release and stripping agents that are non-toxic, biodegradable and have zero or low VOC's.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Formwork materials:
  - .1 Use formwork materials to CAN/CSA-A23.1-16.
- .2 Form ties:
  - .1 Removable or snap-off metal ties, fixed or adjustable length, free of devices leaving holes larger than 25 mm diameter in concrete surface.
- .3 Form release agent: non-toxic, chemically active release agents containing compounds that react with free lime present in concrete to provide water insoluble soaps, preventing set of film of concrete in contact with form.
- .4 Falsework materials: to CSA-S269.1-16.
  - .1 Materials required to bear grade marks, or be accompanied with certificates, test reports or other proof of conformity.
- .5 Premoulded joint fillers:
  - .1 Bituminous impregnated fiberboard to ASTM D1751.

2.1 MATERIALS  
(Cont'd)

- .6 Bond Breaker:
  - .1 Impermeable tube formed of polyvinylchloride, rubber or similar material to the approval of the Departmental Representative. Internal diameter equal to dowels.
- .7 Sealant: to Section 07 92 10 - Joint Sealing.

PART 3 - EXECUTION

3.1 FABRICATION AND  
ERECTION

- .1 Verify lines, levels and centres before proceeding with formwork/falsework and ensure dimensions agree with drawings.
- .2 Obtain Departmental Representative's approval for use of earth forms framing openings not indicated on drawings.
- .3 Hand trim sides and bottoms and remove loose earth from earth forms before placing concrete.
- .4 Fabricate and erect falsework in accordance with CSA S269.1-16.
- .5 Fabricate and erect formwork in accordance with CAN/CSA-S269.-16 to produce finished concrete conforming to shape, dimensions, locations and levels indicated within tolerances required by CAN/CSA-A23.1-16.
- .6 Align form joints and make watertight. Keep form joints to minimum.
- .7 Use 25 mm chamfer strips on external corners and/or 25 mm fillets at interior corners, joints, unless specified otherwise.
- .8 Form chases, slots, openings, drips, recesses, expansion and control joints as indicated.
- .9 Build in anchors, sleeves, and other inserts required to accommodate Work specified in other sections. Assure that all anchors and inserts will not protrude beyond surfaces designated to receive applied finishes, including painting.

3.1 FABRICATION AND  
ERECTION  
(Cont'd)

- .10 Clean formwork in accordance with  
CAN/CSA-A23.1-16, before placing concrete.

3.2 REMOVAL AND  
RESHORING

- .1 Leave formwork in place for following minimum  
periods of time after placing concrete.  
.1 5 days for beams, slabs, decks and other  
structural members, or 3 days when replaced  
immediately with adequate shoring to standard  
specified for falsework.
- .2 Remove formwork when concrete has reached 75% of  
its design strength or minimum period noted above,  
whichever comes later, and replace immediately  
with adequate reshoring.
- .3 Provide all necessary reshoring of members where  
early removal of forms may be required or where  
members may be subjected to additional loads  
during construction as required.
- .4 Space reshoring in each principal direction at not  
more than 3000 mm apart.
- .5 Re-use formwork and falsework subject to  
requirements of CAN/CSA-A23.1-16.

3.3 JOINT FILLERS

- .1 Locate and form expansion joints as indicated.  
Install joint filler in all joints.
- .2 Use 13 mm thick joint filler to separate  
slab-on-grade and extend joint filler from bottom  
of slab to within 25 mm of finished slab surface  
unless indicated otherwise.

3.4 JOINT SEALANT

- .1 Fill expansion and control joints with sealer as  
per manufacturer instructions.