



RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions
Travaux publics et Services gouvernementaux
Canada
189 Prince William St Rm 405
189, rue Prince William, pièce 405
Saint-John, NB E2L 2B9
Bid Fax: (506) 636-4376

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Saint John, NB (STJ)
189 Prince William St., Rm 405
189, rue Prince William, Pc 405
St. John, NB E2L 2B9

Title - Sujet Mechanical Sys. Maint.-Monctn&Sussx	
Solicitation No. - N° de l'invitation W6837-170004/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client W6837-170004	Date 2017-03-28
GETS Reference No. - N° de référence de SEAG PW-\$STJ-003-4105	
File No. - N° de dossier STJ-6-39207 (003)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2017-04-04	
Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Doucet (STJ), Gisele	Buyer Id - Id de l'acheteur stj003
Telephone No. - N° de téléphone (506) 636-4541 ()	FAX No. - N° de FAX (506) 636-4376
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Cette modification à l'invitation numéro quatre (4) est soumise pour inclure l'addenda numéro 4 suivant.

La modification qui suit apportée aux documents de soumission entre en vigueur dès maintenant. L'addenda fera partie des documents de contrat.

Toutes autres conditions ne changent pas.

Addenda numéro 4.

1. QUESTIONS / RÉPONSES

Q1. Under Description – Major Operational Inspection, Section 3.5 Software Maintenance

There are three types of controls (VCI, Honeywell, Automated Logic) there would be no way for any one company to provide software maintenance for all three. Please clarify.

R1. The Contractor will provide this service on all Controls listed in this Spec's 1.14 Maintenance Inspections .1 Lines .1 and .2 and as per Annex "A", "B" and "C". Also they will provide repair service if required as per 1.15 Basis of Payment. The Contractor must be qualified and knowledgeable as per 1.19 Qualifications .1 and .2 in all 3 controls systems

Q2. In the event of an unplanned equipment failure (motor, pump, bearing, compressor, etc), is the contractor required to cover the costs of those repairs?

R2. For any unforeseen equipment failure the Contractor will provide service as per the hourly rate and materials as per the Spec, under Section 1. 15 Basis of Payment .2 line .3, .4 and .5.

Q3. The spec does not mention filters or belt replacements. A typical maintenance on air handling equipment is usually 4 times per year for filter replacements, and once yearly for belt replacement. Are we to price this maintenance without allowing for these materials?

R3. For any unforeseen equipment failure the Contractor will provide service as per the hourly rate and materials as per the Spec, under Section 1. 15 Basis of Payment .2 line .3, .4 and .5.