



**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
**Bid Receiving Public Works and Government**  
**Services Canada/Réception des soumissions Travaux**  
**publics et Services gouvernementaux Canada**  
**800 Burrard Street, Room 219**  
**800, rue Burrard, pièce 219**  
**Vancouver**  
**British Columbia**  
**V6Z 0B9**  
**Bid Fax: (604) 775-9381**

## **SOLICITATION AMENDMENT**

## **MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du**  
**fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Maitland Island Tower	
<b>Solicitation No. - N° de l'invitation</b> F1705-160229/A	<b>Amendment No. - N° modif.</b> 001
<b>Client Reference No. - N° de référence du client</b>	<b>Date</b> 2017-04-07
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-015-8028	
<b>File No. - N° de dossier</b> PWY-6-39367 (015)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin</b> <b>at - à 02:00 PM</b> <b>on - le 2017-04-26</b>	<b>Time Zone</b> <b>Fuseau horaire</b> Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Chan (PWY), Scarlett	<b>Buyer Id - Id de l'acheteur</b> pwy015
<b>Telephone No. - N° de téléphone</b> (604) 369-7853 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Maitland Island Tower, Douglas Channel – Kitimat, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/</b> <b>de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

Solicitation No. - N° de l'invitation  
F1705-160229/A

Amd. No. - N° de la modif.  
001

Buyer ID - Id de l'acheteur  
pwy015

Client Ref. No. - N° de réf. du client

File No. - N° du dossier  
PWY-6-39367

CCC No./N° CCC - FMS No/ N° VME

---

### **Solicitation Amendment 001**

This solicitation amendment is raised to address contractors' questions and to include Addendum #1. All other terms and conditions remain unchanged.

#### **Questions from contractors:**

Q1. On drawing WM-695-1000, it is mentioned that the tower has to be triangular in cross section. Is a square section acceptable if we believe to be more economical?

A1. A square section is acceptable.

Q2. On drawing WM-695-1000, it is mentioned that the tower twist @ top is 0.05 degrees (table of Tower Specifications). Section 13 36 13, Clause 1.7.7 states « maximum twist and tilt are 0.5 degrees. Please clarify.

A2. Maximum twist is 0.05 degrees, maximum tilt is 0.5 degrees.

Q3. On drawing WM-695-1000, it is mentioned « N/A » for paint. Section 13 36 13, Clause 3.5 deals with surface preparation and coating system to be applied. Please clarify.

A3. Hot-dipped galvanized finish. No paint required.

**Project Name:** Maitland Island Tower

**Project Number:** F1705-160229

**Date:** April 7, 2017

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

**Plans**

WM-695-1000-CCG MAITLAND ANTENNA LAYOUT

Drawing will be revised to remove requirement for a triangular cross section. A square cross section is acceptable.

**Specifications**

SECTION 13 36 13 – STEEL TOWERS

**Part 1            General**

**1.7                DESIGN REQUIREMENTS**

.7                To read as follows:

The operational requirement for maximum twist is 0.05 degrees and for maximum tilt is 0.5 degrees.

**Part 3            Execution**

**3.5                SURFACE PREPARATION**

This section is to be removed from the requirements. Tower to have a hot dipped galvanized finish, no requirement to paint.